



- NOTES :-**
- ALL DEVELOPMENT ABOVE THE HIGH WATER MARK IS NOT PART OF THE FORESHORE LICENCE BUT IS SUBJECT OF A SEPARATE PROPOSAL TO AN BORD PLEANÁLA VIA A STRATEGIC INFRASTRUCTURE DEVELOPMENT APPLICATION.
 - THIS DRAWING PROVIDES AN INDICATIVE DESIGN AND CONSTRUCTION SEQUENCE FOR THE IRISH LANDFALL AT CLAYCASTLE. THE DRAWING HAS BEEN DEVELOPED TO AID IN THE ENVIRONMENTAL ASSESSMENT.
 - LANDFALL DESIGN INCLUDING TEMPORARY FACILITIES (SPOIL STORAGE LOCATION) TO BE CONFIRMED IN DETAILED DESIGN. HOWEVER, ALL TEMPORARY WORKS TO BE CONTAINED IN THE COMPOUND FENCING SHOWN.
 - THE CABLE DIAMETERS ARE CURRENTLY UNKNOWN AND ARE SUBJECT TO DETAILED DESIGN. HOWEVER, IT IS ANTICIPATED THAT EACH ELECTRICAL CABLE WILL HAVE A DIAMETER OF BETWEEN 100MM AND 200MM AND THE FIBRE OPTIC LINK WILL HAVE A DIMENSION OF APPROXIMATELY 20MM.

LEGEND :-

TRENCH	HARD SURFACE
TJB	GRASSED AREA
CONSTRUCTION COMPOUND	BUILDING

GEODETIC DATA:			
GIS COORD SYSTEM:	EPSG:	VERTICAL DATUM:	UNITS:
WGS 84 UTM-29N	32629	O.D. MALIN	METERS
DOCUMENT No.	DOCUMENT TITLE		

REFERENCE DOCUMENTS

THE INFORMATION CONTAINED ON THIS DRAWING IS CONFIDENTIAL, UNLESS AGREED OTHERWISE (BY A RELEVANT CONTRACT OR IN WRITING) THIS DRAWING SHALL REMAIN THE PROPERTY OF WOOD PLC. WITHOUT PRIOR AGREEMENT THE DRAWING SHOULD NOT BE USED FOR ANY OTHER PURPOSE THAN THAT AGREED, NOR SHOULD THE DRAWING BE REPRODUCED IN WHOLE, OR PART, OR PASSED ONTO ANY THIRD PARTY.

C	09.03.21	ISSUED FOR DRAFT SUBMISSION	BCA	JKE	CMU	BOK	
B	24.02.21	ISSUED FOR REVIEW	BCA	JKE	CMU	BOK	
A	23.02.21	ISSUED FOR INTERNAL REVIEW	BCA	JKE	CMU	BOK	
REV	DATE	REVISION	BY	CHK	ENG	PM	CLIENT



PROJECT	CELTIC INTERCONNECTOR	FOR PLANNING PURPOSES ONLY - NOT FOR CONSTRUCTION -
CLIENT		

TITLE			
IRISH SHORE APPROACH AND LANDFALL AT CLAYCASTLE OPTION 2 - PHASE ONE			
DRAWN: B.CAULFIELD	DATE: 22.02.21	PROJECT No. 400584	SCALE AS SHOWN SHEET 01
CHWEL: C.MURRAY	DATE: 22.02.21	CAD REF. 400584-PL-DWG-007_C	
ENG: B.OKEEFFE	DATE: 22.02.21	DRAWING NUMBER 400584-PL-DWG-007	REV. C
CLT. APP.			