



---

The submissions on this file and the Inspector's report were considered at a Board meeting held on January 10<sup>th</sup> 2017.

The Board decided to grant permission generally in accordance with the Inspector's recommendation, for the following reasons and considerations, and subject to the following conditions.

### **Reasons and Considerations**

Having regard to the zoning objective, the design and layout of the proposed development and the pattern of development in the area, it is considered that, subject to compliance with conditions below, the proposed development would not seriously injure the visual amenities of the area or residential amenity of property in the vicinity or have a negative impact on the nature and setting of a protected structure. The proposed development would, therefore, be in accordance with the proper planning and sustainable development of the area.

### **Conditions**

1. The development shall be carried out and completed in accordance with the plans and particulars lodged with the application except as may otherwise be required in order to comply with the following conditions. Where such conditions require details to be agreed with the planning authority, the developer shall agree such details in writing with the planning authority prior to commencement of development and the

development shall be carried out and completed out in accordance with the agreed particulars.

**Reason:** In the interest of clarity.

2. The developer shall facilitate the preservation, recording and protection of archaeological materials or features that may exist within the site. In this regard, the developer shall -

- (a) notify the planning authority in writing at least four weeks prior to the commencement of any site operation (including hydrological and geotechnical investigations) relating to the proposed development,

- (b) employ a suitably-qualified archaeologist who shall monitor all site investigations and other excavation works, and

- (c) provide arrangements, acceptable to the planning authority, for the recording and for the removal of any archaeological material which the authority considers appropriate to remove.

In default of agreement on any of these requirements, the matter shall be referred to An Bord Pleanála for determination.

**Reason:** In order to conserve the archaeological heritage of the site and to secure the preservation and protection of any remains that may exist within the site.

3. During the construction and demolition phases of the proposed

development the noise level shall not exceed 55 dB(A) rated sound level, as measured at the nearest dwelling. Procedures for the purpose of determining compliance with this limit shall be submitted to, and agreed in writing with, the planning authority prior to commencement of development.

**Reason:** To protect the [residential] amenities of property in the vicinity of the site

4. All repair/restoration works shall be carried out in accordance with best conservation practice as detailed in the application and the “Architectural Heritage Protection Guidelines for Planning Authorities” (Department of Arts, Heritage and the Gaeltacht, 2011). The repair/restoration works shall retain the maximum amount possible of surviving historic fabric in-situ including structural elements, plasterwork and joinery and shall be designed to cause minimum interference to the building structure and/or fabric.

**Reason:** To ensure that the integrity of the historic structures is maintained and that the structures are protected from unnecessary damage or loss of fabric

- 5 Site development and building works shall be carried out only between the hours of 0800 to 1900 Mondays to Fridays inclusive, between 0800 to 1400 hours on Saturdays and not at all on Sundays and public holidays.  
Deviation from these times will only be allowed in exceptional circumstances where prior written approval has been received from the planning authority.

**Reason:** In order to safeguard the residential amenities of property in the vicinity.

6. Water supply and drainage arrangements, including the attenuation and disposal of surface water, shall comply with the requirements of the planning authority for such works and services.

**Reason:** In the interest of public health

**Board Member**

---

Paul Hyde

**Date:** 10.01.17