



An
Bord
Pleanála

Board Direction
PLPL03.248419

The submissions on this file and the Inspector's report were considered at a Board meeting held on September 19th 2017.

The Board decided to grant permission generally in accordance with the Inspector's recommendation, for the following reasons and considerations, and subject to the following conditions.

Reasons and Considerations

Having regard to the pattern of development in the vicinity and the policies of the current Clare County Development Plan 2017-2023, it is considered that , subject to compliance with the conditions set out below, the proposed development would not seriously injure the visual or residential amenity of the area, nor result in any adverse impacts on groundwater or surface water and would be acceptable in terms of traffic safety. The proposed development would, therefore, be in accordance with the proper planning and sustainable development of the area.

Conditions

1. The development shall be carried out and completed in accordance with the plans and particulars lodged with the application, as amended by the further plans and particulars submitted on the 13th Day of February 2017,

except as may otherwise be required in order to comply with the following conditions. Where such conditions require details to be agreed with the planning authority, the developer shall agree such details in writing with the planning authority prior to commencement of development and the development shall be carried out and completed in accordance with the agreed particulars.

Reason: In the interests of clarity.

2. The water supply to serve the proposed dwelling shall have sufficient yield to serve the proposed development, and the water quality shall be suitable for human consumption. Details, demonstrating compliance with these requirements, shall be submitted to, and agreed in writing with, the planning authority prior to commencement of development.

Reason: To ensure that adequate water is provided to serve the proposed dwelling, in the interest of public health.

3. (a) The treatment plant and polishing filter shall be located, constructed and maintained in accordance with the details submitted to the planning authority on the 13th Day of February 2017 and in accordance with the requirements of the document entitled "Code of Practice - Wastewater Treatment and Disposal Systems Serving Single Houses (p.e. ≤ 10)" – Environmental Protection Agency, 2009. No system other than the type proposed in the submissions shall be installed unless agreed in writing with the planning authority.

(b) Certification by the system manufacturer that the system has been properly installed shall be submitted to the planning authority within four weeks of the installation of the system.

(c) A maintenance contract for the treatment system shall be entered into and paid in advance for a minimum period of five years from the first occupancy of the dwellinghouse and thereafter shall be kept in place at all times. Signed and dated copies of the contract shall be submitted to, and agreed in writing with, the planning authority within four weeks of the installation.

(d) Surface water soakways shall be located such that the drainage from the dwelling and paved areas of the site shall be diverted away from the location of the polishing filter.

(e) Within three months of the first occupation of the dwelling, the developer shall submit a report from a suitably qualified person with professional indemnity insurance certifying that the proprietary effluent treatment system has been installed and commissioned in accordance with the approved details and is working in a satisfactory manner and that the polishing filter is constructed in accordance with the standards set out in the EPA document.

Reason: In the interest of public health.

4. All public service cables for the development, including electrical and telecommunications cables, shall be located underground throughout the site.

Reason: In the interest of visual amenity.

5. All surface water generated within the site boundaries shall be collected and disposed of within the curtilage of the site. No surface water from roofs, paved areas or otherwise shall discharge onto the public road or adjoining properties.

Reason: In order to prevent pollution.

6. Notwithstanding the exempted development provisions of the Planning and Development Regulations, 2001, and any statutory provision replacing or amending them, no development falling within Class 1 or Class 3 of Schedule 2, Part 1 of those Regulations shall take place within the curtilage of the house without a prior grant of planning permission.

Reason: In order to ensure that a reasonable amount of rear garden space is retained for the benefit of the occupants of the dwelling.

7. The developer shall pay to the planning authority a financial contribution in respect of public infrastructure and facilities benefiting development in the area of the planning authority that is provided or intended to be provided by or on behalf of the authority in accordance with the terms of the

Development Contribution Scheme made under section 48 of the Planning and Development Act 2000, as amended. The contribution shall be paid prior to commencement of development or in such phased payments as the planning authority may facilitate and shall be subject to any applicable indexation provisions of the Scheme at the time of payment. Details of the application of the terms of the Scheme shall be agreed between the planning authority and the developer or, in default of such agreement, the matter shall be referred to An Bord Pleanála to determine the proper application of the terms of the Scheme.

Reason: It is a requirement of the Planning and Development Act 2000, as amended, that a condition requiring a contribution in accordance with the Development Contribution Scheme made under section 48 of the Act be applied to the permission.

Board Member

Date: 19/09/2017

Terry O'Niadh