

Board Direction BD-002972-19 ABP-302664-18

The submissions on this file and the Inspector's report were considered at a Board meeting held on 29/04/2018.

The Board decided to allow the appeal, generally in accordance with the Inspector's recommendation, and to direct the Building Control Authority as follows:

Remove condition number 2

Reasons and Considerations

Having regard to the existing building and the previously approved FSC applications and noting that neither BB100, IS 3218: 2013 or The Department Education Technical Guidance Document 003 seek the provision of an L1 system in schools of this scale and design, it is not considered necessary in this instance to provide an L1 system in this school to achieve compliance with Part B of the Building Regulations 1997 to 2017.

Board Member		Date:	08/05/2019
	Stephen Bohan	_	