

An  
Bord  
Pleanála

**Board Direction**  
**BD-011641-23**  
**ABP-312819-22**


The submissions on this file and the Inspectors report were considered at a Board meeting held on 12/01/2023

The Board decided to refuse the appeal, generally in accordance with the Inspector's recommendation, for the reasons and considerations set out below:

#### **Reasons and Considerations**

Having regard to the form and layout of the building, and the nature of the proposed works, the Revised Fire Safety Certificate Application and supporting documentation, the appeal, the reports of the Building Control Authority and the Appellant and to the recommendations of the reporting Inspector, in particular the extent of fire testing information and the lack of clarity of information provided with regard to the Green Wall System and its component parts, the Board is not satisfied that it has been fully demonstrated that the proposed installation of the Green Wall System would comply with the requirements of Section B2 Internal Fire Spread ( Linings) of the Second Schedule to the Building Regulations 1997-2019.

**Board Member**

  
Michelle Fagan

**Date:** 13/01/2023

