



**An  
Bord  
Pleanála**

**Board Direction  
BD-013748-23  
ABP-313967-22**

The submissions on this file and the Inspector's report were considered at a Board meeting held on 14/09/2023.

The Board decided to grant permission generally in accordance with the Inspector's recommendation, for the following reasons and considerations, and subject to the following conditions.

### **Reasons and Considerations**

Having regard to the nature and scale of the proposed infill development for a house and wastewater treatment system, within the settlement boundary of Gormanstown and on a site which is zoned 'A1 – Existing Residential', it is considered that the proposal would be in accordance with the Meath County Development Plan 2021-2027, and subject to compliance with the conditions set out below, the proposed development would not seriously injure the amenities of the area or of property in the vicinity and would, therefore, be in accordance with the proper planning and sustainable development of the area.

## 1.0 Conditions

1.	<p>The development shall be carried out and completed in accordance with the plans and particulars lodged with the application on the 11<sup>th</sup> day of February 2022, except as may otherwise be required in order to comply with the following conditions. Where such conditions require details to be agreed with the planning authority, the developer shall agree such details in writing with the planning authority prior to commencement of development and the development shall be carried out and completed in accordance with the agreed particulars.</p> <p><b>Reason:</b> In the interest of clarity.</p>
2.	<p>The developer shall comply with the following requirements of the PA:</p> <p>The proposed concrete kerb shall be provided prior to commencement of development as per Drawing 8023(A3) – Site Layout Plan, which was received on the 27<sup>th</sup> day of May 2022.</p> <p><b>Reason:</b> In the interest of traffic safety.</p>
3.	<p>The site development and construction works shall be carried out such a manner as to ensure that the adjoining streets are kept clear of debris, soil and other material and cleaning works shall be carried on the adjoining public roads by the developer and at the developer's expense on a daily basis.</p> <p><b>Reason:</b> To protect the residential amenities of property in the vicinity.</p>
4.	<p>Site development and building works shall be carried out only between the hours of 0800 to 1900 Mondays to Fridays inclusive, between 0800 to 1400 hours on Saturdays and not at all on Sundays and public holidays. Deviation from these times will only be allowed in exceptional circumstances where prior written approval has been received from the planning authority.</p> <p><b>Reason:</b> In order to safeguard the residential amenities of property in the vicinity.</p>

5.	<p>Water supply and drainage arrangements, including the attenuation and disposal of surface water, shall comply with the requirements of the planning authority for such works and services.</p> <p><b>Reason:</b> In the interest of public health.</p>
6.	<p>a) All surface water generated within the site boundaries shall be collected and disposed of within the curtilage of the site. No surface water from roofs, paved areas or otherwise shall discharge onto the public road or adjoining properties.</p> <p>b) The access driveway to the proposed development shall be provided with adequately sized pipes or ducts to ensure that no interference will be caused to existing roadside drainage.</p> <p><b>Reason:</b> In the interest of traffic safety and to prevent pollution.</p>
7.	<p>a) The proposed septic tank drainage system shall be in accordance with the standards set out in the document entitled "Code of Practice - Wastewater Treatment and Disposal Systems Serving Single Houses (p.e. ≤ 10)" – Environmental Protection Agency, 2009.</p> <p>b) Within three months of the first occupation of the dwelling, the developer shall submit a report from a suitably qualified person with professional indemnity insurance certifying that the proprietary effluent treatment system has been installed and commissioned in accordance with the approved details and is working in a satisfactory manner in accordance with the standards set out in the EPA document.</p> <p>c) A maintenance contract for the treatment system shall be entered into and paid in advance for a minimum period of five years from the first occupancy of the dwellinghouse and thereafter shall be kept in place at all times. Signed and dated copies of the contract shall be submitted to, and agreed in writing with, the planning authority within four weeks of the installation.</p> <p><b>Reason:</b> In the interest of public health.</p>

8.	<p>The applicant shall comply with the requirements of Irish Water.</p> <p><b>Reason:</b> In the interest of public health.</p>
9.	<p>a) The roof colour of the proposed house and garage shall be blue-black, black, dark brown or dark-grey. The colour of the ridge tile shall be the same as the colour of the roof.</p> <p>b) The external walls shall be finished in neutral colours such as grey or off-white.</p> <p><b>Reason:</b> In the interest of visual amenity.</p>
10.	<p>All public service cables for the development, including electrical and telecommunications cables, shall be located underground throughout the site.</p> <p><b>Reason:</b> In the interest of visual amenity.</p>
11.	<p>The developer shall pay to the planning authority a financial contribution in respect of public infrastructure and facilities benefiting development in the area of the planning authority that is provided or intended to be provided by or on behalf of the authority in accordance with the terms of the Development Contribution Scheme made under section 48 of the Planning and Development Act 2000, as amended. The contribution shall be paid prior to commencement of development or in such phased payments as the planning authority may facilitate and shall be subject to any applicable indexation provisions of the Scheme at the time of payment. Details of the application of the terms of the Scheme shall be agreed between the planning authority and the developer or, in default of such agreement, the matter shall be referred to An Bord Pleanála to determine the proper application of the terms of the Scheme.</p> <p><b>Reason:</b> It is a requirement of the Planning and Development Act 2000, as amended, that a condition requiring a contribution in accordance with the Development Contribution Scheme made under section 48 of the Act be applied to the permission.</p>
12.	<p>The site shall be landscaped, using only indigenous deciduous trees and hedging species, in accordance with details which shall be submitted to,</p>

and agreed in writing with, the planning authority prior to commencement of development.

Any plants which die, are removed or become seriously damaged or diseased, within a period of [five] years from the completion of the development, shall be replaced within the next planting season with others of similar size and species, unless otherwise agreed in writing with the planning authority.

Reason: In order to screen the development and assimilate it into the surrounding rural landscape, in the interest of visual amenity.

**Board Member**



**Date:** 15/09/2023

Liam Bergin

