

**An
Bord
Pleanála**

**Board Direction
BD-016178-24
ABP-316209-23**

The submissions on this file and the Inspector's report were considered at a Board meeting held on 30/04/2024.

The Board decided to grant permission generally in accordance with the Inspector's recommendation, for the following reasons and considerations, and subject to the following conditions.

Reasons and Considerations

Having regard to the existence of an existing dwelling on site, to the provisions of the Cork County Development Plan 2022-2028 in relation to landscape and scenic routes, and to the sensitive design, layout and scale of the proposed development, it is considered that, subject to compliance with the conditions set out below, the proposed development would not seriously injure the visual amenities of the area, would not be prejudicial to public health, would be acceptable in terms of traffic safety and convenience and would, therefore, be in accordance with the proper planning and sustainable development of the area.

Conditions

1. The development shall be carried out and completed in accordance with the plans and particulars lodged with the application, except as may otherwise be required in order to comply with the following conditions. Where such conditions require details to be agreed with the planning authority, the

developer shall agree such details in writing with the planning authority prior to commencement of development and the development shall be carried out and completed in accordance with the agreed particulars.

Reason: In the interest of clarity.

2. Details of the materials, colours and textures of all of the external finishes to the extended and modified dwellinghouse shall be submitted to, and agreed in writing with, the planning authority prior to commencement of development.

Reason: In the interest of visual amenity.

3. (a) Prior to commencement of development, a revised landscape scheme shall be submitted to, and agreed in writing with, the planning authority.

The scheme shall include the following:

- (i) the location of the proposed wastewater treatment system, and
 - (ii) the numbers (either individually or in clusters) of the proposed tree planting.
- (b) Any plants which die, are removed or become seriously damaged or diseased, within a period of five years from the completion of the development, shall be replaced within the next planting season with others of similar size and species, unless otherwise agreed in writing with the planning authority.

Reason: In order to screen the development and assimilate it into the surrounding rural landscape, in the interest of visual amenity.

4. (a) All surface water generated within the site boundaries shall be collected and disposed of within the curtilage of the site. No surface water from roofs, paved areas or otherwise shall discharge onto the public road or adjoining properties.

- (b) Prior to commencement of development, proposals for surface water drainage at the relocated vehicular entrance at the north western corner of the site shall be submitted to, and agreed in writing with, the planning authority.

Reason: In the interest of pollution prevention and orderly development.

- 5. (a) The treatment plant and polishing filter shall be located, constructed and maintained in accordance with the details submitted to the planning authority on the 17th day of January, 2023, and in accordance with the requirements of the document entitled "Code of Practice - Wastewater Treatment and Disposal Systems Serving Single Houses (p.e. ≤ 10)" – Environmental Protection Agency, 2021. No system other than the type proposed in the submissions shall be installed unless agreed in writing with the planning authority.
- (b) Certification by the system manufacturer that the system has been properly installed shall be submitted to the planning authority within four weeks of the installation of the system.
- (c) A maintenance contract for the treatment system shall be entered into and paid in advance for a minimum period of five years from the first occupancy of the development and thereafter shall be kept in place at all times. Signed and dated copies of the contract shall be submitted to, and agreed in writing with, the planning authority within four weeks of the installation.
- (d) Surface water soakways shall be located such that the drainage from the dwelling and paved areas of the site shall be diverted away from the location of the polishing filter.
- (e) Within three months of the first occupation of the development, the developer shall submit a report from a suitably qualified person with


professional indemnity insurance certifying that the proprietary effluent treatment system has been installed and commissioned in accordance with the approved details and is working in a satisfactory manner and that the polishing filter is constructed in accordance with the standards set out in the EPA document.

Reason: In the interest of public health.

6. The developer shall pay to the planning authority a financial contribution in respect of public infrastructure and facilities benefiting development in the area of the planning authority that is provided or intended to be provided by or on behalf of the authority in accordance with the terms of the Development Contribution Scheme made under section 48 of the Planning and Development Act 2000, as amended. The contribution shall be paid prior to commencement of development or in such phased payments as the planning authority may facilitate and shall be subject to any applicable indexation provisions of the Scheme at the time of payment. Details of the application of the terms of the Scheme shall be agreed between the planning authority and the developer or, in default of such agreement, the matter shall be referred to An Bord Pleanála to determine the proper application of the terms of the Scheme.

Reason: It is a requirement of the Planning and Development Act 2000, as amended, that a condition requiring a contribution in accordance with the Development Contribution Scheme made under section 48 of the Act be applied to the permission.

Board Member


Patricia Calleary

Date: 30/04/2024