

An
Coimisiún
Pleanála


Direction
CD-021286-25
ABP-322753-25

The submissions on this file and the Inspector's report were considered at a meeting held on 12/11/2025.

The Commission decided to refuse to grant a revised fire safety certificate for works to which the application relates, generally in accordance with the Inspector's recommendation, for the following reasons and considerations.

Planning

Commissioner:


Patricia Calleary

Date: 14/11/2025

DRAFT WORDING FOR ORDER

Reasons and Considerations

The Commission noted the proposal put forward by the appellant as part of the revised fire safety application and appeal, involves infilling the existing wall cavity located between the external leaf and the polystyrene insulation fixed to the inner leaf, using a foam-injected cavity wall insulation product, 'FIRELITE', with the intended purpose to serve to address non-compliance with works proposed to fulfil the requirements of B3.3 (concealed spaces) of B3 (internal fire spread) of Part B of the Building Regulations 1991, being the regulations applicable at the time of the grant of the previous relevant fire certificate ref: 217/96 for the apartment block. In its deliberations on the appeal, the commission also noted that the appellant's technical compliance document in support of the approved fire certificate (ref: 217/96) relied

on compliance with Diagram B.3.7 Technical Guidance Document B, 1991, that was relevant at that time, in respect of closing of cavities at all openings and at the top of the wall. In respect of addressing the non-compliance occurrence through the current revised fire certificate application and appeal, the appellant is availing of the provisions of Diagram 17 of TGD: Part B (2006, reprinted edition 2020) which replaced Diagram B.3.7 of the earlier TGD: Part B (1991).

No technical evidence has been included as part of the revised fire certificate application or appeal demonstrating that the proposed FIRETITE cavity insulation product has been tested as part of a complete wall configuration that is comparable to the actual configuration of the existing apartment building (100mm brick/block external leaf, 100mm cavity containing 50mm polystyrene insulation against the inner leaf and 100mm concrete block inner leaf with window and door openings) or to demonstrate that it is suitable for the specific wall configuration and the intended purpose to achieve compliance with B3 of the Building Regulations 1997, as amended.

In the absence of relevant technical evidence, the commission was not satisfied that it has been adequately demonstrated in the application or appeal, through performance testing of the product in a comparable external wall arrangement that the proposed approach would adequately prevent unforeseen fire spread occurring.

The commission was not satisfied that the proposed use of the 'FIRELITE' cavity insulation product as an acceptable alternative proposal for achieving compliance to that previously approved by reference to fire certificate 217/96 and, in respect of the current appeal would meet the requirements of Part B3 (Internal fire spread – structure) of the second schedule to the Building Regulations 1997 in the apartment block.