



---

**Planning and Development Acts 2000 to 2018**

**Planning Authority: Cork County Council**

**Planning Register Reference Number: 180/7338**

**Appeal** by Patrick and Gillian O'Donovan of Glenisla, Fennell's Bay, Crosshaven, County Cork against the decision made on the 15<sup>th</sup> day of February, 2019 by Cork County Council to grant subject to conditions a permission to Elizabeth and Robert Jeffreys care of Kiosk Architects of 18 Saint Patrick's Place, Wellington Road, Cork in accordance with plans and particulars lodged with the said Council.

**Proposed Development:** Construction of a single storey dwelling with car port, treatment unit and percolation area, new vehicular entrance and all associated site works at Kilcolta, Fennell's Bay, Crosshaven, County Cork.

**Decision**

**GRANT permission for the above proposed development in accordance with the said plans and particulars based on the reasons and considerations under and subject to the conditions set out below.**

## **Matters Considered**

In making its decision, the Board had regard to those matters to which, by virtue of the Planning and Development Acts and Regulations made thereunder, it was required to have regard. Such matters included any submissions and observations received by it in accordance with statutory provisions.

## **Reasons and Considerations**

Having regard to the location of the site within the settlement boundary for Crosshaven and the Bays, the provisions of the Cork County Development Plan, 2014, the existing pattern of development in the area and the nature and scale of the proposed development, it is considered that, subject to compliance with the conditions set out below, the proposed development would be acceptable, would not seriously injure the amenities of the area and would be acceptable in terms of traffic safety and convenience. The proposed development would, therefore, be in accordance with the proper planning and sustainable development of the area.

## Conditions

1. The development shall be carried out and completed in accordance with the plans and particulars lodged with the application, except as may otherwise be required in order to comply with the following conditions. Where such conditions require details to be agreed with the planning authority, the developer shall agree such details in writing with the planning authority prior to commencement of development and the development shall be carried out and completed in accordance with the agreed particulars.

**Reason:** In the interest of clarity.

2. Prior to commencement of development, proposals to provide a public amenity walkway along the southern boundary of the site shall be submitted to, and agreed in writing with, the planning authority.

**Reason:** In the interest of amenity.

3. (a) The treatment plant and polishing filter shall be located, constructed and maintained in accordance with the details submitted to the planning authority on the 18<sup>th</sup> day of December, 2018 and in accordance with the requirements of the document, entitled "Code of Practice - Wastewater Treatment and Disposal Systems Serving Single Houses (p.e. ≤ 10)" – Environmental Protection Agency, 2009. No system other than the type proposed in the submissions shall be installed, unless agreed in writing with the planning authority.

- (b) Certification by the system manufacturer that the system has been properly installed shall be submitted to the planning authority within four weeks of the installation of the system.
- (c) A maintenance contract for the treatment system shall be entered into and paid in advance for a minimum period of five years from the first occupancy of the dwellinghouse and thereafter shall be kept in place at all times. Signed and dated copies of the contract shall be submitted to, and agreed in writing with, the planning authority.
- (d) Surface water soakaways shall be located such that the drainage from the dwelling and paved areas of the site shall be diverted away from the location of the polishing filter.
- (e) Within three months of the first occupation of the dwelling, the developer shall submit a report from a suitably qualified person with professional indemnity insurance certifying that the proprietary effluent treatment system has been installed and commissioned in accordance with the approved details and is working in a satisfactory manner and that the polishing filter is constructed in accordance with the standards set out in the Environmental Protection Agency document.

**Reason:** In the interest of public health.

4. The site shall be landscaped in accordance with a comprehensive scheme of landscaping, details of which shall be submitted to, and agreed in writing with, the planning authority prior to commencement of development.

All planting shall be adequately protected from damage until established. Any plants which die, are removed or become seriously damaged or diseased, within a period of five years from the completion of the development shall be replaced within the next planting season with others of similar size and species, unless otherwise agreed in writing with the planning authority.

**Reason:** In the interests of residential and visual amenity.

5. Water supply and drainage arrangements, including the disposal and attenuation of surface water, shall comply with the requirements of the planning authority for such works and services.

**Reason:** In the interest of public health.

6. Site development and building works shall be carried out only between the hours of 0700 to 1900 Mondays to Fridays inclusive, between 0800 to 1400 hours on Saturdays and not at all on Sundays and public holidays. Deviation from these times will only be allowed in exceptional circumstances where prior written approval has been received from the planning authority.

**Reason:** In order to safeguard the residential amenities of property in the vicinity.

7. The construction of the development shall be managed in accordance with a Construction Management Plan, which shall be submitted to, and agreed in writing with, the planning authority prior to commencement of development. This plan shall provide details of intended construction practice for the development, including noise management measures and off-site disposal of construction/demolition waste.

**Reason:** In the interests of public safety and residential amenity.

8. The developer shall pay to the planning authority a financial contribution in respect of public infrastructure and facilities benefiting development in the area of the planning authority that is provided or intended to be provided by or on behalf of the authority in accordance with the terms of the Development Contribution Scheme made under section 48 of the Planning and Development Act 2000, as amended. The contribution shall be paid prior to the commencement of development or in such phased payments as the planning authority may facilitate and shall be subject to any applicable indexation provisions of the Scheme at the time of payment. Details of the application of the terms of the Scheme shall be agreed between the planning authority and the developer or, in default of such agreement, the matter shall be referred to An Bord Pleanála to determine the proper application of the terms of the Scheme.

**Reason:** It is a requirement of the Planning and Development Act 2000, as amended, that a condition requiring a contribution in accordance with the Development Contribution Scheme made under section 48 of the Act be applied to the permission.

---

**Dave Walsh**

**Member of An Bord Pleanála**

**duly authorised to authenticate  
the seal of the Board.**

**Dated this            day of            2019.**