



An
Bord
Pleanála

Ordú Boird
Board Order
ABP-311120-21

**Na hAchtanna Rialtais Áitiúil
(Truailliú Uisce) 1977 go 2007**

**Údarás Pleanála: Comhairle
Chontae na Gaillimhe
Uimhir Thagartha: W494/19**

**Local Government (Water Pollution)
Acts 1977 to 2007**

**Planning Authority: Galway County
Council
Reference Number: W494/19.**

Achomharc ó Máire Uí Mhuirín agus Daoine Eile as Páirc, An Spidéal, County Galway maidir le cead a dheonaigh Comhairle Contae na Gaillimhe, ar an 16ú lá Iúil, 2021, do cheadúnas faoi alt 4 den Acht Rialtais Áitiúil (Truailliú Uisce), 1977, d'Údarás na Gaeltachta as Na Forbacha, Contae na Gaillimhe chun eisilteach trádála ó Micro Moulding agus Advant Medical, as Páirc Ghnó Shailearna a scaoileadh isteach sna huiscí dromchla ag sruthán 150 méadar ó thuaighd den R336, Na hAille, Indreabháin, Contae na Gaillimhe.

Appeal by Máire Uí Mhuirín and Others of Páirc, An Spidéal, County Galway in relation to the granting, on the 16th day of July, 2021, by Galway County Council, of a licence under section 4 of the Local Government (Water Pollution) Act, 1977, to Údarás na Gaeltachta of Na Forbacha, County Galway for the discharge of trade effluent from Micro Moulding and Advant Medical, of Páirc Ghnó Shailearna to surface waters at a stream 150 metres north of the R336, na hAille, Indreabháin, County Galway.

An Cinneadh

I bhfeidhmiú na gcumhachtaí a bhronnann alt 8 den Acht Rialtais Áitiúil (Truailliú Uisce) 1977 air, á n-ionadú ag alt 6 den Acht Rialtais Áitiúil (Truailliú Uisce) (Leasú), 1990, diúltaíonn an Bord Pleanála leis seo, bunaithe ar na Cúiseanna agus na hÁbhair a Cuireadh san Ábhair atá leagtha amach thíos, don achomharc agus ordaíonn sé don údarás ceadúnúcháin an ceadúnas a dheonú de réir na gcoinníollacha seo a leanas atá i gceangal leis:

Coinníollacha

1. Raon feidhme

Baineann an ceadúnas leis an bhforbairt thuasluaite faoin gcead pleanála reatha amháin. Is é $3\text{m}^3/\text{lá}$ an t-uasmhéid is ceadmhach a scaoileadh. Má dhéantar aon athrú ar an bhforbairt nó ar an gcóras cóireála, lorgóidh an ceadúnaí athbhreithniú ar an gceadúnas reatha.

Decision

In exercise of the powers conferred on it by section 8 of the Local Government (Water Pollution) Act, 1977, as substituted by section 6 of the Local Government (Water Pollution) (Amendment) Act, 1990, An Bord Pleanála, based on the Reasons and Considerations set out below, hereby refuses the appeal and directs the licensing authority to grant the licence in accordance with the following conditions attached to it:

Conditions

1. Scope

This licence relates of the above-mentioned development with current planning permission only. The maximum permitted discharge is $3\text{m}^3/\text{day}$. Should any changes be made to the development or the treatment system, a review of the current licence shall be sought by the licensee.

Tá coinníollacha ar bith a ghabhann leis an gceadúnas seo ina gceangal ar aon duine a scaoileann, nó a chuireann faoi deara nó a cheadaíonn eisilteach lena mbaineann an ceadúnas seo.

Any conditions attached to this licence are binding on any person discharging, or causing or permitting the discharge of, effluent to which this which licence relates.

2. Scaoileadh

2. Discharge

2.1 Scaoileadh Eisiltigh

2.1 Effluent Discharge

Ní dhéanfaidh an ceadúnaí aon eisilteach nár cóireáladh a scaoileadh, a chur faoi deara ná a cheadú a scaoileadh.

The licensee shall not discharge, cause, or permit the discharge of, any effluent which has not been treated.

2.2 Scaoileadh Eisiltigh Chóireáilte

2.2 Treated Effluent Discharge

Scaipfear an t-eisilteach cóireáilte isteach in Abhainn na hÁille gan níos a chruthú ná baol truailithe d'uisce dromchla nó don screamhuisce.

The treated effluent shall be discharged to the Áille River without causing a nuisance or posing a pollution risk to surface or ground waters.

2.3 Caighdeáin Feidhmíochta maidir le Scaoileadh Eisiltigh

Comhlíonfaidh an t-eisilteach cóireáilte, sula scaoilfear chuig an scagaire snasta é, na caighdeáin seo a leanas:

Ní sháróidh cion cúig lá an Éilimh Bhithcheimiceach ar Ocsaigin sa scaoileadh ón ionad cóireála 25 mg/l.

Ní sháróidh cion an Éilimh Cheimicigh ar Ocsaigin sa scaoileadh ón ionad cóireála 125 mg/l.

Ní sháróidh cion Soladach ar Fuaidreamh sa scaoileadh ón bhfearas cóireála 35 mg/l.

Tá na caighdeáin atá leagtha amach thuas bunaithe ar an acmhainn chomhshamhlaithe, a fuair Comhairle Chontae na Gaillimhe dar dáta Deireadh Fómhair, 2020. Má thagann aon fhianaise chun solais ar éilliú an uisce ghlactha, féadfaidh an t-údarás ceadúnúcháin caighdeáin bhreise nó

2.3 Discharge Effluent Performance Standards

The treated effluent, prior to its discharge to the polishing filter, shall comply with the following standards:

The five-day Biochemical Oxygen Demand content of the discharge from the treatment plant shall not exceed 25 mg/l.

The Chemical Oxygen Demand content of the discharge from the treatment plant shall not exceed 125 mg/l.

The Suspended Solid content of the discharge from the treatment plant shall not exceed 35 mg/l.

The standards set out above are based on the assimilation capacity, received by Galway County Council dated October, 2020. If any evidence of contamination of the receiving water arises, the licensing authority may add additional or alternative standards to the licence.

mhalartacha a chur leis an gceadúnas.

3. Anailís

3.1 Anailís ar Eisilteacht

Déanfaidh saotharlann chreidiúnaithe ceadaithe (Creidiúnú ISO 17025 INAB nó a ionadach coibhéiseach) anailís ar an eisilteach cóireáilte sula scaoiltear chuig an scagaire snasta é dhá uair sa bhliain agus déanfar an tsampláil a leathadh go cothrom ar feadh na bliana.

Déanfar na paraiméadair seo a leanas a thomhas agus an anailís orthu a chur ar aghaidh chuig Rannóg Comhshaoil Chomhairle Chontae na Gaillimhe.

Paraiméadar	Aonaid
Éileamh Bithcheimiceach ar Ocsaigin	mg/L
Éileamh Ceimiceach ar Ocsaigin	mg/L
Solaid ar Fuaidreamh	mg/L
pH	aonaid pH

3. Analysis

3.1 Effluent Analysis

Analysis of the treated effluent prior to its discharge to the polishing filter shall be carried out by an approved accredited laboratory (ISO 17025 INAB Accreditation or its equivalent replacement) twice per year with sampling to be spread evenly throughout the year.

The following parameters shall be measured and the analysis of the same forwarded to the Environment Section of Galway County Council.

Parameter	Units
Biochemical Oxygen Demand	mg/L
Chemical Oxygen Demand	mg/L
Suspended Solids	mg/L
pH	pH units
Total Nitrogen	mg/L N
Total Phosphorous	Mg/L P

Nitrigin Iomlán	mg/L N
Fosfar Iomlán	Mg/L P

Cuirfear torthaí anailíse na samplaí a thógtar ar fáil go leictreonach agus i bhformáid a bheidh ag luí le córas Chomhairle Chontae na Gaillimhe chun torthaí a thaifeadadh.

The analysis results for samples taken shall be made available electronically and in a format compatible with Galway County Council's system for recording results.

Seolfar torthaí na hanailíse go leictreonach chuig wastewaterresults@galwaycoco.ie laistigh de dhá sheachtain ó dhá an tsamplála. Cuirfear na torthaí isteach san fhormáid Excel chuí lena n-iompórtáil isteach i gcóras leictreonach Chomhairle Chontae na Gaillimhe mar aon le cóip dheimhnithe de na torthaí. Gheofar tuilleadh ó Rannóg Comhshaoil Chomhairle Chontae na Gaillimhe.

The analysis results shall be submitted electronically to wastewaterresults@galwaycoco.ie within two weeks of the date of sampling. The results shall be submitted in the appropriate excel format for importation to Galway County Council's electronic system in addition to a certified copy of the results. Further details can be contained from the Environment Section of Galway County Council.

4. Gléasra Cóireála

4. Treatment Plant

4.1 Uiscí dromchla

4.1 Surface waters

Eisiafar ón gcóras gach rith chun srutha uisce dromchla ó dhíonta agus ó limistéir phábháilte.

All surface water run-off from roofs and paved areas shall be excluded from the system.

4.2 Córas Cóireála

Aonrófar gach fuíolluisce lena chóireáil. Déanfar soláthar sa chóras cóireála do bhith-dhíghrádú an insiltigh chun na caighdeáin cóireála eisiltigh a leagtar amach i gcoinníoll 2.3 den cheadúnas seo a chomhlíonadh. Dearfar agus tógfar an t-ionad cóireála i gcomhréir go hiomlán le ceanglais lámhleabhair threoracha ábhartha na Gníomhaireachta um Chaomhnú Comhshaoil lena n-áirítear na Lámhleabhair Chóireála Fuíolluisce: Córais Chóireála do Phobail Beaga, Gnóthais, Ionaid Fóillíochta agus Óstáin, 1999.

4.2 Treatment System

All wastewater shall be isolated for treatment. The system of treatment shall provide for biodegradation of the influent so as to comply with the treatment effluent standards outlined in condition number 2.3 of this licence. The treatment plant shall be designed and constructed in full conformity with the requirement of relevant Environmental Protection Agency guidance manuals including the Wastewater Treatment Manuals: Treatment Systems for Small Communities, Business, Leisure Centres and Hotels, 1999.

5. Gaisce Gréisce

Feistear gaiste gréisce ceadaithe sa chóras bailithe fuíolluisce le linn na tógála. Is é an ceadúnaí atá freagrach as na gaistí gréisce a ghlanadh agus a chothabháil.

5. Grease Trap

An approved grease trap shall be fitted in the wastewater collection system during construction. Cleaning and maintenance of the grease traps is the responsibility of the licensee.

6. Méadrú

Feisteofar na cineálacha méadair nó na gairis tomhais cheadaithe ar an ngléasra cóireála chun toirt laethúil an eisiltigh chóireáilte a urscaoileadh a thomhas agus a thaifeadadh.

Coimeádfar na taifid seo agus beidh siad ar fáil d'fhoireann Chomhairle Chontae na Gaillimhe ach iad a iarraidh. Is é an t-uas-scaoileadh laethúil a cheadaítear in aghaidh an lae faoin gceadúnas seo ná 11,600 lítear.

6. Metering

Approved recording type meters or measuring devices shall be fitted to the treatment plant to allow for the measuring and recording of the daily volume of treated effluent discharged. These records shall be maintained and be available on request to Galway County Council staff. The maximum daily discharge permitted under this licence is 11,600 litres per day.

7. Rochtain Éasca

Ceadófar rochtain ar an ngléasra cóireála agus ar a shuiteálacha go léir do dhaoine údaráithe arna gceapadh faoi fhorálacha na nAchtanna um Thruailliú Uisce 1977 go 1990.

Déanfar na hoibreacha cóireála a fhorbairt chun rochtain a sholáthar ar an ngléasra d'fheithiclí bóthair chun críocha díshlodaithe agus obair chothabhála. Déanfar é a aonrú óna thimpeallacht laistigh de theorainneacha slána sábháilte chun

7. Ready Access

Access to the treatment plant and all its installations shall be allowed to authorised persons appointed under the provisions of the Water Pollutions Acts 1977 to 1990.

The treatment works shall be developed to provide access to the plant by road vehicles for the purposes of de-sludging and maintenance work. It shall be isolated from its surroundings by secure and safe boundaries to prevent interference with, or

trasnaíocht nó damáiste don ghléasra
nó don asraon sceite a chosc.

damage to, the plant or discharge
outlet.

8. Seomra Samplála

In aice leis an ngléasra cóireála,
déanfar seomra samplála a thógáil de
mhéid leordhóthanach chun gur féidir
samplaí den eisilteach cóireáilte a
thógáil ar bhealach sábháilte.
Soláthrófar rochtain éasca ar an
seomra samplála i gcónaí.

8. Sampling Chamber

Adjacent to the treatment plant, a
sampling chamber shall be
constructed, adequately sized to
allow for the taking of samples of
the treated effluent in a safe
manner. Ready access to the
sampling chamber shall be provided
at all times.

9. Airíoch

Is é an ceadúnaí a bheidh freagrach
as cigireacht agus cothabháil an
ionaid chóireála agus is airíoch
ainmnithe a thabharfaidh a ainm, a
sheoladh agus a uimhreacha
teileafóin teagmhála i scríbhinn do
Rannóg Comhshaoil Chomhairle
Chontae na Gaillimhe laistigh de
cheithre seachtaine ó dháta dheonú
an cheadúnais, a dhéanfaidh é.
Cuirfear Comhairle Chontae na
Gaillimhe ar an eolas faoi aon
athruithe pearsanra maidir leis an
airíoch laistigh de choicís ón athrú sin.

9. Caretaker

The inspection and maintenance of
the treatment plant shall be the
responsibility of the licensee and
carried out by a nominated
caretaker whose name, address and
contact telephone numbers shall be
furnished to the Environment
Section of Galway County Council in
writing within four weeks of the date
of the grant of the licence. Galway
County Council shall be notified of
any personnel changes with regard
to the caretaker within two weeks of
such change.

Beidh an t-airíoch cothabhála oilte a dhóthain agus beidh sé eolach ar oibriú agus ar chothabháil an ghréasáin agus an chórais chóireála. Féachfaidh an t-airíoch chuige go bhfuil na caidéil, na mótair agus na corraitheoirí go léir ag oibriú i gcomhréir le sonraíochtaí na soláthróirí agus go ndéanfar na taiscéalaithe go léir a chothabháil agus a chalabhrú go rialta.

The maintenance caretaker shall be adequately trained and familiarised with the operation and maintenance of the network and treatment system. The caretaker shall ensure that all pumps, motors and agitators are operating in accordance with suppliers' specifications and that all probes are regularly maintained and calibrated.

10 Conradh Cothabhála

Déanfaidh an ceadúnaí conradh le soláthraí an ghléasra nó le conraitheoirí ceadaithe eile chun an trealamh go léir a sheirbhísiú.

Tabharfaidh an ceadúnaí cóip den chonradh seirbhísithe molta do Chomhairle Chontae na Gaillimhe lena cheadú laistigh de cheithre seachtaine ón dáta a dtiocfaidh an ceadúnas i bhfeidhm.

Ní dhéanfar aon athrú ina dhiaidh sin ar nádúr an chonartha cothabhála gan comhaontú a fháil roimh ré i scríbhinn ó Chomhairle Chontae na Gaillimhe.

10 Maintenance Contract

The licensee shall enter a contract with the supplier of the plant or other approved contractors for the servicing of all equipment.

A copy of the proposed servicing contract shall be furnished by the licensee to Galway County Council for approval within four weeks of the date the licence comes into effect.

No change shall subsequently be made in the nature of the maintenance contract without the prior agreement of Galway County

Council in writing being first obtained.

Coimeádfar taifid ar na nithe seo a leanas agus beidh siad ar fáil d'fhoireann Chomhairle Chontae na Gaillimhe ach iad a iarraidh:

Records of the following shall be maintained and be available on request to Galway County Council staff:

(a) Gach seirbhísiú ar an ngléasra agus ar an trealamh.

(a) All servicing of the plant and equipment.

(b) Méid laethúil eisilteach cóireáilte a scaoiltear.

(b) Daily volumes of treated effluent discharged.

11 . Fógra faoi Neamhchomhlíonadh

11. Notification of Non-Compliance

Cuirfear Rannóg Comhshaoil Chomhairle Chontae na Gaillimhe ar an eolas faoi aon mhífheidhm ar an bhfearas cóireála gur dócha go leanfaidh cliseadh i gcomhlíonadh na gcaighdeán feidhmíochta as, caighdeáin atá leagtha amach i gcoinníoll 2.3 den cheadúnas seo nó go ndéanfaí aon truailliú ar aon uiscí dromchla nó screamhuisce.

The Environment Section of Galway County Council shall be notified of any malfunction of the treatment plant that is likely to result in a failure to comply with the performance standards set out in condition number 2.3 of this licence or the pollution of any surface or ground waters.

12 Baint Sloda

Déanfar sloda a bhaint de réir fhorálacha an Achta um Bainistiú Dramhaíola, 1996, arna leasú, agus de réir aon rialacháin arna ndéanamh faoi.

Déanfar gach sloda a ghintear a dhiúscairt lasmuigh den láthair gan núis a chruthú. Déanfar an oibríocht diúscartha sloda i gcomhréir le dea-chleachtas chun an baol truaillithe uisce dromchla nó screamhuisce a íoslaghdú. I gcás ina ndiúscaítear sloda ar thalamh talmhaíochta, déanfar é sin i gcomhréir le forálacha Rialacháin na gComhphobal Eorpach um Bainistiú Dramhaíola (Sloda Séarachais a Úsáid sa Talmhaíocht), 1998 go 2001, agus Rialacháin na gComhphobal Eorpach (Dea-Chleachtas Talmhaíochta chun Uiscí a Chosaint) 2017. Coimeádfar taifid ar bhaint sloda agus ar dhiúscairt gach sloda agus cuirfear ar fáil iad do Chomhairle Chontae na Gaillimhe ar iarraitas.

12. Sludge Removal

Removal of sludge shall be carried out in accordance with the provisions of the Waste Management Act, 1996, as amended, and any regulations made thereunder.

All sludge generated shall be disposed of off-site without causing nuisance. The sludge disposal operation shall be carried out in accordance with good practice so as to minimise the risk of surface or ground water pollution. Where sludge is disposed of on agricultural land, this shall be done in accordance with the provisions of the European Communities Waste Management (Use of Sewage Sludge in Agriculture) Regulations, 1998 to 2001, and the European Communities (Good Agricultural Practice for Protection of Waters) Regulations 2017. Records of desludging and the disposal of all sludge shall be maintained and made available on request to Galway County Council.

13 Ranníocaíocht Bhliantúil

Íocfaidh an ceadúnaí le Comhairle Chontae na Gaillimhe cibé ranníocaíocht réasúnach a mheasfaidh an t-údarás is gá i leith mhonatóireacht ar an scaoileadh chun a dhualgais faoi na hAchtanna um Thruailliú Uisce 1977 agus 1990 a chomhlíonadh. Íocfaidh an ceadúnaí íos-ranníocaíocht bhliantúil de €550 (cúig chéad caoga euro) le Comhairle Chontae na Gaillimhe.

Déanfar an méid a bheidh le híoc a choigeartú go bliantúil i gcomhréir leis an bPraghasinnéacs Tomhaltóirí a bhaineann leis an tráth a thiocfaidh an íocaíocht chun bheith dlite. Coimeádfaidh Comhairle Chontae na Gaillimhe an ceart chun an ráta ranníoca a athrú gach bliain chun an costas iarbhír monatóireachta a thabhaigh sí an bhliain roimhe sin agus a mheastar don bhliain dár gcionn a chur san áireamh.

13. Annual Contribution

The licensee shall pay to Galway County Council such reasonable contribution towards the monitoring of the discharge as the authority considers necessary for the performance of its duties under the Water Pollution Acts 1977 and 1990. The licensee shall pay Galway County Council a minimum annual contribution of €550 (five hundred and fifty euro).

The amount to be paid shall be adjusted annually in accordance with the Consumer Price Index appertaining at the time when the payment becomes due. Galway County Council shall reserve the right to alter the rate of contribution each year in order to take account of the actual cost of monitoring incurred by it in the previous year and estimated for the next year.

14 Athruithe ar Úinéireacht

Tabharfar fógra i scríbhinn do Rannóg Comhshaoil Chomhairle Chontae na Gaillimhe maidir le haon athrú ar úinéireacht cuideachta agus/nó ainm trádála laistigh de dhá sheachtain dá leithéid d'athrú. De réir alt 4(6) de na hAchtanna Rialtais Áitiúil (Truailliú Uisce, 1977 go 2007, beidh coinníollacha an cheadúnais seo ina gceangal ar an duine a scaoilfidh an t-eisilteach lena mbaineann an ceadúnas seo, nó a chuirfidh faoi deara nó a cheadóidh an scaoileadh

14. Changes in Ownership

The Environmental Section of Galway County Council shall be notified in writing of any change to company ownership and/or trading name with two weeks of such a change. As per section 4(6) of the Local Government (Water Pollution Acts, 1977 to 2007, the conditions of this licence shall be binding on the person discharging, or causing or permitting the discharge, of the effluent to which this licence relates.

15 Ceangal le Séarach Poiblí

Dearfar an gréasán agus an córas cóireála sa chaoi is gur féidir an córas a nascadh go héasca le córas poiblí cóireála fuíolluisce má bhíonn ceann ar fáil. Ar choinníoll go dtugann Uisce Éireann le fios go bhfuil ceangal indéanta, tá dualgas ar an gceadúnaí ceangal le córas cóireála fuíolluisce poiblí má bhíonn ceann ar fáil.

15. Connection of Public Sewer

The network and treatment system shall be designed such that the system can be readily connected to a public wastewater treatment system if one becomes available. Provided Irish Water indicate that connection is feasible, the licensee is obliged to connect to a public wastewater treatment system if one becomes available.

Cúiseanna agus Tuisceanna

Teacs

Ag féachaint do:

- (a) nádúr (easilteach teaghlaigh agus trádála) agus uastoirt an eisiltigh a bheidh le scaoileadh (sa raon ó 1.95m³ in aghaidh an lae go dtí uas-scaoileadh 2.75m³ in aghaidh an lae amach anseo) isteach in Abhainn na hAille,
- (b) an Tuarascáil Measúnaithe Acmhainne Ashamhlaithe Dramhaíola (a chuir an t-iarratasóir faoi bhráid an Údaráis Cheadúnúcháin an 28ú lá de Dheireadh Fómhair 2020) arna déanamh de réir an Iarratais ar Cheadúnas chun Doirteadh isteach in Uiscí Dromchla, Treoir don Iarratasóir, Grúpa Oiliúna Seirbhísí Uisce thar ceann na Roinne Comhshaoil, Oidhreacht agus Rialtais Áitiúil,

Reasons and Considerations

Having regard to

- (a) the nature (domestic and trade effluent) and maximum volume of effluent to be discharged (ranging from 1.95m³/day to a maximum discharge of 2.75m³/day in the future) to the Áille River,
- (b) the Waste Assimilative Capacity Assessment Report (submitted by the applicant to the Licensing Authority on the 28th day of October 2020) carried out in accordance with the Application for a Licence to Discharge to Surface Waters, Guidance to Applicant, Water Services Training Group on behalf of the Department of Environment, Heritage and Local Government,

- | | |
|---|---|
| <p>(c) nach bhfuil dobharlach glactha Abhainn na hÁille ainmnithe le haghaidh úsáid áirithe nó mar rud a dteastaíonn cosaint uaidh mar gheall ar a íogaireacht i leith truailliú nó toisc go bhfuil speicis nó gnáthóga a bhfuil tábhacht ar leith ag baint leo (is é sin, mar Uisce Salmanaide, Uisce Snámha Intíre, Uisce Diúilicíní Péarla, Uisce Íogair nó Limistéar faoi Chaomhnú Speisialta nó Limistéar faoi Chosaint Speisialta),</p> | <p>(c) the fact that the receiving Áille River waterbody is not designated for a particular use or as needing protection due to its sensitivity to pollution or because it contains species or habitats of particular importance (that is, as a Salmonid Water, an Inland Bathing Water, Pearl Mussel Water, Sensitive Water or a Special Area of Conservation or Special Protection Area),</p> |
| <p>(d) do Stádas “Measartha” Abhainn na hÁille faoin gCreat-Treoir Uisce 2013 -2018, agus</p> | <p>(d) the 2013 -2018 Water Framework Directive “Moderate” Status of the Áille River, and</p> |
| <p>(e) go bhfuil sprioc-stádas cáilíochta uisce “Maith” ag Abhainn na hÁille mar atá sainmhínithe sna Rialacháin um Uisce Dromchla 2009 (arna leasú) agus go bhfuil sprioc-stádas cáilíochta uisce “sármhaith” de réir na Rialachán um Cháilíocht Uiscí Snámha, (S.I. Uimhir 791 2008) ag na huiscí cósta glactha snámha agus áineasa síos an abhainn.</p> | <p>(e) the fact that the Áille River has a target water quality status of “Good” as defined in the Surface Water Regulations 2009 (as amended) and the receiving downstream bathing and recreational coastal waters have a target water quality status of “excellent” in accordance with the Bathing Waters Quality Regulations, (S.I. Number 791 2008).</p> |

bhí an Bord sásta gur bhunaigh an measúnú ar acmhainn asamhlaithe dramhaíola, ar bhonn monatóireacht chomhthimpeallach suas an abhainn agus síos an abhainn ón bpointe doirte, an chóireáil thánaisteach chaighdeánach le teorainn uachanna sonraithe astaíochta do BOD: 25mg/L, COD: 1.25mg/L agus TSS: Is leor 35mg/L lena chinntiú nach gcuireann an scaoileadh isteach in Abhainn na hÁille cumas an dobharlaigh Stádas Maith a bhaint amach (mar atá sainmhínithe faoin gCreat-Treoir Uisce agus na Rialacháin ghaolmhara) i mbaol nó nach cúis é le haon mheath ar an stádas atá ann faoi láthair agus go ngéilleann sé mar sin do na Rialachán um Uisce Dromchla 2009 (arna leasú) agus do na Rialacháin um Cháilíocht Uiscí Snámha (S.I uimh. 79/2008).

the Board was satisfied that the waste assimilative capacity assessment established, on the basis of ambient monitoring upstream and downstream of the discharge point, the standard secondary treatment with specified emission limit values for BOD: 25mg/L, COD: 1.25mg/L and TSS: 35mg/L is sufficient to ensure that the discharge to the Áille River does not compromise the ability of the water body to achieve Good Status (as defined under the Water Framework Directive and associated Regulations) nor cause any deterioration in existing status and is therefore in compliance with the Surface Water Regulations 2009 (as amended) and the Bathing Waters Quality Regulations (S.I no. 79/2008).

Dr. Maria Fitzgerald

Maria Fitzgerald

Comhalta den Bhord Pleanála atá údaraithe go cuí chun séala an Bhord a fhíordheimhniú

Member of An Bord Pleanála duly authorised to authenticate the seal of the Board.

Dated this **23rd** day of **May** **2022**