

An Coimisiún Pleanála

Commission Order ABP-321906-25

Building Control Acts 1990 to 2014

Building Control Authority: Fingal County Council

Building Control Authority Register Reference Number: FSC3024330

Appeal by Blanche Developments Limited care of Michael Slattery Associates of 19 Windsor Place, Lower Pembroke Street, Dublin in relation to the decision made on the 14^{th} day of January 2025, by Fingal County Council to grant subject to conditions a fire safety certificate under section 6 (2)(a)(ii) of the Building Control Act, 1990, as amended by section 5(a) of the Building Control Act 2007 in respect of a proposed development at Block D – Site A at Blanchardstown Centre, Coolmine, Dublin in accordance with plans and particulars lodged with the said authority:

WHEREAS the said appeal relates only to condition number 2 attached to the decision of the Building Control Authority:

AND WHEREAS An Coimisiún Pleanála is satisfied, having regard to the nature of the said conditions, that the determination by the Commission of the relevant application as if it had been made to it in the first instance would not be warranted:

ABP-321906-25

An Coimisiún Pleanála

Page 1 of 2

- (

NOW THEREFORE An Commission Pleanála, in exercise of the powers conferred on it by section 7 of the Building Control Act 1990 and by Article 40 (2) of the Building Control Regulations, 1997, and based on the reasons and considerations set out below, hereby directs the said authority to delete the said condition number 2 and the reason therefor:

Reasons and Considerations

Having regard to the presented design, to the submissions lodged in connection with the Fire Safety Certificate application and the appeal, and to the report and recommendation of the reporting Inspector, it is considered that it has been demonstrated by the appellant that the provision of a second (alternative) escape stair is not a requirement that is necessary to demonstrate compliance with Technical Guidance Document B - Fire Safety, (2006, reprinted 2022 and that is the relevant edition of the technical guidance in respect of the current appeal) or accordingly to demonstrate compliance with the requirements of Part B of the Second Schedule to the Building Regulations 1997, as amended. Therefore Condition 2 as originally attached by the Building Control Authority to the Fire Safety Certificate is not necessary.

atrici **Patricia Calleary**

Planning Commissioner of An Coimisiún Pleanála duly authorised to authenticate the seal of the Commission.

Dated this OZ day of July

2025.

ABP-321906-25

An Coimisiún Pleanála

Page 2 of 2