



Notes:

1. This drawing is not to be scaled. Figured dimensions only to be taken.
2. This drawing is for indicative use only. The Process type and arrangement shown requires confirmation by outline design.
3. 38kV Power line passes through the proposed land boundary. It is assumed that the power line to be re-routed around site boundary.
4. All earthworks shall be at a maximum slope of 1V : 2H.
5. All tanks shall be covered with GRP clam shell covers.
6. All drawings to be checked by the Contractor on Site.
7. Engineer to be informed by the Contractor of any discrepancies before any work commences.
8. All levels shown relate to Ordnance Survey datum at Malin Head, the geographic coordinate system is to Irish Transverse Mercator (ITM).

