



Your Ref: ABP-313322-22  
Our Ref: CDS20001675

An Bord Pleanála,  
64 Marlborough Street,  
Dublin.

**Uisce Éireann**  
Bosca OP 6000  
Baile Átha Cliath 1  
Éire

**Irish Water**  
PO Box 6000  
Dublin 1  
Ireland

**T:** +353 1 89 25000  
**F:** +353 1 89 25001  
[www.water.ie](http://www.water.ie)

1<sup>st</sup> December 2022

Dear Sir/ Madam,

**Re:** Strategic Housing Development – Regarding the construction of 443 no. residential units (41 no. houses, 402 no. apartments), creche and all associated site works at Priorsland, within the townlands of Carrickmines Great and Brennanstown, Dublin 18.

Irish Water has reviewed the plans and particulars submitted for this Strategic Housing Development Application and based on the details provided by the applicant to Irish Water as part of their Pre-Connection Enquiry, and on the capacity available in the local networks, Irish Water has the following observations:

**In respect of Water:**

Feasible without infrastructure upgrade by Irish Water.

**In respect of Wastewater:**

Feasible without infrastructure upgrade by Irish Water.

**Design Acceptance:**

The applicant (including any designers/contractors or other related parties appointed by the applicant) is entirely responsible for the design and construction of all water and/or wastewater infrastructure within the Development redline boundary which is necessary to facilitate connection(s) from the boundary of the Development to Irish Water's network(s) (the "Self-Lay Works"), as reflected in the applicants Design Submission.

A statement of Design Acceptance was issued by Irish Water on 1<sup>st</sup> April 2022.

**Planning Recommendation:**

Irish Water respectfully requests the board condition(s) any grant as follows:

1. The applicant shall sign a connection agreement with Irish Water prior to any works commencing and connecting to the Irish Water network.
2. Irish Water does not permit any build over of its assets and separation distances as per Irish Waters Standards Codes and Practices shall be achieved.
  - (a) Any proposals by the applicant to build over/near or divert existing water or wastewater services subsequently occurs, the applicant shall submit details to Irish Water for assessment of feasibility and have written confirmation of feasibility of diversion(s) from Irish Water prior to connection agreement.
3. All development shall be carried out in compliance with Irish Water Standards codes and practices.

Queries relating to the observations above should be sent to [planning@water.ie](mailto:planning@water.ie)

PP. Ali Robinson

---

**Yvonne Harris**

Connections and Developer Services