



Technical Note:

Assessment of Borehole data at Arthur Cox Building and Cadenza Building

TBC | P01

06/03/2024



MetroLink

Project No: 32108600
Document Title: Assessment of Borehole data at Arthur Cox Building and Cadenza Building
Document No.: TBC
Revision: P01
Date: 06/03/2024
Client Name: TII / NTA
Client No:
Project Manager: Paul Brown
Author: Jose A Aparicio
File Name: TBC

Jacobs Engineering Ireland Limited

Merrion House
Merrion Road
Dublin 4, D04 R2C5
Ireland
T +353 1 269 5666
F +353 1 269 5497
www.jacobs.com

© Copyright 2024 Jacobs Engineering Ireland Limited. The concepts and information contained in this document are the property of Jacobs. Use or copying of this document in whole or in part without the written permission of Jacobs constitutes an infringement of copyright.

Limitation: This document has been prepared on behalf of, and for the exclusive use of Jacobs' client, and is subject to, and issued in accordance with, the provisions of the contract between Jacobs and the client. Jacobs accepts no liability or responsibility whatsoever for, or in respect of, any use of, or reliance upon, this document by any third party.

Document History and Status

Revision	Date	Description	Author	Checker	Reviewer	Approver
P01	06/03/2024	First Issue	JAA	---	---	---

Contents

1.	Assessment of Boreholes data at Arthur Cox Building and Cadenza Building.....	4
----	---	---

1. Assessment of Borehole data at Arthur Cox Building and Cadenza Building

The applicant has reviewed the boreholes logs provided by AGL Consulting (acting on behalf of the owners of both buildings) on 1 March 2024 and concludes the following:

- The boreholes show a similar but higher profile for the competent rock level compared to MetroLink Geotechnical Profile.
- The settlement assessment undertaken based on the MetroLink Geo-Long Section has thus considered a more conservative scenario.
- An assessment using the higher rock levels indicated by the property owners should therefore reduce the current settlement values.