
Our Case Number: ABP-317810-23



Health and Safety Authority The Metropolitan Building James Joyce Street Dublin Dublin 1

Date: 01 May 2024

Re: Open Cycle Gas turbine power plant (350MW) and associated infrastructure

Located on land to the north of Tynagh Power Station, Derryfrench, Tynagh, Loughrea, Co.

Galway.

Dear Sir / Madam,

An Bord Pleanála has received your recent submission in relation to the above mentioned proposed development and will take it into consideration in its determination of the matter.

The Board will revert to you in due course with regard to the matter.

Please be advised that copies of all submissions / observations received in relation to the application will be made available for public inspection at the offices of the local authority and at the offices of An Bord Pleanála when they have been processed by the Board.

More detailed information in relation to strategic infrastructure development can be viewed on the Board's website: www.pleanala.ie.

If you have any queries in the meantime, please contact the undersigned officer of the Board or email sids@pleanala.ie quoting the above mentioned An Bord Pleanála reference number in any correspondence with the Board.

Yours faithfully,

Niamh Hickey Executive Officer

Direct Line: 01-8737145

PA04

Email

Honor Caird Marren

From: Niamh Hickey

Sent: Friday 26 April 2024 11:17
To: Honor Caird Marren

Subject: FW: Open cycle gas turbine power plant (350MW) and associated infrastructure

located on land to the North of Tynagh power station, Derryfrench, Tynagh,

Loughrea, Co. Galway

Attachments: Tynagh North OCGT ABP-317810-23 HSA ref 4169.pdf

Follow Up Flag: Follow up Flag Status: Flagged

From: Geoff Hynes < Geoff_Hynes@hsa.ie > **Sent:** Wednesday, April 24, 2024 4:26 PM

To: SIDS <sids@pleanala.ie>

Subject: RE: Open cycle gas turbine power plant (350MW) and associated infrastructure located on land to the

North of Tynagh power station, Derryfrench, Tynagh, Loughrea, Co. Galway

Caution: This is an **External Email** and may have malicious content. Please take care when clicking links or opening attachments. When in doubt, contact the ICT Helpdesk.

To whom it may concern,

Please see attached in relation to the above.

Regards,

Geoff

Geoff Hynes

Inspector | CCPS Unit | Health & Safety Authority

Mobile: 087-6002298 Email: geoff hynes@hsa.ie Web: www.hsa.ie

Health and Safety Authority, An tÚdarás Sláinte agus Sábháilteachta,

Metropolitan Building, An Foirgneamh Uirbeach,

James Joyce Street, Sráid James Joyce,
Dublin 1, Baile Átha Cliath 1

D01 KOY8 D01 KOY8

An tÚdarás Sláinte agus Sábháilteachta Beulth and Safety Authority Ár bhFís: Saolta agus fiontair shláintiúla, shábháilte agus

tháiraiúla

Our Vision: Healthy, safe and productive lives and

enterprises

<u>HSA Twitter</u> <u>HSA Facebook</u> HSA YouTube

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the system manager.

The Health and Safety Authority, its servants or agents, accept no liability for any errors or omissions in the information provided in this correspondence or for any loss or damage occasioned to any person as a result of using the information provided.

This footnote also confirms that this email message has been swept for the presence of computer viruses.



An tÚdarás Sláinte agus Sábháilteachta Health and Safety Authority

©0818 289 389 😜 landuseplanning@hsa.ie 🌖 www.hsa.ie

An Bord Pleanala, 64 Marlborough street, Dublin 1 D01 V902 By email to sids@pleanala.ie

Our Ref: PAR 4169

24/04/2024

Re: Open cycle gas turbine power plant (350MW) and associated infrastructure located on land to the North of Tynagh power station, Derryfrench, Tynagh, Loughrea, Co. Galway

To whom it may concern,

The Health and Safety Authority (the Authority), acting as the Central Competent Authority under the Chemicals Act (Control of Major Accident Hazards Involving Dangerous Substances) Regulations 2015 (S.I. 209 of 2015), gives technical advice to the planning authority when requested, under regulation 24(2) in relation to:

- (a) the siting and development of new establishments:
- (b) modifications to establishments of the type described in Regulation 12(1):
- (c) new developments including transport routes, locations of public use and residential areas in the vicinity of establishments, where the siting, modifications or developments may be the source of, or increase the risk or consequences of, a major accident.

The Authority currently has insufficient information to provide technical advice on this application, therefore the Authority requests the Planning Authority to seek further information in accordance with regulation 24(10) from the applicant in relation to this application.

Section 6.3.3 of the COMAH land use planning assessment for Tynagh North (Ref: 578-23-X0041 R7, dated 14th March 2024) - Pipeline rupture leading to fireball should be considered as a credible event, and modelled accordingly.

Appendix 1, site layouts. An overall map should be furnished that shows the area that will form the COMAH site boundary and includes:

- a) The existing Tynagh Energy COMAH site
- b) The previously granted Tynagh South COMAH site
- c) The proposed Tynagh North COMAH site

The Authority will be in a position to provide advice to An Bord Pleanala within 4 weeks of receipt of the requested information.

If you have any queries please contact the undersigned.

Yours sincerely

g.Hynes

Geoff Hynes

Inspector,

COMAH, Chemical Production & Storage (CCPS)