

An  
Bord  
Pleanála

## Memorandum ABP-317810 - Request for Further Information under Section 131

**To:** Paul Caprani, ADP  
**From:** Laura Finn, PI  
**Re:** 317810 - Request for Further Information  
**Date:** 7<sup>th</sup> May 2024

Having regard to the content of the submission made by the Health and Safety Authority (HSA) on 24<sup>th</sup> April 2024, I am of the opinion that further information is required from the Applicant in order to assist further with my assessment of this application as detailed below;


- The HSA on 24<sup>th</sup> April 2024, requested further information from the applicant in order to provide technical advice on the application. (Copy of response enclosed)
- The HSA has stated that 'Section 6.3.3 of the COMAH land use planning assessment for Tynagh North (Ref: 578-23-X0041 R7, dated 14<sup>th</sup> March 2024) – Pipeline rupture leading to fireball should be considered as a credible event, and modelled accordingly.

Appendix 1, site layouts. An overall map should be furnished that shows the area that will form the COMAH site boundary and includes:


- a) The existing Tynagh Energy COMAH site
- b) The previously granted Tynagh South COMAH site
- c) The proposed Tynagh North COMAH site'

- I am requesting the applicant review the request from the HSA and respond as appropriate.
- The Applicants are also requested to respond to the third-party concerns that were received by Mr. Colm Shaughnessy and John Nash Solicitors on behalf of Ralph Conroy, Niamh and Stephen Loughrey, John Briscoe, Pat Whelan and Enda and Philomena Briscoe (Copy of Responses enclosed)

Please allow 4 weeks for response to this request.



Laura Finn  
Inspectorate

Endorsed   
8/5/24