

**From:** [O Connor, Peter](#)  
**To:** [Ellen Moss](#); [SIDS](#)  
**Cc:** [Kieran O'Connor](#); [Martin Ahern](#); [Aiden O'Neill](#); [Devine, Rachel](#)  
**Subject:** Re: ABP-319566-24  
**Date:** Wednesday, September 25, 2024 5:54:54 PM  
**Attachments:** [image002.png](#)  
[Response to Submission ABP Letter September 2024 SLNG September 2024 Rev00\(MERGED\).pdf](#)

---

**Caution:** This is an **External Email** and may have malicious content. Please take care when clicking links or opening attachments. When in doubt, contact the ICT Helpdesk.

**Re: ABP-319566-24**

FAO. Ms Ellen Moss

The following submission is made in response to the letter from An Bord Pleanála (the “Board”) dated 6th September 2024 in relation to pending application reference no. ABP-319566-24.

The Board invited Shannon LNG Limited (the “Applicant”) to make a submission on the observations received by the Board. Those observations were received by the Board during the public consultation process for ABP-319566-24. The public consultation period was from 29th April 2024 to 17th June 2024.

Please note that in addition to the soft copy submission (attached), a hard copy submission has also been forwarded to the Board.

Regards,

**Peter O' Connor**

Technical Director, Environment

M +44-(0)7503-627-897

[peter.oconnor@aecom.com](mailto:peter.oconnor@aecom.com)

**AECOM**

[aecom.com](https://www.aecom.com)

**Delivering a better world**

[LinkedIn](#) | [Twitter](#) | [Facebook](#) | [Instagram](#)



©2018 Time Inc. Used under license

# Response to Submissions Shannon Technology and Energy Park Power Plant (ABP-319566-24)

Response to An Bord Pleanála letter dated 06 September  
2024

Shannon LNG Limited

September 2024

Prepared for:  
Shannon LNG Limited

AECOM Ireland Limited  
4th Floor  
Adelphi Plaza  
Georges Street Upper  
Dun Laoghaire  
Co. Dublin A96 T927  
Ireland

T: +353 1 238 3100  
aecom.com

© 2024 AECOM Ireland Limited. All Rights Reserved.

This document has been prepared by AECOM Ireland Limited ("AECOM") for sole use of our client (the "Client") in accordance with generally accepted consultancy principles, the budget for fees and the terms of reference agreed between AECOM and the Client. Any information provided by third parties and referred to herein has not been checked or verified by AECOM, unless otherwise expressly stated in the document. No third party may rely upon this document without the prior and express written agreement of AECOM.

## Table of Contents

1.	Introduction .....	1
2.	Health and Safety Authority (HSA).....	3
3.	National Parks and Wildlife Service (NPWS).....	5
3.1	Loss of Annex 1 Habitat Estuaries and Reefs .....	5
3.2	River Shannon and River Fergus Estuaries SPA: Oil Pollution Prevention .....	6
4.	Transport Infrastructure Ireland (TII) .....	7
4.1	TII 2.2 – Structures.....	7
5.	National Monument Services (NMS).....	7
6.	Submissions from An Taisce, Friends of the Environment, Gluaiseacht for Global Justice, Safety Before LNG, Not Here Not Anywhere, Future Generations Kerry, Melina & Christine Sharp & Michale Eversen. ....	8
6.1	Obligations under the Climate Act .....	8
6.2	Carbon Budgets and Emission Reduction Obligations .....	9
6.3	Operational Life and Construction Timeframe .....	10
6.4	University College Cork (UCC) Research, McMullin et al, “Lock In” .....	10
6.5	Major Adverse Climate Impact .....	11
6.6	Fugitive Emissions and Methane Leakage .....	11
6.7	Cumulative Impacts and Project Splitting .....	13
6.8	Feasibility of Hydrogen Transition.....	13
6.9	Decarbonisation Renewables vs Emission Reduction .....	14
6.10	Pipeline Planning Permission .....	14
6.11	Impacts to Lower River Shannon.....	14
6.12	An Taisce 7.1 – Impact on Breeding Birds.....	15
6.13	An Taisce 8.0 – Visual and Light Pollution.....	17
6.14	Proposed LNG Terminal .....	17
6.15	Alternative Locations not considered.....	18
6.16	Flow direction of the pipeline .....	18
Appendix 1: QRA Power Plant Rev 05		
Appendix 2: MATTE for Power Plant Rev 03		

# 1. Introduction

The following submission is made in response to the letter from An Bord Pleanála (the “Board”) dated 6<sup>th</sup> September 2024 in relation to pending application reference no. ABP-319566-24.

The Board invited Shannon LNG Limited (the “Applicant”) to make a submission on the observations received by the Board. Those observations were received by the Board during the public consultation process for ABP-319566-24. The Applicant welcomes this opportunity to respond.

The Applicant has carried out a comprehensive review of all observations received by the Board during the public consultation period from 29<sup>th</sup> April to 17<sup>th</sup> June 2024. From the Applicant’s review, it appears that several key themes occur across the submissions and the Applicant has drafted this response to address these key themes, rather than individually addressing each submission in turn. The letters were received by the Applicant from the Board on the 1<sup>st</sup> July and 19<sup>th</sup> July 2024.

As directed, this response does not contain any additional reports or supplementary reports and is confined to the issues raised in the observations received by the Board. The matters raised are comprehensively addressed in the EIAR submitted with the Application, the Applicant welcomes this opportunity to respond to some of the key themes raised in the submissions received.

Submissions from the following Prescribed Bodies: Health and Safety Authority (HSA), National Parks and Wildlife Service (NPWS), Transport Infrastructure Ireland (TII) and National Monument Services (NMS) are responded to individually as these submissions do not overlap and are not repeated within other submissions. Submissions from An Taisce, Friends of the Environment, Gluaiseacht for Global Justice, Safety Before LNG, Not Here Not Anywhere, Future Generations Kerry, Melina and Christine Sharp, and Michael Eversen overlap and are somewhat repeated in many cases. Therefore, the Applicant has responded with the key themes identified in those submissions under the following headings:

- Obligations under the Climate Act;
- Carbon Budgets and Emission Reduction Obligations;
- Operational Life and Construction Timeframe;
- UCC Research, McMullin et al and “lock in”;
- Major Adverse Climate Impact;
- Fugitive Emissions and Methane Leakage;
- Cumulative Impacts and Project Splitting;
- Feasibility of Hydrogen Transition;
- Decarbonisation Renewables vs Emission Reduction;
- Pipeline Planning Permission;
- Impacts to Lower River Shannon;

- An Taisce 7.1 – Impact on Breeding Birds;
- An Taisce 8.0 – Visual and Light Pollution;
- Proposed LNG Terminal; and
- Alternative Locations not considered.

The response clarifies how the Proposed Development complies with the European, National and Regional policy and regulations.

## 2. Health and Safety Authority (HSA)

Detailed in Table 2.1 are the responses to the HSA comments received on the 18<sup>th</sup> June 2024. The updated Quantitative Risk Assessment (QRA) and Major Accident to the Environment (MATTE) that address the 16 comments from the HSA as are included in Appendix 1 and Appendix 2.

**Table 2.1: Response to HSA Comments**

Comment	Response
1. The applicant is required to provide a site map with the boundary of the COMAH establishment clearly outlined. To note this is not the boundary of ownership, rather the COMAH establishment boundary. The COMAH boundary should also be included in Figure 11.	COMAH boundary added as requested. (Figure 1 and result figures in Section 10).
2. Provide further details on spill management and containment arrangements at the distillate tanker unloading area. It is the Authority's understanding that the tanks will be filled by road tanker as there is no reference to a jetty.	Details of spill management added in Section 2.3, and spill management plan referenced.
3. The report does not include hydrogen in the inventory of dangerous substances. However, in section 14.5.2.3 it states that hydrogen will be used for turbine cooling purposes. This will need to be assessed from hydrogen storage, to the point of use as required by the Technical Land Use Planning Guidance document (TLUPG).	A TEWAC (Totally enclosed water to air cooled) generator is proposed for the power plant. Therefore, Hydrogen will not be used for generator cooling on turbines of this size, and is therefore not discussed in the QRA.
4. It is noted that section 10 of the report provides maps with the risk outputs. Confirm how were the inputs for SAFETI calculated and what scenarios are they based on? The outputs from the consequence modelling of the scenarios should also be provided in the report.	The risk contours are generated automatically by SAFETI, based on the release source parameters and frequencies entered. Section 3 has been expanded to provide more information regarding the data entered into SAFETI.
5. In relation to jet fires, the consequences from both vertical and horizontal fires should be modelled.	Both horizontal and vertical releases considered as requested.
6. The report does not refer to the criteria set out in the TLUPG in relation to new establishments i.e. 10 <sup>-6</sup> /yr for the public and 5x10 <sup>-6</sup> /yr for offsite workers. Confirm in the report that this criteria has been met.	The criteria is detailed in chapter 3.1 of the QRA. and the conclusions state that the site complies with the criteria. The criteria has now also been duplicated in Section 10.2 and 10.3, with statements that the criteria are met.
7. A natural gas release scenario in the turbine enclosure should be assessed and included in the QRA. Loss of containment scenarios and frequencies from table 64 of TLUPG should be used in this instance.	This scenario has been added, and the model inputs are described in Section 3.
8. Sections 3.3.2 and 5.2 refer to scenarios relating to steam. Steam is not classified as a dangerous substance under the Control of Major Accident Hazard (COMAH) Regulations 2015, consequently the COMAH Regulations do not apply to steam. However, it should be determined whether a steam	This was conservatively included in the previous assessment but has negligible impact on the results and the potential for escalation resulting from a release of steam is considered negligible. The scenario has therefore been removed.

Comment	Response
scenario could initiate a major accident relating to a dangerous substance on the site, and if so, this should be included.	
9. Section 3.3.2 refers to Battery Energy Storage Systems (BESS). A BESS is not a substance or mixture as defined under the CLP Regulations. It is therefore not subject to the COMAH Regulations. However, it should be determined if a BESS could be an initiator of a major accident relating to a dangerous substance on the site, and if so, this should be included.	Risks due to the presence of the BESS are primarily related to its potential to cause a significant fire. However, this fire will be contained within the BESS building, and the probability of it escalating into a major accident affecting areas outside the site is discounted. Therefore, this scenario has not been calculated in the QRA. Section 3.3.2 has been updated accordingly.
10. Table 10 (scenario conditions) appears to be missing some pressure data.	Apologies, this was an unnoticed issue generating the PDF – we have checked, and this issue has been rectified .
11. Section 5.3 last paragraph “The probability of successful leak detection and automatic isolation of the pipe has been taken as 0.99, with a detection time of 30s”. What is the source for this data and where is it used in the analysis? Mitigation measures such as leak detection/isolation cannot be considered for the purposes of Land Use Planning, such modelling should always be conservative in nature and should not include the use of mitigatory factors such as detection systems.	Detection / isolation is typically taken into account in risk studies, but as commented this has no impact in land use planning assessment. Detection / isolation has therefore been removed.
12. Section 7.4 Effects of bunding– The meaning of this section is unclear, consider review of this content.	Section 7.4 revised to clarify that the primary and second bunds are considered to contain all leaks, and that the maximum surface area of an associated pool fire is limited by the total area of the bunds.
13. Section 7.4.3 refers to Regulations in Northern Ireland which are not relevant to this application are to be removed or amended to reflect relevant legislation in ROI.	Revised accordingly.
14. Section 7.4.4 refers to Transformer oil. Confirm whether this substance meets the criteria of a dangerous substance as set out in in Schedule 1 of the COMAH Regulations 2015.	As discussed in Section 7.1, whether the transformer oil meets the dangerous substance criteria is dependent on the specific type of oil used, which is not finalised at this point. The transformer oil has therefore, conservatively, been evaluated in the MATTE as a dangerous substance.
15. Section 7.6 refers to “triple containment”, what does this mean? Provide further details.	Revised accordingly.
16. In Section 1.4 it states that there will be 16,000m <sup>3</sup> diesel stored at the site whilst in table 7.2 it refers to 11,500m <sup>3</sup> diesel. Confirm which amount is correct and correct figure throughout document.	While the total storage capacity of all the 5 tanks is 16,000 m <sup>3</sup> , the three-day tanks (~2,000 m <sup>3</sup> each) will normally be empty, so normally only 11,500 cubic metres of distillate will be stored. But for conservative purposes in the QRA, a total inventory of 16,000 m <sup>3</sup> of distillate is assumed as a worst-case scenario. Text in Section 1.4 revised to clarify.



### 3. National Parks and Wildlife Service (NPWS)

The Applicant notes NPWS submission and welcomes all potential conditions from the Board. The Applicant will ensure any such conditions relating to terrestrial and marine biodiversity are met following any grant of permission for the Proposed Development by the Board.

The Applicant's response in relation to the loss of habitat from Annex 1 habitats Estuaries and Reefs associated with the construction, installation and operation of the proposed drainage outfall pipe are provided in Section 3.1.

#### 3.1 Loss of Annex 1 Habitat Estuaries and Reefs

As detailed in Section 2.8.5 of the Natura Impact Statement (NIS) the installation of the drainage outfall, will result in temporary habitat loss of approximately 90m<sup>2</sup> of Annex I habitat above the low water mark and 10m<sup>2</sup> below the low water. Loss of Annex I habitat Estuaries habitat is estimated to be approximately 100m<sup>2</sup>, while the loss of Reef habitat is approximately 65m<sup>2</sup>. Installation of the pipe will result in the loss of 0.000041% and 0.000030% of the Annex I habitats 1130 Estuaries and 1170 Reefs respectively.

The approximate spatial extent of the habitat lost pending decommissioning is 0.000041% and 0.000030% of the Annex I habitats 1130 Estuaries and 1170 Reefs, respectively (NIS Section 3.4.4).

It is the Applicant's view as outlined in Section 3.4.4.2.2 of the NIS, that the loss of Annex I habitats 1130 Estuaries and 1170 Reefs habitat due to the installation of the drainage outflow pipe, relative to the total area of the habitats in the Special Area of Conservation (SAC) is negligible and will not give rise to negative impacts to the structure or functioning of the habitats.

Furthermore, the intertidal and subtidal surveys did not observe any rare, protected or unusual species, and those observed are known to occur widely, it can be concluded that the loss of habitat of this magnitude will have no impact on the structure and functioning of these Annex 1 habitats.

Finally, the Applicant would like to draw the attention of the Board to page 135 and page 208 of the Inspectors report with regards to ABP-311233-21<sup>1</sup>, where the inspector stated in relation to habitat loss from the drainage outfall pipe that:

*"The extent of loss is extremely limited relative to the extent of habitats within the estuary. Community types occurring within the habitats are not rare and occur widely. Subtidal species recorded are not rare, protected or unusual. Natural deposition of sediments and natural recolonisation of hard benthic surfaces by flora and fauna" (Page 135)*

*"Based on the evidence presented, I do not consider that the proposed development, occurring within this dynamic environment, will give rise to an adverse effect on the integrity of the Lower River Shannon Estuary cSAC as the loss of this very small amount of benthic habitat would not adversely impact on the ecological structure or function of the site or of the habitats and community complexes therein". Conclusion: "The loss of Annex I habitats 1130 Estuaries and 1170 Reefs, arising from the development will not give rise to negative impacts to the*

<sup>1</sup> <https://www.pleanala.ie/anbordpleanala/media/abp/cases/reports/311/r311233.pdf>

*functioning of the habitats, and will not result in adverse effects on the integrity of the cSAC or the Special Protection Areas (SPA).” (Page 208)*

## **3.2 River Shannon and River Fergus Estuaries SPA: Oil Pollution Prevention**

### **3.2.1 Nature of Spillage Containment for the tanker unloading station**

As detailed in Section 2.3.8.2 of Chapter 2 and Section 2.3 of the Appendix 2-5, Tertiary containment, bunding and associated pipework will be designed in accordance with EPA Guidance Note on *Storage and Transfer of Materials for Scheduled Activities (2004)*. The tanks will be located in a bunded area, which will allow for either 110% of the largest tank within the bund or 25% of the total volume of substance within the bund, whichever is the larger, in accordance with CIRIA C736, *Containment systems for the prevention of pollution: Secondary, tertiary and other measures for industrial and commercial premises, (CIRIA, 2014)*.

Refer to planning drawing reference 198291-SS-A4114, which details the design of the containment for the fuel storage and pumping facility including the tanker unloading area.

### **3.2.2 If there will be a rapid mechanism to close the presumed sluice between the pond and the stormwater outfall into the SPA in the event of a spillage entering the stormwater system**

Refer to Figure 2.14 of the Chapter 2, in the event of a fire or an oil spillage there is an automatic shut off valve located at the outlet of the firewater retention pond. The automatic shut-off valve is linked to the Site's fire detection system can also be used in the event of an oil spillage.

### **3.2.3 If equipment and materials to deter birds from landing in the pond will be available for immediate use in the unlikely event of an Oil Spillage**

The firewater retention pond will be lined with an appropriate liner to render it impermeable and will not develop aquatic vegetation. It will be located within a large industrial facility. In the absence of aquatic vegetation and given its location the pond will not attract significant numbers of birds including birds listed as conservation interests for River Shannon SAC and the River Fergus Estuaries SPA. Standard bird dispersal techniques may be used during operation to deter usage such as kites, scarers etc if required. However, the Applicant will ensure that equipment and materials to deter birds from landing in the pond will be available for immediate use in the unlikely event of an oil spillage. A designated member of staff will be assigned the task of ensuring that birds are moved away from the lagoon during an incident using standard bird scarers. Where longer term measures are required to prevent birds returning, the ecologist for the project will ensure that adequate medium to long term measures are implemented as required.

## 4. Transport Infrastructure Ireland (TII)

The Applicant notes the Transport Infrastructure Ireland (TII) submission and welcomes all potential conditions proposed by the Board. The Applicant will ensure all conditions relating to Traffic and Transport are met following any grant of permission for the Proposed Development by the Board.

Further clarity on the weight of the Heat Recovery Steam Generators (HRSG) and the Steam Gas Turbine (STG)-800 gas turbines are provided in the following subsections.

### 4.1 TII 2.2 – Structures

With reference to the expectational abnormal loads, the EIAR details a conservative weight for the STG component as being 238 tonnes, which represents an exceptional abnormal load as correctly stated by TII in their submission.

Following recent conversations between the Applicant and their Steam Turbine and HRSG suppliers, the Applicant has confirmed that the weight of each of the HRSG and STG will be below 150 tonnes.

The EIAR states that they will be transported by a modular six axle and three axle trailers in combination pulled by tow bar on a standard four axle lorry. According to the Department of Transport, the maximum weight laden for an articulated vehicle having a total of six or more axles is 40t<sup>2</sup>. Therefore, the total weight of the STG component including, the weight of the modular six axle and three axle trailers in combination pulled by tow bar on a standard four axle lorry, will be 190 tonnes. Therefore, this would fall under definition of an abnormal load as defined by TII, which is between 46 and 200 tonnes.

## 5. National Monument Services (NMS)

The Applicant notes NMS submission and welcomes all potential conditions proposed by the Board. The Applicant will ensure all conditions relating to marine and terrestrial archaeology are met following any grant of permission for the Proposed Development by the Board.

---

<sup>2</sup> [http://www.irha.ie/wp-content/uploads/2019/02/vehicle\\_weights\\_\\_dimensions\\_limits.pdf](http://www.irha.ie/wp-content/uploads/2019/02/vehicle_weights__dimensions_limits.pdf)

## **6. Submissions from An Taisce, Friends of the Environment, Gluaiseacht for Global Justice, Safety Before LNG, Not Here Not Anywhere, Future Generations Kerry, Melina & Christine Sharp & Michale Eversen.**

The Applicant appreciates the responses received and welcomes the opportunity to respond and address the matters raised.

Submissions from An Taisce, Friends of the Environment, Gluaiseacht for Global Justice, Safety Before LNG, Not Here Not Anywhere, Future Generations Kerry, Melina & Christine Sharp & Michael Eversen overlap and are somewhat repeated in many cases. Therefore, the Applicant has responded with the key themes identified in these under the following headings:

### **6.1 Obligations under the Climate Act**

The Climate Action Plan 2024 (CAP24), the National Long Term Climate Action Strategy, the National Adaptation Framework, relevant Sectoral Adaptation Plans and the National Climate Objective all support the project.

Compliance with these policies is discussed in detail in Chapter 4 (Energy and Planning Policy) and Chapter 15 (Climate) of the EIAR and is not repeated here for brevity. While this response does not propose to present any new information, the matters raised in the submissions are addressed to direct to the appropriate and relevant part of the EIAR where these issues were considered

These policies confirm that natural gas fired electricity generation will play an important role to 2030 and beyond in supporting intermittent wind generation and allow the phase out of carbon-intensive coal and peat fossil fuel power plants to more sustainable lower carbon fuel sources.

Nowhere in the Climate Action Plan (CAP) 24, the National Long Term Climate Action Strategy, the National Adaptation Framework, Sectoral Adaptation Plans or the National Climate Objective is there a policy to suggest that natural gas fired electricity generation is not required to 2030 and beyond.

At a macro level, national long term climate action strategy requires the electrification of transport and heat which will lead to a significant increase in electricity demand. And with the closure of coal and peat power plants under the CAP 24, natural gas electricity remains as the only significant source of electricity when wind and solar power cannot meet demand. Gas-fired power generation will be required to meet almost all of Ireland's electricity requirements on days of low wind.

As discussed in Chapter 4 and Chapter 15 of the EIAR, the absence of the Proposed Development does not stop Ireland needing natural gas fired electricity for when the wind does not blow or the sun does not shine.

The electrical demand in periods where no renewable energy can be generated would just be satisfied via higher carbon less efficient power plants, such as the proposed emergency generation units such as the 150 MW oil fired unit in Tarbert and the Shannonbridge Power Plant 264 MW distillate diesel oil unit in West Offaly.

For reference the Applicant's Proposed Development is a highly efficient low carbon combined cycle power plant, where the carbon impact is much lower than an equivalent Open Cycle Gas Turbine (OCGT) design (Figure 15.1, Chapter 15 of the EIAR) and diesel fired emergency generation units (such as those, as identified from information in the public domain, currently under construction at Tarbert and operational at Shannonbridge).

## 6.2 Carbon Budgets and Emission Reduction Obligations

Compliance with Carbon Budgets and Emission Reduction obligations is set out in detail in Chapter 4 (Energy and Planning Policy) and Chapter 15 (Climate) of the EIAR and is not repeated here in detail for brevity. While no new information needs to be presented, a brief summary conclusion is offered for ease of reference. Refer also to Section 4.2.15, Section 4.2.16, and Section 15.9 to 15.12 of the EIAR.

A carbon budget represents the total amount of emissions that may be emitted in the State during a five-year period, measured in tonnes of carbon dioxide (CO<sub>2</sub>) equivalent. It is calculated on an economy-wide basis.

As part of its work, the Climate Change Advisory Council is responsible for proposing three five-year economy-wide carbon budgets, covering the periods 2021-2025, 2026-2030 and 2031-2035, to assist the State in achieving its national climate objectives and greenhouse gas emissions targets agreed by the European Union.

The Climate Action Plan 2024 (CAP24) is the third annual update to Ireland's Climate Action Plan. It is discussed in Section 4.2.3 of the EIAR. CAP24 was approved by Government on 20th December 2023.

CAP24 builds upon CAP23 by refining and updating the measures and actions required to deliver the carbon budgets and sectoral emissions ceilings. The Plan provides a roadmap for taking decisive action to halve Ireland's emissions by 2030 and reach net zero by no later than 2050, as committed to in the Climate Action and Low Carbon Development (Amendment) Act 2021. CAP24 notes:

*"Rapid delivery of flexible gas generation is needed at scale and in a timeframe to replace emissions from coal and oil generation as soon as possible to reduce impacts on the carbon budgets. The introduction of renewable gas generation into the grid is an important factor of ensuring a security of supply for Ireland's electricity system".*

The design of the Proposed Development have been chosen for its flexibility and efficiency. All future energy scenarios, show gas power plant being required in the period to 2050 and beyond. Given that it is accepted by all competent authorities that gas-fired generation will be required, there will be emissions in aggregate from power plant operating in the Single Electricity Market regardless of which individual plant generates the emissions.

The operation of the Single Electricity Market, which takes into account the cost of emissions under the EU Emissions Trading Scheme<sup>3</sup>, dictates that the most efficient and least emitting plant will be dispatched first for energy generation and system stability purpose. The efficiency of the Proposed Development combined with its ability to operate at a low minimum generation capacity means that the Proposed Development (CCGT) will be dispatched ahead of a less efficient OCGT power plant, as it will provide lower direct emissions and also provide system inertia (and other system services) at a lower output allowing for higher instantaneous renewable (non-synchronous) generation that would otherwise be the case if the Proposed Development was not developed<sup>4</sup>.

In summary, the Proposed Development is compliant with carbon budgets and emission reduction obligations.

### 6.3 Operational Life and Construction Timeframe

The need for gas fired generation up to 2050, and beyond, is clearly set out in Chapter 4 of the EIAR and is not repeated here for brevity. No new information needs to be presented.

Currently, policies do not forecast beyond 2050, but regardless of forecasts, renewable generation will remain intermittent. The wind does not blow, and the sun does not shine 100% of the time. The Applicant foresees the need for the Proposed Development post 2050. For this reason, an operational life of 25 years was selected.

Future policy and legislation between now and 2050 may impose additional requirements on the Proposed Development. If this is the case, then the Applicant will, in accordance with industry planning requirements, seek planning permission for any additional technology as required.

### 6.4 University College Cork (UCC) Research, McMullin et al, “Lock In”

Reference is made in submissions to UCC research and McMullin *et al* , which seems to suggest that as more renewable penetration is built, the existing natural gas infrastructure (pipeline and power

---

<sup>3</sup> EirGrid is part of the EirGrid Group who, through the Single Electricity Market Operator (SEMO), is responsible for the operation of the Single Electricity Market (SEM). SEM is the all-island wholesale electricity market. As the TSO, EirGrid plays a vital role in the operation of the SEM. EirGrid's electricity forecasts are used to ensure that there is sufficient generation capacity to meet electricity demand at all times of the day. The dispatch of the Power Plant will be controlled by SEMO. Dispatch under the I-SEM is determined by economic merit as well as the requirements of the grid and EirGrid are obliged to dispatch based on economic merit. As all power production requires the producer to purchase the necessary emissions allowances under the ETS, the cost of emissions as per the ETS is reflected in the price of power and therefore in dispatch (i.e. plants which are less carbon efficient will have higher costs and be lower in the economic merit order). Plants are required under the balancing market principles code of practice to reflect the cost of carbon in their bidding prices which ensure the I-SEM arrangements reflect carbon efficiency as a part of the overall dispatch of plants (SEM Committee, 2017).

<sup>4</sup> As the level of renewable generation on the system at any one time increases, thermal power plant has their dispatch quantities decreased by EirGrid to facilitate the output of the renewable power plants. However, a certain number of dispatchable plants must remain on the system to provide the services mentioned above. 'Positioning' is when the grid operator keeps a power plant running so as to be on standby to provide these services to the grid operators in real time. This is a vital process for grid stability; however, with inflexible power plants it can lead to larger than necessary power plants being positioned. This causes increased emissions, increased curtailment of renewables (to make room for the positioned power plant) and increased costs.

plants) will have sunk costs that will need to be paid for regardless of use, and this then may present a barrier to decarbonisation.

An Taisce summarise the point by noting, *“favouring conventional power plants at the expense of investment in clean fuels exacerbates the fossil gas lock in problem and elevates the risk of stranded assets”*.

An Taisce and others present this concern as a “Lock in” of fossil fuels. It is noted that “lock in” is not defined within the submissions received or within any recognised economic textbook or government policy.

The submissions infer that academic research is suggesting that building a merchant power plant confers an enduring and indefinite obligation on the state. This is not the case.

The power plant is a private merchant plant, and the State is not underwriting the investment. When the power plant is no longer needed it will be decommissioned. This is clearly discussed in the EIAR. Section 15.8.1.2 Operational Phase GHG Emissions of the EIAR states that the power plant will only operate when dispatched by the Grid operator and only after renewables are despatched first.

Finally, it should be noted that electrical demand sets supply. The presence, or absence, of supply (i.e. power plants) does not impact demand.

## 6.5 Major Adverse Climate Impact

Mitigation measures for the Proposed Development are adequately set out in Chapter 15 of the EIAR. These mitigation measures are not repeated here for brevity. No new information is presented. As detailed in Section 15.2 Chapter 15, emissions from the Proposed Development will equate to around 2.8% of Ireland’s carbon allowance in 2030, a major adverse impact, however without the supply of dispatchable energy from gas fired power stations to support the wider decarbonisation of the economy, these reduction targets may not be met. Furthermore, direct operational emissions from the Proposed Development will be covered by the EU ETS.

A number of embedded mitigation measures have been developed through the design process to reduce GHG emissions throughout its design life including measures to reduce energy and material consumption. Further, in the future it is likely that the Proposed Development may be transitioned from a natural gas to a hydrogen-powered facility which would substantially reduce GHG emissions and aid the further decarbonisation of the national grid. Any future operation on hydrogen will require a future planning application, which is specifically noted in the EIAR

## 6.6 Fugitive Emissions and Methane Leakage

An Taisce and others suggest that fugitive emissions of methane have not been assessed because of the content of Table 15-2 of the EIAR.

While there is a lacuna in the text of Table 15-2, the Applicant confirms for completeness that fugitive emissions were included in the assessment, as evidenced in Table 15-19, where the fugitive emissions are calculated and reported.

Table 15-19 clearly shows that Well to Tank (WTT) emissions (also labelled as Fuel and Energy-Related Activities) have been included within the assessment, contributing c. 7% of total operational emissions.

WTT emissions include those resulting from venting, flaring and estimated methane leakage within the overall supply chain. Fugitive emissions of methane, therefore, have been considered within the assessment.

It is also important to differentiate between fugitive emissions from the upstream natural gas supply chain and those within the Proposed Development itself. Upstream fugitive emissions are included within the wider WTT emissions and are reported in Table 15-9 and fall under Scope 3.

Fugitive emissions within the Proposed Development would fall under Scope 1, and these emissions are de minimis and not expected.

Scope 1 fugitive emissions of methane within the development are de minimis and not expected for the following reasons

1. As noted in Chapter 1 of the EIAR, equipment specifications of the Proposed Development are such that it will be required to operate under an IE Licence, to submit annual environmental information and emissions reports to the EPA, and to surrender sufficient EU Allowances to cover its annual emissions under the terms of the EU Emissions Trading System (ETS).
2. The Proposed Development will also be classified as a Lower Tier Control of Major Accidents Hazards (COMAH) Establishment. The Site will therefore need a licence to operate from the HSA. The HSA licence will require us to operate the facility in a safe and compliant manner and eliminate any leaks.
3. As noted in Chapter 2, the Site will have an Integrated Control and Safety System (ICCS) system. The ICSS will be a distributed control system that will provide process control, fire and gas detection, event logging, and emergency shutdown (ESD) functions. Any methane leakage in any part of the Proposed Development (Power Plant) will be detected and will activate the Fire and Gas System (FGS), Process Safety System (PSS) and / or ESD systems accordingly, and the emission stopped.
4. Natural gas (methane) within the site will be odourised which is detectable at parts per billion level. Any fugitive emission will be instantly detected and stopped.

In conclusion, fugitive emissions were included in the assessment, as evidenced in Table 15-19, where the fugitive emissions are calculated and reported. Fugitive emissions within the facility are de minimis.



## 6.7 Cumulative Impacts and Project Splitting

Chapter 1 of the EIAR notes the following:

*“The Masterplan for the Shannon Technology and Energy Park (STEP) will integrate the Proposed Development and a (future) Strategic Gas Reserve Facility and a (future) Data Centre Campus. Note – The Strategic Gas Reserve Facility and Data Centre Campus is not included in this application and will therefore be subject to a separate planning application. It is important to note the STEP Power Plant (the Proposed Development) is not functionally dependent on the Strategic Gas Reserve Facility or the Data Centre, i.e. the Power Plant can and will operate without the Strategic Gas Reserve Facility or Data Centre”.*

The overall Shannon Technology and Energy Park (STEP) is required to be approved by means of a series of applications. This is not the same as a deliberate splitting of a large project. In fact, it is important to note that an EIAR either has been (i.e. in respect of the 220kV Grid Connection, application currently pending before the Board), or will (i.e. in respect of the Strategic Gas Reserve Facility and Data Centre Campus, subject to future planning applications) be prepared to cover every element of the overall STEP project. All of the relevant impacts have been fully assessed and the EIA processes followed are fully in accordance with the EIA Directive and transposing legislation in Ireland. Therefore, no project splitting or failure to assess cumulative impacts arises if each part of the masterplan development is subject to the EIA Directive.

The assessment of greenhouse gas emissions in Chapter 15 specifically referred to in An Taisce’s submission, has been undertaken following best practice guidance from the Institute of Environmental Management and Assessment (IEMA) (Assessing GHG emissions and evaluating their Significance, 2nd version 2022). IEMA states that all global cumulative GHG sources are relevant to the effect on climate change, and this should be taken into account in defining the receptor (the atmospheric concentration of GHGs) as being of high sensitivity to further emissions.

As such, IEMA goes on to state that *‘Effects of GHG emissions from specific cumulative projects therefore in general should not be individually assessed, as there is no basis for selecting any particular (or more than one) cumulative project that has GHG emissions for assessment over any other.’*

Following this guidance, it was therefore deemed not necessary nor appropriate to consider cumulative impacts from developments being brought forward under separate planning applications.

Furthermore, the assessment considers the impact of GHG emissions from the Proposed Development on Ireland meeting its national carbon budgets and targets. In doing so this assessment, it is considered inherently cumulative as it considered emissions from the Proposed Development in context of Ireland as a whole.

## 6.8 Feasibility of Hydrogen Transition

The concern about using hydrogen as a sustainability measure in this application is premature. The Applicant is not proposing the use of hydrogen as a sustainability measure in this application. The Applicant is not seeking planning permission to operate under hydrogen in this application. The EIAR considers the Proposed Development operating on natural gas only. Any future operation on hydrogen will require a future planning application, which is specifically noted in the EIAR. However as stated in

Section 2.1 of Chapter 1, the Applicant notes that the Proposed Development has the capability to operate at a 50% blend of hydrogen by design, offering the potential for the Proposed Development to become even more efficient in emission terms over the period to 2050. For reference, the Applicants 485MW Power Plant at Long Ridge, Ohio is the first purpose-built hydrogen-burning power plant in the United States (US). The plant is burning between 15-20% hydrogen initially, with the capability to transition to 100% hydrogen over time. The intention, over time, is for the Proposed Development to match this, when the required policies and supply chains for hydrogen are implemented.

The commitment to the transition to hydrogen is demonstrated by the Applicant and its business objectives on a global scale where it is currently constructing a 120MW electrolyser plant near Beaumont, Texas. This is expected to be the largest such facility in the US<sup>5</sup>.

## 6.9 Decarbonisation Renewables vs Emission Reduction

An Taisce suggest that the key to decarbonisation is emissions reduction and not renewables penetration. The Applicant agrees with An Taisce in this qualitative statement. As described in this RFI and the EIAR, the Proposed Development will have significantly lower emissions than other power plants due to its CCGT efficiency and low carbon natural gas fuel, i.e. by displacing higher carbon power plants the Proposed Development will be a significant emissions reducing project.

Of course, as described in Chapter 15, the Proposed Development will only be operated by the grid operator to support wind generation. It will never compete with wind generation.

In summary, the Proposed Development is in full compliance, and is indeed called for, by all relevant climate action policies as clearly set out in Chapter 4 of the EIAR. These reasons are not repeated here for brevity. No new information is presented.

## 6.10 Pipeline Planning Permission

By decision dated 17 February 2009, the Board granted approval to the Applicant Shannon LNG for a 26km gas pipeline between Ralappane, County Kerry, and Leahy's, County Limerick, under section 182D of the Planning and Development Act, 2000 (as amended) Board Ref. PL08.GA0003. The pipeline approval under section 182D is for indefinite duration.

## 6.11 Impacts to Lower River Shannon

The claim that the impact of the warm water discharged was not assessed is incorrect.

As detailed Appendix 3 of the NIS Hydrodynamic and dispersion modelling assessment was undertaken. As part of this study, a computer based hydrodynamic and water quality model Telemac was used to assess the potential changes in water quality and temperature in the receiving waters from the heated water discharges from the outfall pipe. Section 3.7 states that:

*“The Heated discharge from the processed waters was modelled at 28°C above ambient with the ambient at 12°C. The maximum and mean temperature envelopes are presented in Figures 13 and 14 over a full 15-day spring-neap-spring tidal period. These plots show a very local rise*

---

<sup>5</sup> <https://ir.newfortressenergy.com/news-releases/news-release-details/nfe-enters-agreement-plug-power-120-mw-green-hydrogen-plant-gulf>

*in temperature at the outfall site having a maximum increase of 0.9135°C and a mean increase at the outfall site of 0.069°C. The maximum temperature increase reduces within 100m of the discharge point to 0.171°C which is an insignificant impact. Plume rises and mixes in the water column due to a lower density than the receiving waters. At the outfall site, the maximum temperature occurs at the sea bed but within a short distance, the plume is well mixed vertically.”*

## 6.12 An Taisce 7.1 – Impact on Breeding Birds

The conservation objectives for the River Shannon and River Fergus Estuaries (NPWS 2012), largely relates to wintering birds. One species i.e., Cormorant, has conservation objectives associated with wintering and breeding. As in noted in **Appendix 7B.3 Estuarine bird report** of the NIS

*It is noted Cormorant is listed as a breeding and wintering Special Conservation Interests (SCI) for the River Shannon and River Fergus Estuaries SPA. No signs of breeding Cormorant were recorded at the Proposed Development site and no trees suitable for use as Cormorant roosts or nesting sites were recorded within the Proposed Development site boundary.*

There are no other SCI species which are listed as breeding SCI species within the River Shannon and River Fergus Estuary SPA. While the breeding populations of the other four species listed in the submission i.e., Golden Plover, Dunlin, Lapwing and Ringed Plover are threatened, the breeding status of these species is not relevant to the conservation objectives of the River Shannon and River Fergus Estuary SPA. As is detailed in **Appendix 7B.2** of the EIAR, breeding bird surveys were carried out in 2019/2020 and in 2023. No breeding SCI species were recorded within the Proposed Development site during these breeding bird surveys. Ringed Plover were recorded along the shoreline to the southwest of Knockfinglas Point during the breeding surveys (over 500m west of the Proposed Development site). However, no confirmed breeding was recorded.

The submission from An Taisce notes that 42 species of birds were recorded over a two year survey period. As illustrated in Figure 3.47 and detailed in section 3.3.4.1 of the NIS, this survey area covered over 4.5km of coastline extending east and west from the Proposed Development site. The NIS includes details on the peak numbers of birds recorded from each of the vantage points (six vantage points) along this stretch of the Shannon Estuary and describes the types of habitats visible from each vantage point. Further detail on bird surveys and results are included in the **Appendix 7B.3 Estuarine bird report** which accompanies the NIS. As illustrated in **Figure 3.47**, Point B and Point C overlook the Proposed Development site as well as the shoreline to the east and west of the Site. Overall low numbers of birds were recorded from Point B and Point C throughout the winter and summer surveys. Peak numbers of birds recorded are discussed within **Section 3.3.4.1** of the NIS as follows:

*Point B is located at Knockfinglas Point to the west of the Proposed Development site. Low numbers of gulls, diving birds, and waders were recorded here during both low and high tide surveys. Peak bird numbers at this site were 65 black-headed gulls (13/01/22), 40 light-bellied brent goose (19/03/22), 15 herring gull (17/12/21) and 12 cormorant (17/12/21). All other species were recorded in low numbers.*

*SCI wading birds/waterfowl i.e., curlew (peak number six), redshank (peak number one), shelduck (peak number two), wigeon (peak number seven) and ringed plover (peak number four).*

*Point C is located at Ardmore Point to the east of the Proposed Development site boundary. This overlooks slightly deeper waters than the other survey points with limited intertidal habitats. Gull and divers were regularly recorded at this site, albeit in small numbers. A mixed flock of gulls including 300 black-headed gull was recorded in November 2022. Few SCI waders were recorded here, likely due to the limited foraging habitat present; curlew (peak number 10), lapwing (peak number four). Small numbers of SCI duck species i.e., wigeon (peak number 12), were recorded here at low tide.*

The following summary of these results is included in **Section 3.3.4.1** of the NIS

*With the exception of black-headed gull, bird numbers foraging in the Shannon Estuary to the north of the Proposed Development site are low. This reflects the lack of suitable intertidal foraging habitat in this area, which is largely confined to a small stretch of gravel/shingle shore and subtidal waters. Small numbers of conservation feature bird species were recorded within 500m of the Proposed Development site during winter and summer bird counts. Curlew were recorded foraging on wet grassland habitat near Knockfinglas Point (Point A, Beach and Lagoon), to the west of the Proposed Development site. No terrestrial foraging conservation feature bird species were recorded within the Proposed Development site boundary. While there are small areas of wet grassland within the western section of the Proposed Development site, no terrestrial foraging SCI waders were recorded in this area.*

These results support previous studies along this section of the Shannon Estuary by I-WeBS, NPWS and MKO as well as survey for the applicant in 2006/2007, 2011/2012 and 2018-2020 which found small numbers of SCI birds along the shoreline bordering the Proposed Development site (See Appendix 7B.3 for details).

The following text is noted in the NIS with regards to blasting operations.

*All blasting locations are confined to the onshore habitats and significant noise will dissipate quickly outside the immediate works area. Proposed blasting locations are located at the east of the Proposed Development site. It is understood that no more than one blast per day are envisaged and blasting vibration limits will be achieved by limiting the Maximum Instantaneous Charge (MIC) used in the blasting process. There are no blasting locations within the SAC or SPA and the blasting areas at the east of the Site are a considerable distance from areas used by conservation feature birds and otter.*

*According to Cutts et al. (2013), a single sudden sound such as blasting will generally cause more disturbance than a constant or regular noise regardless of noise level. The typical response would be for birds to move away from affected areas to less disturbed areas. Birds that remain in the affected area may not forage effectively and this may impact on survival and foraging rates. It is noted that a range of measures will be adopted during the blasting stage of the construction phase to minimise the impact of air overpressure as far as practicable. Given the distance from sensitive receptors, overpressure and vibration impacts from blasting will not be significant. While blasting noise during*

*construction may lead to significant noise in some terrestrial areas of the proposed development site and temporarily displace small numbers of birds from the adjacent lands, given the temporary nature of blasting and the distribution of conservation feature species in the vicinity of the site, no significant impact on the distribution or numbers of conservation interest species within the Lower River Shannon SAC or River Shannon and River Fergus Estuaries SPA will occur.*

While it is noted that different species will have different responses to noise/disturbance, in the case of blasting it is noted that birds are likely to move away from affected areas. However, given the small numbers of birds using the shoreline adjoining the Proposed Development site and the temporary nature of blasting works there is no potential for significant disturbance effects to any SCI species within the River Shannon and River Fergus Estuaries SPA.

As it noted in **Section 3.6.4**, Blasting vibration limits will be achieved by limiting the MIC based on the results of trial blasts carried out in accordance with the procedure detailed in BS6472.

In addition to this, and in line with best practice, construction noise will be monitored throughout the construction process as detailed in Section 3.6.4 of the NIS.

### 6.13 An Taisce 8.0 – Visual and Light Pollution

The potential impacts from lighting could potentially impact on nocturnal fauna such as otter, bats, night foraging/roosting birds. Chapter 7B of the EIAR assesses the potential impacts of increased construction and operational lighting on a range of faunal species. Mitigation measures have been specified during construction and operation to minimise the impacts on lighting and as detailed in the EIAR. Lighting levels will meet national and international engineering standards as a minimum. Light spillage will be largely confined to the lands in the immediate vicinity of the power plant. Modelling of light spillage from the power plant shows that light spillage onto the estuary during operation will be negligible i.e. largely 0.0lux to 0.6lux.

### 6.14 Proposed LNG Terminal

ABP Ref No. ABP-311233-21 for a 10-year permission for a Strategic Infrastructure Development (SID) comprising a power plant, battery energy storage system, regasification unit, jetty and onshore receiving facilities, and an AGI, which was refused by An Bord Pleanála (ABP) (“the Board”) on 15th September 2023 and is currently subject to Judicial Review proceedings. Therefore, the applicant will not be commenting further on this point made by FOE.

In response to the Energy Security Review Package a pre-application was submitted to ABP on 8th March 2024, and a request for a pre-application consultation meeting is pending from the Board. The Proposed STEP Strategic Gas Reserve Facility (APB-319245-24) will include onshore facilities, jetty and FSRU which will extend into the Shannon Estuary at the north-east corner of the Site.

## 6.15 Alternative Locations not considered

Annex IV of the EIA Directive requires the developer to include a description of reasonable alternatives, however the obligation is to only consider reasonable alternatives, therefore excluding unreasonable alternatives i.e., that technically or economically unfeasible. For this reason, the Tarbert Ballylongford Landbank was the only suitable location to accommodate the Proposed Development.

As detailed in Chapter 3 of the EIAR, the Tarbert Ballylongford Landbank a suitable location to accommodate and safely operate the Proposed Development because the location offers the following:

- A large unoccupied landbank on the coast which is zoned for industrial purposes.
- Under the Kerry County Development Plan (CDP) 2022-2028, the Site of the Proposed Development is part of 430.6 hectares (ha) of land which are zoned as a Strategic Development Location (SDL). This SDL is recognised in the CDP for its potential as an Energy Hub and for industrial development at a regional and national level.
- The Site is located in one of nine strategic development locations identified in the Strategic Integrated Framework (SIFP): 'Strategic Development Location H: Tarbert-Ballylongford land bank, Ballylongford'.
- The Shannon Estuary Economic Taskforce recommendation that electricity generation would be a significant strategic investment in the North Kerry / West Limerick region.
- Access to high-capacity gas transmission network (i.e., the 26km Shannon Natural Gas Pipeline has already been permitted).
- The ability to get a high voltage export grid connection offer within the generation capacity shortfall time window.
- Access to high-capacity electricity grid (220kV or higher) that can export 600MW without undue system constraint.

Furthermore, the technology chosen requires suitable available land of sufficient dimensions and also requires a main fuel supply and an electricity grid connection and therefore why an interest in the existing site. Non-environmental factors can have equal or overriding importance including the project economics, land availability, engineering feasibility or planning considerations.

## 6.16 Flow direction of the pipeline

Several submissions have sought clarity on the description of the Above Ground Installation (AGI) in the site notice. The Applicant notes that the site notice states that ***“the AGI will facilitate the import of natural gas to the national gas transmission network”***. [emphasis added].

For completeness and in full, Section 3 of the site notice reads as follows.

- “3.0 A proposed Above Ground Installation (AGI) to include:*  
*— 2no. single-storey chromatograph buildings (approximately 14.19m<sup>2</sup> and approximately 2.7m in height each);*

- 1no. single-storey control & instrumentation building (approximately 186.7m<sup>2</sup> and approximately 4.29m in height);
- 1no. single-storey metering building (approximately 480m<sup>2</sup> and approximately 5.175m in height); aecom.com 3/5
- 5no. single-storey boiler unit buildings (approximately 42.24m<sup>2</sup> and approximately 8m in height each);
- 1no. single-storey regulator building (approximately 243.6m<sup>2</sup> and approximately 5.27m in height);
- 1no. single-storey generator kiosk building (approximately 60.72m<sup>2</sup> and approximately 3.25m in height);
- The following ancillary structures: heat exchangers; filtering; reverse flow valve arrangement; pig trap; and fuel gas let down units.

*The AGI will facilitate the import of natural gas to the national gas transmission network via the already consented 26km Shannon Pipeline (ABP Reg. Ref. PL08.GA0003 and PL08.DA0003)."*

But **Section 2.3** of the EIAR Chapter 2 clearly clarifies that *"The fuel supply to the Proposed Development will be from the gas grid through the Above Ground Installation connection (AGI)"* [emphasis added].

And **Section 2.9.2** (Fuel Supply) of the EIAR also clearly clarifies that *"As outlined in Section 2.3.1.6, the fuel supply to the Proposed Development will be from the gas grid through the AGI. The Proposed Development will use approximately 25.5 GW per day of natural gas when operating at full capacity"* [emphasis added].

And more generally, the description of the Proposed Development throughout the Site Notice, EIAR, NIS and drawings, clearly describe and indicate that the power plant will be fuelled by natural gas supplied from the GNI natural gas network to the power plant via the AGI.

## **Appendix 1: QRA Power Plant Rev 05**






Report for:	Shannon LNG Limited
Report reference:	RMC0500653-R02
Date:	9 August 2024
Release:	05



# Shannon Technology Energy Park (STEP) Power Plant Land Use Planning

Quantitative Risk Assessment (QRA) – Power Plant

# Report Information

Shannon Technology Energy Park (STEP) Power Plant Land Use Planning: Quantitative Risk Assessment (QRA) – Power Plant		
<b>Report reference:</b> RMC0500653-R02	<b>Date:</b> 9 August 2024	<b>Release:</b> 05
<b>Prepared by:</b> Jaime del Valle Team Lead Spain	<b>Reviewed by:</b> Mireia Amigó Senior Risk and Safety Consultant	<b>Approved by:</b> Jaime del Valle Team Lead Spain
		
<b>Client contact:</b> Kieran O'Connor Permit, Regulatory and Environmental Lead T: +353 87 1464 794 koconnor@newfortressenergy.com	<b>Client entity and address:</b> Shannon LNG Limited Listowel Business Centre, Clieveragh Industrial Estate Listowel, Co. Kerry, V31 Y066, IRELAND	
<b>Vysus Group contact:</b> Mireia Amigó Senior Consultant T: +34 (0) 936097131 M: +34 (0) 676639206 mireia.amigo@vysusgroup.com	<b>Vysus Group entity and address:</b> Vysus UK Limited Regus Manchester Business Park 3000 Aviator Road Manchester, M22 5TG United Kingdom	

**Document control (Vysus Group internal use):**

Release	Prepared by	Reviewed by	Approved by	Date	Comments
00	MA	AB	AB	21 Feb 2024	Draft for initial review
01	MA	CS	AB	8 Mar 2024	Issued to client
02	MA	CS	AB	14 Mar 2024	Client comments included
03	MA	CS	AB	25 Mar 2024	Client comments included
04	MA	AB	AB	26 Jul 2024	HSA comments included
05	JdV	MA	JdV	9 Aug 2024	HSA comments included

Vysus Group and variants of it are trading names of Vysus Group Holdings Limited, its subsidiaries and affiliates. Vysus Group Holdings Limited is a limited company registered in England and Wales, registered number 12912998. Registered office: Suite C, 105 Piccadilly, London, W1J 7NJ.

Vysus Group Holdings Limited, its subsidiaries and affiliates and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Vysus Group'. Vysus UK Limited is a member of Vysus Group.

Vysus Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Vysus Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This document includes personal data as defined by the General Data Protection Regulation (EU2016/679) ('Regulation'), and you (client) are obliged to process this data in accordance with the Regulation. This personal data is not to be disclosed to any other party outside the client group and not used for other purpose other than in connection with this project. No personal data is to be transferred outside the country of receipt.

Except as permitted under current legislation no part of this work may be photocopied, stored in a retrieval system, published, performed in public, adapted, broadcast, transmitted, recorded or reproduced in any form or by any means, without the prior permission of the copyright owner.

Enquiries should be addressed to Vysus Group, Proserv House, Prospect Road, Arnhall Business Park, Westhill, AB32 6FJ. © 2024 Vysus Group

---

# Table of Contents

List of Figures .....	5
List of Tables.....	6
List of Abbreviations .....	7
Executive Summary .....	8
1 Introduction .....	10
1.1 Project Background .....	10
1.2 Objectives and Scope .....	10
1.3 Location and Surroundings .....	10
1.4 Site Summary .....	12
1.4.1 Power Plant.....	12
1.4.2 AGI .....	12
1.5 Hazardous Substances .....	13
1.5.1 Properties of Natural Gas .....	13
1.5.2 Hazards of Natural Gas .....	14
1.5.3 Properties of Diesel.....	15
1.5.4 Hazards of Diesel.....	15
2 Facility Description .....	17
2.1 Above Ground Installation (AGI) .....	17
2.2 Power Plant .....	17
2.3 Diesel Storage Unit .....	17
3 Overview of the QRA Methodology .....	19
3.1 Introduction.....	19
3.2 Sectors .....	19
3.3 Scenarios and Frequencies Definition .....	20
3.3.1 Scenarios in the AGI .....	20
3.3.2 Scenarios in the Power Plant.....	21
3.3.3 Scenarios in the Storage Unit .....	21
3.4 Consequence Analysis.....	23
3.4.1 Source Term Modelling.....	23
3.4.2 Physical Effects Modelling .....	23
3.4.3 Impact Modelling .....	24
3.5 Frequency Analysis .....	25
3.6 Risk Analysis .....	26

3.7	Risk Assessment .....	26
4	Scenarios' Conditions .....	27
5	Frequency Analysis .....	29
6	Ignition .....	30
7	Consequence Modelling .....	31
7.1	Modelling Software .....	31
7.2	Fluid Composition .....	31
7.3	Operating Conditions .....	31
7.4	Effect of Bunding .....	31
7.5	Effect of Topography .....	31
7.6	Releases onto Land and Water .....	31
7.7	Dispersion Modelling .....	32
7.8	Surface Roughness Parameter .....	32
7.9	Averaging Time .....	32
7.10	Weather Data .....	32
8	Populations .....	35
8.1	Offsite Populations .....	35
8.2	Onsite Personnel .....	35
9	Risk Criteria .....	36
9.1	Individual Risk .....	36
9.2	Expectation Value (EV) .....	36
9.3	Societal Risk – FN Curve .....	36
10	Risk Calculation Results .....	38
10.1	Consequence results .....	38
10.2	Individual Risk .....	38
10.3	Expectation Value and Societal Risk .....	40
11	Conclusions .....	41
12	References .....	42
Appendix A.	Description of Development Types According to the Guide [2] .....	43
Appendix B.	Above Ground Installation General Arrangement .....	44
Appendix C.	Power Plant General Arrangement .....	45
Appendix D.	Tanks Layout .....	46
Appendix E.	Hazardous and Noxious Substances Spill Plan .....	47

---

# List of Figures

Figure 1 Site Location with indication of the COMAH Establishment boundary .....	11
Figure 2 Proposed Site Overview .....	11
Figure 3 Event tree for a continuous release of a flammable gas (source: BEVI [3]) .....	14
Figure 4 Individual risk zones to be plotted on a map according to the guide [2] .....	19
Figure 5 Development types allowed in each risk zone according to the guide [2] .....	19
Figure 6 AGI natural gas pipelines .....	20
Figure 7 Heat flux and fatality levels, outdoor, for a 60s exposure .....	24
Figure 8 Heat flux levels relevant for people within buildings .....	25
Figure 9 Overpressure fatality thresholds for people outdoors .....	25
Figure 10 Roughness lengths for given types of terrain .....	32
Figure 11 HSA Upper and lower societal risk criterion (log scale) .....	37
Figure 12 Outdoors Individual Risk Contours .....	39
Figure 13 Indoors Individual Risk Contours .....	39
Figure 14 Affected population .....	40
Figure 15 Levels of development according to the guide [2] .....	43

---

# List of Tables

Table 1 Substances subject to control under COMAH regulations in the power plant.....	13
Table 2 Properties of methane [6] .....	13
Table 3 Properties of diesel .....	15
Table 4 Scenarios for aboveground natural pipelines with D > 150 mm (Table 40 of the guide [2]) .....	21
Table 5 Scenarios defined in AGI .....	21
Table 6 Scenarios for process vessels (Table 64 of the guide [2]) .....	21
Table 7 Scenarios defined in power plant .....	21
Table 8 Scenarios for diesel tanks (Table 48 of the guide [2]) .....	22
Table 9 Scenarios for aboveground pipelines (according to BEVI [3]) .....	22
Table 10 Scenarios for transport scenarios (according to BEVI [3]) .....	22
Table 11 Scenarios defined in the storage unit .....	22
Table 12 Scenario conditions .....	28
Table 13 Summary of all scenarios considered in the QRA .....	29
Table 14 Ignition Probability .....	30
Table 15 Wind Rose for Day.....	34
Table 16 Wind Rose for Night.....	34
Table 17 Offsite Populations.....	35
Table 18 Scenario results .....	38

---

# List of Abbreviations

AGI	Above Ground Installation
BESS	Battery Energy Storage System
BLEVE	Boiling Liquid Expanding Vapour Explosion
CCA	Central Competent Authority
CCGT	Combined Cycle gas Turbine
CHP	Combined Heat and Power
COMAH	Control of Major Accident Hazards
cpm	Chances per million (years)
EV	Expectation Value
GNI	Gas Networks Ireland
HRSG	Heat Recovery Steam Generator
HSA	Health and Safety Authority
LFL	Lower Flammability Limit
LNG	Liquified Natural Gas
LOC	Loss Of Containment
LPG	Liquefied Petroleum Gas
LUP	Land Use Planning
QRA	Quantitative Risk Assessment
RNG	Renewable natural gas
SEP	Surface Emissive Power
SDS	Safety Data Sheet
STEP	Shannon Technology Energy Park
TLUP	Technical Land-Use Planning
UDM	Unified Dispersion Model
VCE	Vapour Cloud Explosion

---

# Executive Summary

New Fortress Energy plans to construct a 600 MW power plant on Tarbert Ballylongford Landbank in the Kerry County Council Development Plan 2022-2028.

The STEP Power Plant consist of:

- A power plant, with different trains, with a total production capacity of 600 MW;
- Liquid fuel storage as power plant backup for production and the facilities needed to receive it; and,
- An above Ground Installation (AGI) accommodating valves and control equipment to receive the natural gas from pipeline.

The Irish Health and Safety Authority (HSA) is the statutory body providing technical land-use planning (TLUP) advice in Ireland, which it does at the request of a planning authority. Its policy on TLUP under the Seveso-III Directive [1] is presented in the document Guidance on technical land-use planning advice for planning authorities and COMAH establishment operators [2]. This document provides a clear guidance for the elaboration of a QRA for land use planning, defining scenario frequencies and modelling parameters, with emphasis in a risk-based approach. It identifies sector types and explains for each sector, the nature of accidents that will be considered, along with the scientific approach to estimate the likelihood of those accidents occurring. This enables lines of equal risk (isorisk contours) to be drawn on a map of the establishment and the surrounding area, defining three risk zones. Subsequently, based on the risk level, more or less intensive / extensive developments are allowed, with a decreasing likelihood of being advised against undertaking such developments as the risk decreases across the zones. The QRA conducted according to the HSA guidelines.

The QRA evaluates risk zones surrounding and due to the power plant and the diesel storage. With this aim, a comprehensive quantitative risk assessment (QRA) of the proposed Shannon Technology and Energy Park (STEP) 600 MW Power generation Combined Cycle Gas Turbine (CCGT) plant and the diesel storage unit has been conducted. The QRA has used the suite of models incorporated into the DNV SAFETI software (version 8.9). SAFETI is a comprehensive hazard and risk analysis software tool for all stages of design and operation.

The QRA evaluates risk to personnel associate with release from:

- The diesel storage unit;
- The AGI;
- The onsite piping; and,
- The power generation Combined Cycle gas Turbine (CCGT) Plant.

The following risks are evaluated:

- Individual risk of fatality contours;
- The individual risk at the nearest residential property;
- Societal risk FN curves for members of the public; and,
- The Societal risk Expectation Value (EV) for members of the public.



The conclusions drawn from the results are as follows:

- Comparing the QRA results against land use planning criteria shows there are no incompatible land uses in any of the three LUP zones;
- The individual risk at the nearest residential property is negligible;
- The societal risk has not been calculated as none of the populated areas are in the scope of the risk curves;
- The Expectation Value for members of the public is 0, as no lethality is expected in the populated areas near to the site.

# 1 Introduction

## 1.1 Project Background

New Fortress Energy plans to construct a 600 MW power plant on Tarbert Ballylongford Landbank in the Kerry County Council Development Plan 2022-2028.

The STEP Power Plant consist of:

- A power plant, with different trains, with a total production capacity of 600 MW;
- Liquid fuel storage as power plant backup for production and the facilities needed to receive it;
- An above Ground Installation (AGI) accommodating valves and control equipment to receive the natural gas from pipeline; and,

## 1.2 Objectives and Scope

This QRA evaluates risk to personnel (on-site and off-site) in relation to the power plant, the AGI and the diesel storage unit. The QRA was conducted in accordance with HSA guidelines, focusing solely on land-use considerations.

## 1.3 Location and Surroundings

As stated above, STEP is planned for the south bank of the Shannon estuary between Tarbert and Ballylongford in County Kerry, Ireland; this location is shown in Figure 1 (marked in red).

The STEP is to be located on a circa 603-acre site on the Shannon Estuary at Ralappane, between Tarbert and Ballylongford in Co. Kerry and accessed off the existing L-1010 (Coast Road).

The *Kerry County Development Plan 2022-2028* has zoned the site 'Industry' as part of the Tarbert/Ballylongford Land Bank, and more specifically for marine related industry and compatible industries requiring deep water access.

Figure 2 provides an overview of the site.



The location offers the following:

- A large unoccupied landbank on the coast which is zoned for industrial purposes adjacent to the foreshore;
- Access to high-capacity gas transmission system that can receive up to 800 mmscf/d;
- The ability to get a high voltage export grid connection offer within the generation capacity shortfall time window<sup>1</sup>; and
- Access to high-capacity electricity grid (220 kV or higher) that can export 600 MW without undue system constraint.

## 1.4 Site Summary

### 1.4.1 Power Plant

The proposed Power Plant will comprise of:

- A flexible modular power plant design with up to three (3) blocks of Combined Cycle Gas Turbines (CCGT), each block with a capacity of circa 200 MW for a total installed capacity of up to 600 MW. The multishaft arrangement of the power plant provides fast acting response with very low minimum stable generation and is ideally suited to support increased intermittent renewable generation. Each block shall comprise of two (2) gas turbine generators, two (2) heat recovery steam generator and one (1) steam turbine generator and an air-cooled condenser.
- A 120 MW for 1 hour (120 MWhr) Battery Energy Storage System (BESS). Due to its very fast response, the BESS supports intermittent renewable generation.
- High voltage 220 kV Substation;
- Auxiliary Boiler, powered by natural gas;
- Raw water treatment building;
- Firewater storage tanks and fire water pumps;
- Fuel storage consisting of five diesel tanks, two holding tanks and 3 day tanks, with a total capacity of 16,000m<sup>3</sup><sup>2</sup>; and,
- Ancillary buildings.

### 1.4.2 AGI

The AGI will comprise of:

- Pig-trap (Bi-directional);
- Filtration;
- Fuel gas heaters/ heat exchangers and associated fuel gas skid;

---

<sup>1</sup> An application to connect to the national electrical transmission network via this 220 kV connection was submitted to EirGrid in September 2020. A Connection Agreement for a 600 MW Maximum Export Connection (MEC) was executed with EirGrid in 14th April 2023.

<sup>2</sup> While the total storage capacity of all the 5 tanks is 16,000 m<sup>3</sup>. Some are day tanks and are normally empty. Only 11,500 m<sup>3</sup> of distillate in total will be stored in the secondary fuel storage system. However, conservatively the QRA accounts for the maximum storage capacity of 16,000m<sup>3</sup>.

- Metering equipment located in a Metering Building;
- Gas pressure regulation system located in a Regulator Building;
- Gas chromatographs/ Chromatograph Building;
- Generator Kiosk; and
- Control and Instrumentation building.

## 1.5 Hazardous Substances

Hazardous substances present in the power plant were identified during the MATTE preparation. Materials subject to control under COMAH regulations identified are presented in Table 1.

**Table 1 Substances subject to control under COMAH regulations in the power plant**

Substance
Natural gas
Diesel
Transformer oil
Cleaning materials, laboratory chemicals and paints

The QRA focuses only on accidents involving hazardous substances in quantities that are expected to lead to offsite impacts, which, in the power plant, are natural gas and diesel. Consequently, the scope of the study is limited to areas where these substances are present. The following sections presents the properties and the hazards related to natural gas and diesel.

### 1.5.1 Properties of Natural Gas

Natural gas is a mixture of low molecular weight (typically  $\leq C_4$ ) hydrocarbons (predominantly methane), and in the present study it has been modelled as pure methane as only a very small fraction of the product stream will be heavier hydrocarbons. Physical properties for methane are provided in Table 2.

**Table 2 Properties of methane [6]**

Property	Value
Chemical Formula	CH <sub>4</sub>
CAS Number	74-82-8
Appearance at 20°C	Colourless Gas
Atmospheric Boiling Point (°C)	-161.5
Melting Point (°C)	-182.5
Liquid Specific Gravity	0.422
Vapour Density (air = 1)	0.55
Lower Flammable Limit (vol %)	5
Upper Flammable Limit (vol %)	15
Flash Point (°C)	-188

Property	Value
Auto Ignition Temperature (°C)	595
Long Term Exposure Limit	N/A
LD <sub>50</sub>	N/A
Eco-toxicity	Unlikely to cause adverse effects
Degradability	Disperses rapidly


### 1.5.2 Hazards of Natural Gas

The principal hazards of natural gas result from its:

- Flammability; and,
- vapour dispersion characteristics.

Natural gas is flammable when mixed in air at concentrations from 5 to 15% (volume basis).

The possible outcomes after a release of natural gas are a jet fire if an immediate ignition occurs and a flash fire or explosion if a delayed ignition occurs. These outcomes are shown in Figure 3.



**Figure 3 Event tree for a continuous release of a flammable gas (source: BEVI [3])**

The description of the possible outcomes is presented below.

#### Jet fire

If natural gas is released from storage tanks, piping or pressurized equipment, it will form a gas jet that entrains and mixes with the ambient air. If the material encounters an ignition source while it is within the flammable range, it may result in a jet fire. Such fires have the potential to cause severe damage, but associated consequences are highly dependent on the direction of release (i.e. not omni-directional).

#### Flash Fire

When natural gas is released to the atmosphere, a vapour cloud forms and disperses (mixing with air as it does so). If the resultant vapour cloud is ignited before the cloud is diluted below its LFL, a flash fire may occur. The combustion normally occurs within only portions of the vapour cloud (where mixed with air in flammable concentrations), rather



than the entire cloud. A flash fire may burn back to the release point, resulting in a jet fire but is unlikely to generate damaging overpressures (explode) when unconfined.

## Explosions

If some confinement is present when a natural gas vapour cloud ignites, it can produce damaging overpressures. Areas congested with equipment and structures can facilitate damaging overpressures if a vapour cloud is ignited within such an area. For example, if a vapour cloud infiltrates a process plant area with various vessels, structures, and piping and the cloud ignites, the portion of the cloud within that congested area may generate damaging overpressures.

If no ignition point is present, the flammable cloud will ultimately disperse with no effects.

### 1.5.3 Properties of Diesel

Diesel is used as an alternative fuel for the power plant. While it won't be used regularly, two separate tests will be conducted annually. Diesel fuel is defined as any liquid fuel suitable for use in diesel engines. It is derived from crude oil and primarily composed of heavy hydrocarbons (C8+).

Table 3 presents diesel properties according to the SDS provided by the supplier.

**Table 3 Properties of diesel**

Property	Value
CAS Number	64742-79-6
Appearance at 20°C	Bright yellow liquid
Atmospheric Boiling Point (°C)	172 to 379°C
Melting Point (°C)	-40 to 6°C
Liquid Density	0.8 to 0.9 g/cm <sup>3</sup>
Vapour Density (air = 1)	N/A
Lower Flammable Limit (vol %)	N/A
Upper Flammable Limit (vol %)	N/A
Flash Point (°C)	>56°C
Auto Ignition Temperature (°C)	224°C
LD <sub>50</sub> oral rat	>5000 mg/kg
Eco-toxicity	Toxic to aquatic life with long lasting effects

### 1.5.4 Hazards of Diesel

The Globally Harmonised System for the Classification and Labelling of Chemicals (GHS) classifies all diesel liquids as "Flammable Liquid Category 3". According to the SDS provided, the diesel used in the power plant has a flash point greater than 56°C.

Referring to the decision tree from the guide [2], (Figure 8.- Assignment of Ignition Category), diesel is categorized as an Ignition Category 3 substance, corresponding to an ignition probability of 0. However, for conservative considerations, a probability of ignition of 0.01 is assumed, a value aligned with Category 2 liquids.

The consequence following a loss of containment (LOC) of diesel will be a pool fire, confined or unconfined depending on the location of the release.

The guide provides a maximum surface emissive power (SEP) of heat radiated outwards per unit surface area of the flame from a pool fire of 130 kW/m<sup>2</sup>.



## 2 Facility Description

The QRA has considered hazards from natural gas and diesel associated with operation of:

- The AGI;
- The power generation Combined Cycle gas Turbine (CCGT) Plant; and,
- The diesel storage unit.

### 2.1 Above Ground Installation (AGI)

The AGI will accommodate the valves and control equipment to facilitate the connection to the already consented 26 km Shannon pipeline. It will facilitate the transportation of gas from GNI and will include fiscal metering and pressure control of the gas flow. The AGI is located in a separate compound within the Proposed Development site covering an area of approximately 11,282 m<sup>2</sup>.

The details provided on the AGI are based on information provided by Gas Networks Ireland (GNI) and will be typical of existing GNI AGIs on the national gas transmission network.

The AGI compound will be remotely operated and will normally be unmanned.

The proposed AGI general arrangement is shown in Appendix B.

### 2.2 Power Plant

The power plant will primarily operate using natural gas and will export generated power via the 220 kV connection to the national electricity grid. The usual fuel supply to the power plant will come from the gas grid through the Above Ground Installation (AGI). However, twice a year, the plant will conduct a diesel test utilizing the diesel stored in the tanks.

The proposed Power Plant general arrangement is shown in Appendix C.

### 2.3 Diesel Storage Unit

The Proposed Development also consists of secondary fuel storage and offloading which will supply distillate oil for a minimum of five continuous operating days (approximately 11,500 m<sup>3</sup>), as required by 'Secondary Fuel Obligations on Licensed Generation Capacity in the Republic of Ireland' (CER/09/001), issued by the Commission for Regulation of Utilities (CRU). This reserve will only be used in the event that the gas connection is unavailable and generation on the grid cannot meet demand. The total reserve consists of two storage tanks (~5,000 m<sup>3</sup> each) and three day-storage tanks (~2,000 m<sup>3</sup> each) with a combined capacity of approximately 16,000 m<sup>3</sup>. The layout of these tanks is shown in Appendix D.

Tertiary containment, bunding and associated pipework will be designed in accordance with EPA Guidance Note on Storage and Transfer of Materials for Scheduled Activities. The tanks will be located in a bunded area, which will allow for either 110% of the largest tank within the bund or 25% of the total volume of substance within the bund, whichever is the larger, in accordance with CIRIA C736, Containment systems for the prevention of pollution: Secondary, tertiary and other measures for industrial and commercial premises, (CIRIA, 2014). The distillate oil will be supplied to the Site by HGV tanker at an unloading station adjacent to the storage tanks, which will feed the distillate oil into one of the three day-tanks. Further details are provided in Appendix E (Appendix 2.5 of [6]).

Distillate Oil will be supplied to site by HGV tankers, which will connect to one of the three 2,000 m<sup>3</sup> storage tanks. It is not envisaged that distillate oil would not be used in the normal course of events other than for about three hours per annum for test firing. Containment arrangements to at the distillate tanker unloading area are as follows:

1. Distillate oil will be stored in fixed steel tanks (primary containment) which are located within impermeable bunded areas with weather protection (secondary containment sized to contain greater than 110% of the largest tank volume or 25% of the total stored substances). The tanks and bunds will be subject to a formal risk-based inspection programme conducted by specialist accredited contractors.
2. All drains at this tanker unloading area will pass through Class 1 hydrocarbon interceptors. The interceptors will collect any accidental spills of fuels or oils used in vehicles onsite. Spill kits will be located at strategic points around the Proposed Development to ensure a quick response to any spillages should they occur. Any used spill kits will be disposed of using a hazardous waste disposal contractor and in accordance with all relevant EU and Irish waste management legislation (i.e. the Waste Management Acts 1996-2011 and any regulations made thereunder, and the Waste Framework Directive).
3. A firewater retention pond is included in the establishment and sized according to the EPA Guidance on Retention Requirements for Firewater Runoff (2019). The retention pond will be rendered impermeable by use of an appropriate liner, and integrity-tested in line with the requirements of the Site's licence. All drainage from the tanker unloading area will pass through the retention pond. An automatic shut-off valve linked to the site's fire detection system will be installed on the drainage outlet point. This tertiary system could be used for the containment of any distillate that is not contained by the secondary containment system.
4. During distillate oil offloading operations, protective systems will be in place to prevent a loss of containment such as dry-break hose couplings and vehicle chocks to prevent 'drive-away' incidents.
5. The design equipment and pipework will be to industry codes and standards to reduce the potential for a loss of containment, including the use of welded connections to avoid potential leak sources (flanges).
6. Fuel pipework safety systems such as cathodic protection will be installed along with operational controls and monitoring.
7. Instrumentation and control systems will continuously monitor the process and leaks causing a loss of pressure would be rapidly detected.
8. Alarms, both audible and visual, would be raised in the event of a deviation from set points such as pressure levels, vessel levels, etc. alerting site operators.
9. During commissioning, when distillate oil will be introduced to the site, detailed method statements, plans and assessments will be produced to carry out these activities safely.
10. The Establishment will be operated and managed by experienced, highly trained personnel in accordance with all Regulatory requirements, including COMAH.
11. The design will be subject to numerous formal process safety studies to identify and mitigate hazards, such as Hazard and Operability (HAZOP) studies.

## 3 Overview of the QRA Methodology

### 3.1 Introduction

The COMAH Regulation 24 refers to the siting and development of new establishments. In this context, new establishments are expected to provide sufficient information to enable the Central Competent Authority (CCA) to apply the method outlined in the guidance [2]. Specifically, the individual location-based risk contours depicted in Figure 4 must be plotted on a map.



**Figure 4 Individual risk zones to be plotted on a map according to the guide [2]**

Four development types are defined, and each one is permitted or forbidden based on the zone where it is located and the risk contours outlined. The acceptance criteria are shown in Figure 5:

	Inner Zone (Zone 1)	Middle Zone (Zone 2)	Outer Zone (Zone 3)
Level 1	✓	✓	✓
Level 2	✗	✓	✓
Level 3	✗	✗	✓
Level 4	✗	✗	✗

**Figure 5 Development types allowed in each risk zone according to the guide [2]**

The definition of development types is presented in Appendix A.

Additionally, depending on the results, a societal risk evaluation may also be necessary.

### 3.2 Sectors

The guide [2] defines 13 different sectors, each of which with characteristic dangerous substances and types of major accidents. For each sector, a method of generating generic TLUP risk zones is elaborated. For complex sites, sector-specific approaches from the guide can be combined.

As the power plant is not specifically mentioned in the guide, a combination of scenarios from other sectors has been used (see Section 3.3).

### 3.3 Scenarios and Frequencies Definition

To define the scenarios to be calculated, all installations and equipment present in the power plant have been compared to those outlined in the guide. Subsequently, a selection based on their similarities has been made. All scenarios are defined to occur either in the power plant or in the storage unit.

The scenarios have been coded as follows: XX-YY-nn A/B... with:


- XX: the substance considered in the scenario, being NG for Natural Gas and DI for Diesel;
- YY: the location of the scenario, being AG the Aboveground Installation and PP the Power Plant (including the storage area);
- nn consecutive number to identify the scenario; and,
- A/B... to indicate that the scenario is repeated in identical equipment.

A complete list of the considered scenarios and their conditions is shown in Table 12.

#### 3.3.1 Scenarios in the AGI

In the AGI, the only dangerous substance considered is the natural gas.

Natural gas is fed to the AGI via a pipeline from out of the battery limit, enter a regulation station where the pressure is reduced from 98 bar to 45 bar and then exits the AGI towards the power plant. These 2 pipelines are presented in Figure 6 (in blue, the 98 bar pipeline and in red the 45 bar one).



**Figure 6 AGI natural gas pipelines**

Scenarios for natural gas aboveground pipelines are defined in table 40 of the guide [2] and are shown below in Table 4.

**Table 4 Scenarios for aboveground natural pipelines with D > 150 mm (Table 40 of the guide [2])**

LOC scenario	Frequency (m <sup>-1</sup> yr <sup>-1</sup> )	Event #, [2]
Pipeline rupture	1E-07	087
Pipeline leak of 0.1D (max 50 mm)	5E-07	088

The scenarios defined in the AGI are presented below in Table 5:

**Table 5 Scenarios defined in AGI**

Scn. ID	Description	Substance	Frequency (m <sup>-1</sup> yr <sup>-1</sup> )
NG-AG-01	Rupture of the natural gas pipeline	Natural gas	1E-07
NG-AG-02	Leak in the natural gas pipeline	Natural gas	5E-07
NG-AG-03	Rupture of the natural gas pipeline	Natural gas	1E-07
NG-AG-04	Leak in the natural gas pipeline	Natural gas	5E-07

### 3.3.2 Scenarios in the Power Plant

In the power plant, the only dangerous substance considered is the natural gas.

Natural gas is fed to the turbine via a pipeline. Scenarios for natural gas aboveground pipelines are defined in table 40 of the guide [2] and are shown in Table 4.

In addition, six scenarios considering a natural gas release in the turbine enclosure have been considered. Frequencies to be used are described in Table 64 of the guide [2] and are shown in Table 6.

**Table 6 Scenarios for process vessels (Table 64 of the guide [2])**

LOC scenario	Frequency (yr <sup>-1</sup> )	Event #, [2]
Instantaneous release	5E-06	181
Release over 10 minutes	1E-05	182
Release through a 10 mm pipe	5E-04	183

Risks associated with the steam drum were considered but, whilst the steam equipment presents a risk to personnel in the vicinity, there is no risk beyond the site boundary and no credible escalation scenarios were identified that could present a risk at the site boundary.

Risks due to the presence of the BESS are primarily related to its potential to cause a significant fire. However, this fire will be contained within the BESS building, and the probability of it escalating into a major accident affecting areas outside the site is discounted. Therefore, this scenario has not been calculated in the QRA.

The scenarios defined in the power plant are presented below in Table 5:

**Table 7 Scenarios defined in power plant**

Scn. ID	Description	Substance	Frequency
NG-PP-01	Rupture of the natural gas pipeline	Natural gas	1E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
NG-PP-02	Leak in the natural gas pipeline	Natural gas	5E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
NG-PP-03	Instantaneous release	Natural gas	5E-06 (yr <sup>-1</sup> )
NG-PP-04	Release over 10 minutes	Natural gas	1E-05 (yr <sup>-1</sup> )
NG-PP-05	Release through a 10 mm pipe	Natural gas	5E-04 (yr <sup>-1</sup> )

### 3.3.3 Scenarios in the Storage Unit

For the liquid fuel storage, scenarios are extracted from the “Flammable liquid storage installations” on chapter 3.6 of the guide [2]. As mentioned previously, diesel is categorized as a category 3 substance, for which no scenarios need to be described. However, as a conservative approach, the QRA will treat Diesel as a Category 2 substance.

Scenarios for diesel tanks are presented in Table 48 of the guide [2] and summarized in Table 8.

**Table 8 Scenarios for diesel tanks (Table 48 of the guide [2])**

LOC scenario	Leak Frequency (yr <sup>-1</sup> )	Ignition Probability	Consequence	Consequence Frequency (yr <sup>-1</sup> )	Event #, [2]
Instantaneous failure	5E-06	0.01	Pool Fire	5E-08	123
Failure over 10 minutes	5E-06	0.01	Pool Fire	5E-08	125
10 mm pipe leak over 30 minutes	1E-04	0.01	Pool Fire	1E-06	127
Overtop pool fire	-	-	Pool Fire	5E-08	--

There are five diesel tanks of two different types. There are two holding tanks (A and B) with an 18 m diameter and three day-tanks with a 13 m diameter. The corresponding scenarios for tanks are presented in Table 11.

The guide does not consider scenarios related to flammable liquid pipelines. Vysus recommends using the values from the BEVI [3]. The corresponding scenarios are shown below in Table 9:

**Table 9 Scenarios for aboveground pipelines (according to BEVI [3])**

LOC scenario	Frequency (m <sup>-1</sup> yr <sup>-1</sup> )		
	D < 75 mm	75 mm ≤ D ≤ 150 mm	D > 150 mm
Pipeline rupture	1E-06	3E-07	1E-07
Pipeline leak of 0.1D (max 50 mm)	5E-06	2E-06	5E-07

The transport of diesel to the power plant via pipeline is expected to be carried out twice a year when the power plant is run on diesel as a test, lasting just a few hours. A total pipeline operation time of 24 h per year has been initially considered. However, there may be an incipient problem that is not revealed whilst the pipeline is not in operation, leading to a leak when the pipe is in use; and therefore, the enabling factor of use is not considered. The corresponding scenarios for pipelines are presented in Table 11.

Diesel unloading operations are expected to be conducted very infrequently as the diesel is only maintained as a backup fuel and no consumption is foreseen. Considering the presence of trucks as once per year, with a total duration of the unloading operation of 12 h, frequencies for transport scenarios are presented in Table 10:

**Table 10 Scenarios for transport scenarios (according to BEVI [3])**

LOC scenario	Frequency (yr <sup>-1</sup> )	Trucks per year	Unloading duration (h)	Pool fire freq. (yr <sup>-1</sup> )
Instantaneous failure of the truck	1E-05	1	12	1.37E-08
Leak largest connection	5E-07	1	12	6.85E-10

Unloading operations from truck have not been considered in the QRA due to the fact that the risk is negligible compared to the minimum risk level to be considered from the guide [2] of 1E-07/y.

Summarizing, all scenarios proposed for the storage unit are presented below in Table 11:

**Table 11 Scenarios defined in the storage unit**

Scn. ID	Description	Substance	Frequency (m <sup>-1</sup> yr <sup>-1</sup> )
DI-PP-01A/B	Instantaneous release of the content of tanks A/B	Diesel	5E-06
DI-PP-02A/B	Failure over 10 minutes of tanks A/B	Diesel	5E-06
DI-PP-03A/B	10 mm pipe leak over 30 minutes from tanks A/B	Diesel	1E-04
DI-PP-04A/B	Overtop fire on tanks A/B	Diesel	5E-08

Scn. ID	Description	Substance	Frequency (m-1 yr-1)
DI-PP-05A/B/C	Instantaneous release of the content of day-tanks A/B/C	Diesel	5E-06
DI-PP-06A/B/C	Failure over 10 minutes of day-tanks A/B/C	Diesel	5E-06
DI-PP-07A/B/C	10 mm pipe leak over 30 minutes from day-tanks A/B/C	Diesel	1E-04
DI-PP-08A/B/C	Overtop fire on day-tanks A/B/C	Diesel	5E-08
DI-PP-09	Pipeline rupture	Diesel	1E-06
DI-PP-10	Pipeline leak of 0.1D (max 50 mm)	Diesel	5E-06

### 3.4 Consequence Analysis

The purpose of consequence analysis is to determine the potential outcome (or outcomes) of the various scenarios comprising the QRA. Consequence analysis may be broken down into the following steps:

- Source term modelling;
- Physical effects modelling; and,
- Impact modelling.

SAFETI performs these steps in a single model that automatically proceeds from one step to the next.

#### 3.4.1 Source Term Modelling

Source term modelling determines the behaviour of the material upon leakage, in terms of:

- Release rate and / or quantity;
- The velocity of the material;
- The phase of the material (liquid, gas / vapour or two-phase); and,
- The conditions within the material upon release (temperature, density, etc.).

Where the material forms a pool of liquid, it will also be necessary to model the pool spreading and rate of vaporisation of material from the pool. Where a bund (i.e. secondary containment) is provided, the potential size of the pool is limited to the size of the bund.

#### 3.4.2 Physical Effects Modelling

Modelling of physical effects predicts the behaviour of the material once it has been released, using the source term modelling results as inputs. The types of physical effects considered may include:

- Gas or vapour dispersion;
- Fire dimensions and heat output (for ignited releases of flammable material); and,
- Size and strength of explosions (for ignited flammable clouds in congested / confined regions).

Since some of the calculations performed can be quite complex, and the number of calculations required in a QRA study can be large, software packages are usually employed to perform the modelling.



### 3.4.3 Impact Modelling

Impact modelling evaluates the effect of different physical phenomena on receptors of interest (i.e. people, environmental features or assets, depending on the objectives of the study). In the present study, the parameters used for impact modelling are derived from the guide [2]. Specifically, the parameters related to flammable substances, given the absence of toxic substances in the STEP.

To estimate the fatal consequences of major accidents, established probit relationships for fatality are used; these are conservatively derived and help to ensure consistency in approach, resulting in a risk-based analysis that is robust and transparent. A range of consequences can be expected in a population exposed to an acute hazard (dose) which can be represented mathematically by a dose-response curve, with the number of people suffering fatal effects being the response.

Below are described the probit equations used in the QRA for estimating the consequences of specific types of major accident as detailed in the HSA guide [2].

#### 3.4.3.1 Consequences for thermal radiation

Thermal radiation exposure arises from fire-type events, with accidents that give rise to a thermal (heat) effect having a different impact on indoor and outdoor populations.

The thermal effect on people outdoors (i.e. directly exposed to the thermal radiation) is determined by the following probit equation from the HSA guide [2]:

$$Probit = -14.9 + 2.56 \cdot \ln(I^{1.33} \cdot t) \quad (1)$$

Where  $I$  is the incident heat flux in  $\text{kW/m}^2$  and  $t$  is the exposure duration in seconds. The recommended value for  $t$  is 60 seconds. Using this value, equation (1) gives the following fatality percentages at the heat flux levels shown in Figure 7.




**Figure 7 Heat flux and fatality levels, outdoor, for a 60s exposure**

For flash fires, the HSA guide [2] stipulates that a fatality rate of 100% is assumed inside the lower flammability limit (LFL) envelope, with 0% fatalities outside that envelope.

People inside buildings will have some protection from the effects of incident thermal radiation. The guide [2] stipulates the following values in Figure 8 for relevant thermal radiation thresholds.





**Figure 8 Heat flux levels relevant for people within buildings**

For flash fire, within the flash fire envelope, indoor fatality levels are conservatively assumed to be 10% in the HSA guide [2].


### 3.4.3.2 Consequences for explosion overpressure

The probit equation used for determining consequences from blast overpressure for personnel outside presented in the guide [2] is:

$$Probit = 1.47 + 1.35 \cdot \ln(P) \quad (2)$$

With P in psi.

This relationship applies only to people exposed to blast overpressure outdoors and gives the following in Figure 9 relationship between overpressure and fatality.



**Figure 9 Overpressure fatality thresholds for people outdoors**

As the plant constitutes an open and uncongested area, overpressure dissipates quickly and negligible effect at offsite buildings is expected, specially considering there are no buildings close to the site. Hence, overpressure over people indoors is not calculated.

## 3.5 Frequency Analysis

In general terms, frequency analysis is used to calculate:

- The likelihood of a given release of dangerous material occurring – this is usually expressed as a frequency (e.g. 1E-03 per year, or once in a thousand years);
- Given that a release has occurred, the probability that a given type of physical effect follows – for example, for releases of flammable material, the type of effect may depend on whether the material is ignited soon after the release begins, or at some time later; and,

- Given that a certain type of physical effects results, the probability of an undesired outcome – this may depend on the wind direction, the probability that a person is present within the hazard range, and the probability of successful emergency action.

Frequency analysis approaches fall into three categories:

- Use of relevant historical data;
- Use of analytical or simulation techniques (such as fault tree analysis or event tree analysis); and,
- Use of expert judgment.

In the present QRA, frequency values from the HSA guide [2] have been used in all scenarios for natural gas and diesel.

### 3.6 Risk Analysis

In simple terms, risk is the chance of an undesired outcome with the chance usually expressed as a frequency; the undesired outcome may be fatality, environmental damage or financial loss. In terms of risks to people, there are different types of risk outputs that may be calculated using QRA:

- Risk indices (such as Fatal Accident Rate);
- Individual risk usually expressed as the risk of harming a hypothetical person with a defined set of characteristics. Individual risk results may be expressed as a point value (the individual risk to a hypothetical person at a given geographical location), as a graph of individual risk versus distance (a risk transect) or as risk isocontours overlaid on a map;
- Societal risk, which expresses the frequency with which different numbers of people could be affected by an accident. It is usually presented as an 'FN curve', where F is the frequency with which N or more people are affected.

### 3.7 Risk Assessment

Once the risk analysis results have been obtained, it is necessary to assess their significance. This usually involves comparison of the results with risk acceptance criteria. The risk acceptance criteria used in this study corresponds to the criteria shown in Figure 4 (see Section 3.1).

## 4 Scenarios' Conditions

The following table summarizes the conditions considered when calculating the scenarios.

**Table 12 Scenario conditions**

Scn. ID	Description	Substance	Pipe diameter (mm)	Pipe length (m)	Vessel / Tank diameter (m)	Height / Length (m)	Temperature (°C)	Pressure (barg)
NG-AG-01	Rupture of the natural gas pipeline	Natural gas	750	250 <sup>(1)</sup>	--	--	Ambient	98
NG-AG-02	Leak in the natural gas pipeline	Natural gas	750	250 <sup>(1)</sup>	--	--	Ambient	98
NG-AG-03	Rupture of the natural gas pipeline	Natural gas	250	100 <sup>(1)</sup>	--	--	Ambient	45
NG-AG-04	Leak in the natural gas pipeline	Natural gas	250	100 <sup>(1)</sup>	--	--	Ambient	45
NG-PP-01	Rupture of the natural gas pipeline	Natural gas	250	872	--	--	Ambient	45
NG-PP-02	Leak in the natural gas pipeline	Natural gas	250	872	--	--	Ambient	45
NG-PP-03	Instantaneous release	Natural gas	--	--	--	--	Ambient	Atmospheric
NG-PP-04	Release over 10 minutes	Natural gas	--	--	--	--	Ambient	Atmospheric
NG-PP-05	Release through a 10 mm pipe	Natural gas	--	--	--	--	Ambient	Atmospheric
DI-PP-01A/B	Instantaneous release of the content of tanks A/B	Diesel	--	--	18	21	Ambient	Atmospheric
DI-PP-02A/B	Failure over 10 minutes of tanks A/B	Diesel	--	--	18	21	Ambient	Atmospheric
DI-PP-03A/B	10 mm pipe leak over 30 minutes from tanks A/B	Diesel	--	--	18	21	Ambient	Atmospheric
DI-PP-04A/B	Overtop fire on tanks A/B	Diesel	--	--	18	21	Ambient	Atmospheric
DI-PP-05A/B/C	Instantaneous release of the content of day tanks A/B/C	Diesel	--	--	13	15.5	Ambient	Atmospheric
DI-PP-06A/B/C	Failure over 10 minutes of day tanks A/B/C	Diesel	--	--	13	15.5	Ambient	Atmospheric
DI-PP-07A/B/C	10 mm pipe leak over 30 minutes from day tanks A/B/C	Diesel	--	--	13	15.5	Ambient	Atmospheric
DI-PP-08A/B/C	Overtop fire on day tanks A/B/C	Diesel	--	--	13	15.5	Ambient	Atmospheric
DI-PP-09	Pipeline rupture	Diesel	50	365	--	350	Ambient	10
DI-PP-10	Pipeline leak of 0.1D (max 50 mm)	Diesel	50	365	--	350	Ambient	10

(1) To account for possible pipe features such as bends or changes in direction, and to be more conservative (since the frequency is per meter) this estimated length has been multiplied by a factor of 2 in the final calculations.

## 5 Frequency Analysis

According to the scenario definition in chapter 3.3, Table 13 summarizes all scenarios considered and their frequencies. Conservatively, the potential duration of the effects of a release at the site boundary are not considered in land use planning, and therefore detection and isolation are not account for.

**Table 13 Summary of all scenarios considered in the QRA**

Scn. ID	Description	Substance	Frequency
NG-AG-01	Rupture of the natural gas pipeline	Natural gas	1E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
NG-AG-02	Leak in the natural gas pipeline	Natural gas	5E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
NG-AG-03	Rupture of the natural gas pipeline	Natural gas	1E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
NG-AG-04	Leak in the natural gas pipeline	Natural gas	5E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
NG-PP-01	Rupture of the natural gas pipeline	Natural gas	1E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
NG-PP-02	Leak in the natural gas pipeline	Natural gas	5E-07 (m <sup>-1</sup> yr <sup>-1</sup> )
DI-PP-01A/B	Instantaneous release of the content of tanks A/B	Diesel	5E-06 (yr <sup>-1</sup> )
DI-PP-02A/B	Failure over 10 minutes of tanks A/B	Diesel	5E-06 (yr <sup>-1</sup> )
DI-PP-03A/B	10 mm pipe leak over 30 minutes from tanks A/B	Diesel	1E-04 (yr <sup>-1</sup> )
DI-PP-04A/B	Overtop fire on tanks A/B	Diesel	5E-08 (yr <sup>-1</sup> )
DI-PP-05A/B/C	Instantaneous release of the content of day-tanks A/B/C	Diesel	5E-06 (yr <sup>-1</sup> )
DI-PP-06A/B/C	Failure over 10 minutes of day-tanks A/B/C	Diesel	5E-06 (yr <sup>-1</sup> )
DI-PP-07A/B/C	10 mm pipe leak over 30 minutes from day-tanks A/B/C	Diesel	1E-04 (yr <sup>-1</sup> )
DI-PP-08A/B/C	Overtop fire on day-tanks A/B/C	Diesel	5E-08 (yr <sup>-1</sup> )
DI-PP-09	Pipeline rupture	Diesel	1E-06 (m <sup>-1</sup> yr <sup>-1</sup> )
DI-PP-10	Pipeline leak of 0.1D (max 50 mm)	Diesel	5E-06 (m <sup>-1</sup> yr <sup>-1</sup> )

## 6 Ignition

Ignition probabilities to be used, according to the guide [2] are shown in Table 14.

**Table 14 Ignition Probability**

Substance	Immediate Ignition Probability	Delayed Ignition Probability	Source
Natural gas	0.09	0.91	Table 20 of the guide [2]
Diesel	0.01	0	

## 7 Consequence Modelling

### 7.1 Modelling Software

The Shannon Power Plant QRA has used the suite of models incorporated into the DNV SAFETI software (version 8.9). SAFETI is a comprehensive hazard and risk analysis software tool for all stages of design and operation.

SAFETI evaluates the progress of a potential incident from the initial release to far-field dispersion including modelling of pool spreading and evaporation, and flammable and toxic effects.

SAFETI contains models tailored for hazard analysis of offshore and onshore industrial installations. These include:

- Discharge and dispersion models, including a Unified Dispersion Model (UDM).
- Flammable models, including resulting radiation effects, for jet fires, pool fires and boiling liquid expanding vapour explosions (BLEVEs).
- Explosion models, to calculate overpressure and impulse effects.

### 7.2 Fluid Composition

As discussed in Section 1.5.1, releases from the natural gas pipeline are modelled as methane releases. Diesel releases are modelled as dodecane releases.

### 7.3 Operating Conditions

Operating conditions for each release scenario are provided in Section 4.

### 7.4 Effect of Bunding

Secondary fuel (distillate oil) will be stored with tertiary containment. Bunding and associated pipework will be designed in accordance with EPA Guidance Note on Storage and Transfer of Materials for Scheduled Activities. The secondary containment (primary bund) design will allow the greater of 110% of the largest tank within the bund or 25% of the total volume of substance within the bund, whichever is the larger. A second bund (tertiary containment) will be built around the primary bund and will contain any spillage should the primary bund fail or be overtopped by a spillage.

On this basis a release of diesel from the tanks is assumed to be confined within the dimensions of the bunded area containing the tanks (estimated to be 3,900 m<sup>2</sup>), meaning that the maximum surface area of a pool fire resulting from a release from the tanks is also taken to be 3,900 m<sup>2</sup>.

### 7.5 Effect of Topography

At the proposed location, when moving south from the riverbank, the terrain elevates to an approximate height of 30 metres before gradually descending. The Shannon facility will be constructed on 'plateaux' carved into the hillside descending toward the river.

It has been assumed that topography has minimal effect on dispersion of natural gas.

### 7.6 Releases onto Land and Water

As discussed in Section 7.4, the distillate oil tanks are provided with both a primary bund and a secondary bund, which are sufficiently sized to ensure that the entire inventory released would be contained within these bunds. The secondary bund ensures that the spill would still be contained even in the event of failure or overtop spillage of the the primary bund.

## 7.7 Dispersion Modelling

Dispersion of methane is dependent on several parameters, including: surface roughness, averaging time, material properties, wind speed and weather conditions. The weather data used in the study are discussed in Section 7.10.

Diesel releases will be contained within the bund around the tanks, with minimal gas flashing off.

## 7.8 Surface Roughness Parameter

Surface (terrain) roughness affects how quickly and how far a release may spread. The guide [2] gives the roughness lengths in Figure 10 for typical types of terrain. As recommended in [2] for general terrain without defining features, a surface roughness parameter of 0.1 has been used in this study for dispersion as recommended in the guide [2].

#	Short description of the terrain	Roughness length (m)
1	Open water (at least 5 km)	0.0002
2	Mud flats, snow; no vegetation, no obstacles	0.005
3	Open, flat terrain; grass, a few isolated objects	0.03
4	Low vegetation; large obstacles here and there, $x/h > 20$	0.10
5	High vegetation; distributed large obstacles, $15 < x/h < 20$	0.25
6	Park, bushes; many obstacles, $x/h < 15$	0.5
7	Strewn with large obstacles (suburb, wood)	1.0
8	Town centre with high-rise and low-rise buildings	3.0

Figure 10 Roughness lengths for given types of terrain

## 7.9 Averaging Time

When using gas dispersion models the 'averaging time' is a description of the time over which a gas concentration is averaged. At a particular point in space the concentration of a plume at equilibrium will vary for two reasons. Firstly, as the wind direction is not perfectly constant the plume will meander about a mean value. Secondly there are 'in-cloud' fluctuations due to the turbulence inherent in the atmosphere. As dispersion models aim to show a 'time averaged' concentration at a particular point, this average will depend on the length of time over which the concentration was 'sampled'. The situation is made more complicated because the different types of dispersion model assume different definitions of 'averaging time'.

The use of a short averaging time will maximise the recorded concentration at a given point, whereas a longer averaging time will give a lower value. This is because the use of a short averaging time captures the concentration 'peaks' at a location.

In this study an averaging time of 18.75 s has been used (this is the SAFETI default value for flammable gases).

## 7.10 Weather Data

Within a risk assessment, weather conditions are usually described as a combination of a letter with a number, such as 'F2'. The letter denotes the Pasquill stability class and the number gives the wind speed in metres per second.



The Pasquill stability classes describe the amount of turbulence present in the atmosphere and range from A to F. Stability class A corresponds to 'unstable' weather, with a high degree of atmospheric turbulence, as would be found on a bright sunny day. Stability class D describes 'neutral' conditions, corresponding to an overcast sky with moderate wind. A clear night with little wind would be considered to represent 'stable' conditions, denoted by stability class F.

Wind speeds range from light (1-2 m/s) through moderate (around 5 m/s) to strong (10 m/s or more). The probability of the wind blowing from a particular direction is commonly displayed graphically as a 'wind rose'.

According to the guide [2], dispersion should be modelled in D5 and F2 conditions, with a temperature of 15°C used in D5 conditions and 10°C for F2 conditions.

However, the wind directionality distribution is not given in the guide [2]. Therefore, nearest weather data is used to derive the directionality distribution probabilities. Shannon Airport is the nearest weather station, located 35 km away from the site, near Ballylongford, and is therefore the most representative data source to be used in the QRA.

A detailed analysis of the weather data during day and night has been performed for this study.

The fraction of time considered to be 'day' was calculated by assigning day and night hours to different months of the year, then calculating the number of daytime hours. Note that 'day' and 'night' were defined according to hypothetical resident behaviour (i.e. on when people may typically get up and go to bed, and not sunrise and sunset). Within the weather calculation, this has been defined as a 14 hour period during summer (defined as the period from April to the end of October, when daylight saving time operates) from 07:00 GMT (06:00 DST) until 21:00 GMT (20:00 DST); and a 12 hour period during winter (all months not defined as summer) from 06:00 GMT to 18:00 GMT.

The data were then processed to obtain wind direction probabilities (i.e. 'wind rose' data) and the proportion of time for which D5 and F2 weather conditions occurred. As part of this analysis combinations of stability and wind speed that are not F2 or D5 are grouped together and included in the F2 and D5 distribution. i.e. Stability Classes A, B, C and D are grouped together as D5, Stability classes E, F and G are grouped together as F2.

The guide [2] established that D5 conditions are assumed to occur 80% of the time and F2 conditions occurring for the remaining 20%. In the QRA this relation is maintained.

Wind roses for day and night conditions are shown in Table 15 and Table 16.

Table 15 Wind Rose for Day

Stability Class	Wind Sector															
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	WSW	WNW	NW	NNW
D5	0.037859	0.03706	0.02175	0.04749	0.11664	0.11708	0.06808	0.09121	0.19493	0.11961	0.06769	0.05836	0.03786	0.03706	0.02175	0.04749
F2	0.000843	0.00142	0.00062	0.00053	0.00155	0.00160	0.00089	0.00102	0.00355	0.00453	0.00311	0.00257	0.00084	0.00142	0.00062	0.00053

Table 16 Wind Rose for Night

Stability Class	Wind Sector															
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	WSW	WNW	NW	NNW
D5	0.01189	0.02006	0.01574	0.03758	0.08888	0.10377	0.05797	0.06342	0.11833	0.06567	0.02781	0.02335	0.01189	0.02006	0.01574	0.03758
F2	0.02598	0.02509	0.01682	0.01978	0.03782	0.02659	0.02034	0.02335	0.04148	0.04186	0.04214	0.04434	0.02598	0.02509	0.01682	0.01978

## 8 Populations

Onsite personnel and off site population numbers used in the assessment are described below.

### 8.1 Offsite Populations

In the event of a major accident, the likelihood of harm to a person indoors differs from that for a person outdoors (see section 3.4). Therefore, it is common practice for QRA studies to consider the proportion of time individuals may spend indoors and outdoors.

To account for time spent indoors and outdoors, the previous QRA study [8] employed the concept of a 'hypothetical house resident' originally developed by the UK HSE [9]. The hypothetical house resident is present all of the time at their dwelling, spending 90% of their time indoors during the day and 99% of their time indoors at night.

In accordance with the guide [2], it is assumed that people are indoors 90% of the time. While this value is considered very conservative, it has been utilized as indicated in the guide. However, an exception is the population in the Money Point Power Station, as this is an industrial site and therefore a higher proportion of time spent outdoors (i.e. more exposed to risk) is assumed. In this case, the estimation from the previous QRA is applied.

The offsite populations used are sourced from various references. Data in **bold** is acquired from reports from The Central statistics Office [11] and correspond with data from the 2022 census. Data for individual residences and the Money Point Power Station are taken from the QRA for the site undertaken in 2013 [10].

**Table 17 Offsite Populations**

Area / Location	No. People	Fraction indoor Day	Fraction Indoor Night
Individual residences within 2 km	4 per residence	0.9	0.9
<b>Ballylongford</b>	<b>415</b>	0.9	0.9
<b>Tarbert</b>	<b>546</b>	0.9	0.9
<b>Kilrush</b>	<b>2649</b>	0.9	0.9
Money Point Power Station	313	0.5	0.7

### 8.2 Onsite Personnel

The objective of the methodology described in the guidelines [2] relates to TLUP advice, which is external to the establishment and is future oriented: the assessment methods presented are not sufficiently detailed to address risk to on-site populations and should not be used for that purpose.

## 9 Risk Criteria

### 9.1 Individual Risk

The current HSA criteria [2] are stated in terms of risk of fatality. Use of probit equations is prescribed for calculation of the probability of fatality given exposure to a dose of a harmful agent (such as thermal radiation, overpressure or toxic gas).

The land use planning zone boundaries in the HSA guidance [2] are presented in Figure 4 (see Section 3.1) and defined as:

- Zone 1 (inner): within the 1E-05/y individual risk of fatality contour;
- Zone 2 (middle): between the 1E-05/y and 1E-06/y individual risk of fatality contours; and,
- Zone 3 (outer): between the 1E-06/y and 1E-07/y individual risk of fatality contours.

The criteria for new establishments found in the HSA guidance [2] are:

- The maximum tolerable risk to a member of the public should not exceed 1E-06/y; and,
- The maximum tolerable risk to a person at an off-site work location should not exceed 5E-06/y.

Land uses are assigned to one of four 'Sensitivity Levels' as summarised in Appendix A.

### 9.2 Expectation Value (EV)

The EV is the calculated number of fatalities per year, multiplying the number of expected fatalities by the frequency in chance in a million years (cpm). For example, a major accident that could result in 120 fatalities with a frequency of occurrence of 1 cpm would have an EV of:

$$EV = 120 * 1 = 120 \quad (3)$$


According to the HSA guidance, the total off-site EV should not exceed the criterion upper limit of 10,000. Between EVs of 100 and 10,000, it should be demonstrated that all practicable efforts have been made to reduce the risk to a level that is as low as reasonably practicable. Above a developmental EV level of 450, an FN curve will be required as part of the demonstration. Where the EV exceeds 10,000, the TLUP advice to the planning authority will always be 'Advice against'.

### 9.3 Societal Risk – FN Curve

When the risk of multiple fatalities from an accident should be taken into account more explicitly, the societal risk must be determined. Societal risk results are commonly presented as an 'FN' curve, which shows the cumulative frequency with which N or more fatalities are experienced.

HSE2001 [12] provides an upper limit value for an intolerable societal risk criterion: for a predicted accident occurring no more frequently than once in 5,000 years, there should be no more than 50 fatalities. This has gained international acceptance as an anchor point for a line (of slope -1) to create an intolerable societal risk criterion for single accidents. The HSA document [5] recommended using points at (200 cpm / 50 fatalities) and (1,000 cpm/10 fatalities) to create that line. An acceptable societal risk single risk criterion line can then be drawn at frequencies that are two orders of magnitude below the intolerable line (so a frequency of 1E-04 on the intolerable line becomes 1E-06 on the acceptable line). The risk criterion lines are shown in Figure 11.

Between the two lines, operators and potential operators will be required to demonstrate that, in relation to proposed changes, all reasonable efforts have been made to reduce the risk to a level that is as low as reasonably practicable.



**Figure 11 HSA Upper and lower societal risk criterion (log scale)**

## 10 Risk Calculation Results

Individual risk of fatality and societal risk have been calculated using the DNV Safeti software (version 8.9) and results are presented in the following sections.

### 10.1 Consequence results

Consequence results for the studied scenarios is presented in below in Table 18.


**Table 18 Scenario results**

Scn. ID	Description	Effect	Distance to 1% lethality due to radiation [m]
NG-AG-01	Rupture of the natural gas pipeline	Jet Fire	270
NG-AG-02	Leak in the natural gas pipeline	Jet Fire	85
NG-AG-03	Rupture of the natural gas pipeline	Jet Fire	80
NG-AG-04	Leak in the natural gas pipeline	Jet Fire	25
NG-PP-01	Rupture of the natural gas pipeline	Jet Fire	70
NG-PP-02	Leak in the natural gas pipeline	Jet Fire	30
NG-PP-03	Instantaneous release	Jet Fire	90
NG-PP-04	Release over 10 minutes	Jet Fire	90
NG-PP-05	Release through a 10 mm pipe	Jet Fire	10
DI-PP-01A/B	Instantaneous release of the content of tanks A/B	Pool Fire	75
DI-PP-02A/B	Failure over 10 minutes of tanks A/B	Pool Fire	65
DI-PP-03A/B	10 mm pipe leak over 30 minutes from tanks A/B	Pool Fire	40
DI-PP-04A/B	Overtop fire on tanks A/B	Pool Fire	No det
DI-PP-05A/B/C	Instantaneous release of the content of day tanks A/B/C	Pool Fire	75
DI-PP-06A/B/C	Failure over 10 minutes of day tanks A/B/C	Pool Fire	65
DI-PP-07A/B/C	10 mm pipe leak over 30 minutes from day tanks A/B/C	Pool Fire	40
DI-PP-08A/B/C	Overtop fire on day tanks A/B/C	Pool Fire	No det
DI-PP-09	Pipeline rupture	Pool Fire	30
DI-PP-10	Pipeline leak of 0.1D (max 50 mm)	Pool Fire	30


### 10.2 Individual Risk

The individual risk contours for people outdoors in the area are presented in Figure 12 and contours for people indoors are presented in Figure 13. The yellow line defines the COMAH site boundary.





**Figure 12 Outdoors Individual Risk Contours**



**Figure 13 Indoors Individual Risk Contours**

The criteria for new establishments found in the HSA guidance [2] are:


- The maximum tolerable risk to a member of the public should not exceed 1E-06/y; and,
- The maximum tolerable risk to a person at an off-site work location should not exceed 5E-06/y.



As it can be seen in the previous figures, in both cases, indoors and outdoors, the risk curve corresponding to  $1\text{E-}06/\text{y}$  is contained in the site perimeter, not affecting members of the public or personnel at an off-site work location and **the criteria for individual risk are met.**

### 10.3 Expectation Value and Societal Risk

To determine the expectation value (EV) and societal risk, the population potentially affected by the risk from the plant has to be evaluated. For this purpose, the risk curve corresponding to  $1\text{E-}09/\text{y}$  has been selected which serves as a conservative measure to define the affected population. It's worth noting that the guide [2] does not impose any limitations beyond  $1\text{E-}07/\text{y}$ . Figure 14 shows the  $1\text{E-}09/\text{y}$  curve overlaid over a map with residential properties identified in purple and the COMAH site boundary in yellow.



**Figure 14 Affected population**

From Figure 14 it can be seen that there is no population that is within the  $1\text{E-}09/\text{y}$  per year risk level. Therefore, the EV is 0, and hence an FN curve is not required **and the societal risk criteria is met.**



## 11 Conclusions

A comprehensive quantitative risk assessment (QRA) of the proposed STEP has been performed. The analysis has been conducted in accordance with the current HSA guidance [2] and it does not constitute a full QRA of the risks to onsite personnel. It is intended for land use and permitting purposes only.

The following results have been obtained:

- Individual risk of fatality contours;
- The individual risk at the nearest residential property;
- Societal risk FN curves; and,
- Societal risk Expectation Values (EVs).

The results for the STEP project presented above have been compared with the HSA's risk criteria presented in Section 9.1.

The conclusions drawn from the results are as follows:

- Comparing the QRA results against land use planning criteria shows there are no incompatible land uses in any of the three LUP zones;
- The individual risk at the nearest residential property is negligible;
- The Expectation Value for members of the public is 0, as no lethality is expected in the populated areas near to the site. And hence no societal risk FN curve is required.

**In conclusion, the risk criteria set by the HSA for new establishments (see section 9) have been met.**


## 12 References

- [1] Directive 2012/18/EU of the European Parliament and of the Council of 4 July 2012 on the control of major-accident hazards involving dangerous substances, amending and subsequently repealing Council Directive 96/82/EC, Official Journal of the European Union, 24 July 2012.
- [2] Guidance on technical land-use planning advice. For planning authorities and COMAH establishment operators. HSA, version 2, February 2023.
- [3] RIVM (2009). Reference Manual BEVI Risk Assessments. Version 3.2.
- [4] Chemicals Act (Control of Major Accident Hazards Involving Dangerous Substances) Regulations 2015. SI No. 209 of 2015.
- [5] HSA (2010). Policy and Approach of the Health and Safety Authority to COMAH Risk-based Land-use Planning.
- [6] Shannon Technology and Energy Park Environmental Impact Assessment Report, AECOM.
- [7] Hazardous Chemicals Data Book, Second Edition 1986. G. Weiss
- [8] ERM (2007). Land Use Planning QRA Studies of the Proposed Shannon LNG Terminal. Report 0059890-R02 Issue 1.
- [9] HSE (1989). Risk criteria for land use planning in the vicinity of major industrial hazards. HMSO Books C30.
- [10] Land -Use Planning QRA of Alterations to Shannon LNG Terminal and addition of a CHP Plant. Scandpower Risk Management. Lloyd's Register. Report No 50102216 R01 Rev 03. 6/3/2013.
- [11] An Phiromh Staidrimh; Census - CSO - Central Statistics Office
- [12] Reducing risks, protecting people: HSE's decision-making process, HSE Books, 2001.

---

# Appendix A. Description of Development Types According to the Guide [2]

In the guidance [2], four levels of development are defined as presented in Figure 15:



**Figure 15 Levels of development according to the guide [2]**

The more detailed description of these development levels is presented in the Appendix 2 of the guide [2] and shown next.

---

# Appendix B. Above Ground Installation General Arrangement

---

# Appendix C. Power Plant General Arrangement

---

# Appendix D. Tanks Layout

---

# Appendix E. Hazardous and Noxious Substances Spill Plan

## **Appendix 2: MATTE for Power Plant Rev 03**






Report for:	Shannon LNG Limited
Report reference:	RMC0500653.1.4
Date:	26 July 2024
Revision:	03



# MATTE assessment for Shannon Technology Energy Park Power Plant

Report prepared for Shannon LNG Limited

# Report Information

MATTE assessment for Shannon Technology Energy Park Power Plant		
<b>Report reference:</b> RMC0500653.1.4	<b>Date:</b> 26 July 2024	<b>Revision:</b> 03
<b>Prepared by:</b> Neil Rimmer Principal Consultant	<b>Reviewed by:</b> Adam Baxter Principal Consultant	<b>Approved by:</b> Adam Baxter Department Manager, UK & Spain
		
<b>Client contact:</b> Kieran O'Connor Permit, Regulatory and Environmental Lead T/M: +353 87 1464 794 koconnor@newfortressenergy.com	<b>Client entity and address:</b> Shannon LNG Limited 27 Market Street, Listowel Co. Kerry, V31 Y436 Ireland	
<b>Vysus Group contact:</b> Mireia Amigó Senior Consultant  T: + 34 936097131 M: + 34 676639206 mireia.amigo@vysusgroup.com	<b>Vysus Group entity and address:</b> Vysus UK Limited Regus Manchester Business Park 3000 Aviator Road Manchester, M22 5TG United Kingdom	

**Document control (Vysus Group internal use):**

Revision	Prepared by	Reviewed by	Approved by	Date	Comments
00	DIT	CJS	AB	20 Mar 2024	Issued to client
01	DIT	CJS	AB	09 Apr 2024	Revised accounting for client comments
02	DIT	CJS	AB	10 Apr 2024	Revised accounting for client comments
03	NR	AB	AB	26 July 2024	Revised accounting for HSA comments

Vysus Group and variants of it are trading names of Vysus Group Holdings Limited, its subsidiaries and affiliates. Vysus Group Holdings Limited is a limited company registered in England and Wales, registered number 12912998. Registered office: Suite C, 105 Piccadilly, London, W1J 7NJ.

Vysus Group Holdings Limited, its subsidiaries and affiliates and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Vysus Group'. Vysus UK Limited is a member of Vysus Group.

Vysus Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Vysus Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This document includes personal data as defined by the General Data Protection Regulation (EU2016/679) ('Regulation'), and you (client) are obliged to process this data in accordance with the Regulation. This personal data is not to be disclosed to any other party outside the client group and not used for other purpose other than in connection with this project. No personal data is to be transferred outside the country of receipt.

Except as permitted under current legislation no part of this work may be photocopied, stored in a retrieval system, published, performed in public, adapted, broadcast, transmitted, recorded or reproduced in any form or by any means, without the prior permission of the copyright owner.

Enquiries should be addressed to Vysus Group, Proserv House, Prospect Road, Arnhall Business Park, Westhill, AB32 6FJ. © 2024 Vysus Group

---

# Table of Contents

1.1	Location of proposed development.....	8
1.2	Key features of the proposed development .....	8
3.1	Exclusions to the scope .....	11
4.1	MATTE definitions and thresholds .....	12
4.2	MATTE Scenarios .....	13
4.3	Compliance requirements .....	13
4.3.1	COMAH.....	13
4.3.2	Land use planning .....	13
4.3.3	Assessment expectations .....	13
5.1	Sources .....	16
5.2	Pathways.....	16
5.3	Receptors.....	17
6.1	Site setting and operation .....	18
6.2	Major accidents and disasters .....	18
6.3	Major accident scenarios .....	18
7.1	Sources .....	20
7.2	Pathways.....	23
7.2.1	Drainage systems on site .....	23
7.2.2	Releases into Bunded Areas .....	23
7.2.3	Releases in the Power Plant Area .....	24
7.2.4	Releases to the Storm Water Drain System.....	24
7.2.5	Releases to Ground/Ground Water from permeable areas.....	24
7.2.6	Releases into Storage Buildings/Warehouses .....	24
7.2.7	Releases at the AGI Area .....	24
7.2.8	Fires .....	25
7.3	Receptors.....	27
7.4	COMAH materials .....	29
7.4.1	Natural gas.....	29
7.4.2	Ammonia Hydroxide .....	29
7.4.3	Diesel .....	29
7.4.4	Transformer Oil .....	31
7.5	Non-COMAH Materials .....	31
7.5.1	Tri-sodium Phosphate.....	32
7.5.2	Sodium Bisulphite .....	32
7.5.3	Sulphuric Acid .....	32

7.5.4	Cleaning Chemicals, Laboratory Chemicals and Paints .....	33
7.5.5	Storage Building Fires .....	33
7.6	MATTE risk evaluation .....	33
7.7	MATTE assessment summary .....	35

---

## List of Figures

Figure 1.	Site location .....	8
Figure 2.	Impression of proposed Power Plant only development and 120MW – 1 hr Battery Storage System.....	9
Figure 3.	A framework for environmental risk assessment and management. ....	15
Figure 4.	Proposed Site Drainage .....	26
Figure 5.	Proposed Development Site .....	27
Figure 6.	Proposed National Heritage Areas (NHA) .....	28
Figure 7.	SPA and SAC.....	28

---

## List of Tables

Table 1.	Example, source, pathway, receptor linkage concept [5].....	16
Table 2.	Materials and Inventory .....	20
Table 3.	Material Classification and Ecotoxicity .....	21
Table 4.	MATTE Sources for the Power Plant only design. ....	33
Table 5.	Review of Environmental Impacts .....	34
Table 6.	MATTE potential for the Power Plant only design.....	36
Table 7.	MATTE assessment summary .....	37

---

# List of Abbreviations

ABP	An Bord Pleanála (Planning Authority)
AGI	Above Ground Installation (Operated by Gas Networks Ireland)
AONB	Areas of outstanding natural beauty
ALARP	As Low As Reasonably Practicable
CA	Competent Authority
CCGT	Combined Cycle Gas Turbine
CDOIF	Chemical and Downstream Oil Industries Forum
COMAH	Control of Major Accident Hazards
CRU	Commission for Regulation of Utilities
DAU	Development Applications Unit
DEFRA	Department for Environment, Food and Rural Affairs
EPA	Environmental Protection Agency
ESA	Environmentally Sensitive Area
HSA	Health and Safety Authority
kV	Kilo Volt
LNR	Local Nature Reserves
LUP	Land use planning
MAPP	Major Accident Prevention Policy
MATTE	Major Accident to the Environment
MW	Mega Watt
NHA	Natural Heritage Area
NSA	Nitrate Sensitive Areas
QRA	Quantitative risk assessment
SAC	Special Area of Conservation
SPA	Special Protection Area
SPR	Source, Pathway, Receptor
SSSI	Site of Special Scientific Interest
STEP	Shannon Technology Enterprise Park

---

# Executive Summary

This report has been prepared for Shannon LNG Limited by Vysus Group. The report documents the findings of a MATTE (Major Accidents to the Environment) study for the proposed Shannon Technology Enterprise Park (STEP) power plant.

## Purpose

The purpose of the MATTE study is to identify potential scenarios associated with Major Accidents for the proposed STEP power plant involving dangerous substances which can pose a credible threat of damage to the environment, as defined and governed by COMAH Regulations.

## Scope

The scope for this MATTE study is the Power Plant Only development (ABP-311233-21).

The report does not address Major accident scenarios which can give rise to serious injury to people; routine environmental emissions associated with the operation of the installation, and connection to gas supply via pipeline.

## Methodology

The MATTE study was conducted as a desk study using the HSA Guidance on technical land-use planning advice for planning authorities and COMAH establishment operators, also taking into account HSA Guidance to Inspectors on the Assessment of Safety Reports under the COMAH Regulations 2015, DEFRA Guidelines for Environmental Risk Management, the COMAH regulations and the Chemical and Downstream Oil Industries Forum (CDOIF).

As per the HSA Guidance, the basic approach was to apply the Source, Pathway, Receptor methodology to identify hazards and assess any residual environmental risk (MATTE) associated with a major accident.

## Findings

The findings of the MATTE assessment are summarised in the table below.

Material	Potential MATTE?	Evaluation	MATTE Risk
Diesel	Yes	The proposed 11,500 m <sup>3</sup> diesel stored on site falls within the Qualifying quantity (>2,500 tonnes) of dangerous substances as referred to in the COMAH Regulations, but the low likelihood of a release occurring combined with the tertiary containment system means that it is very unlikely for a release to occur resulting in the material entering the estuary (pathway).	Low
Transformer oil	Yes	Transformer oil may be hazardous to the environment depending on its chemical composition and a significant release to the estuary could result in a MATTE. Measures on site would prevent the material entering the estuary (pathway)	Very low

Material	Potential MATTE?	Evaluation	MATTE Risk
Firefighting Water	Yes	Firefighting the water may be contaminated with materials that are toxic to the environment and, as such, a release of a large quantity of firefighting water into the Shannon estuary may lead to a MATTE. Measures on site would prevent the material entering the estuary (pathway)	Very low
Natural Gas	No	There is no MATTE associated with the natural gas used on the facility as it does not have any liquid constituents.	N/A Not a MATTE
Ammonia Hydroxide	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Tri-Sodium Phosphate	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Sodium Bisulphite	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Sulphuric acid	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Cleaning materials, laboratory chemicals and paints	No	Materials may be harmful to the environment but only present in small quantities with low possibility of entering the marine environment.	N/A Not a MATTE

All of the identified MATTE events are described as low or very low risk, as the likelihood of a release occurring is low and measures for prevention of discharge to the estuary are present within the plant design and operating philosophy.

It is noted that the risks associated with the facility are in accordance with HSA criteria.

# 1 Introduction

This report has been prepared for Shannon LNG Limited by Vysus Group. The report documents the findings of a MATTE (Major Accidents to the Environment) study for the proposed Shannon Technology Enterprise Park (STEP) power plant.

This study has been performed in accordance with HSA Guidance on technical land-use planning advice for planning authorities and COMAH establishment operators [1] and HSA Guidance to Inspectors on the Assessment of Safety Reports under the COMAH Regulations 2015 [2].

## 1.1 Location of proposed development

The Proposed Development site is located approximately 4.5 km and 3.5 km from Tarbert and Ballylongford in Co. Kerry, respectively.

The Proposed Development site is located within the boundary of two townlands: Kilcolgan Lower and Ralappane, Co. Kerry.

- 450 acres of land zoned for marine and industrial development by local and regional development plans (600 total acres)
- Proximity to high-capacity gas and electricity networks
- 220 kV electrical connection at substation 5 km to East
- Successful in recent ECP 2.1 electrical grid connection process



**Figure 1. Site location**

Within the wider area, energy infrastructure is a significant feature of the landscape. Moneypoint power station lies approx. 2.5 km north of the site in Co. Clare, while Tarbert power station lies approx. 4 km east of the site. Kilpaddoge 220 kV substation lies approx. 3 km to the east of the site, to which a number of high voltage overhead lines are connected. Wind energy projects within both Co. Clare and Co. Kerry form part of the background to views in this area. There are a number of designated conservation sites located in the vicinity including:

- Lower Shannon candidate Special Area of Conservation (SAC), 002165.
- Shannon-Fergus Estuary Special Protection Area (SPA), 00407
- Ballylongford Bay proposed Natural Heritage Area (pNHA), 1332.

## 1.2 Key features of the proposed development

The key features of the Power Plant only development comprise:

- Three (3) blocks of CCGT facilitating a flexible multi-shaft power plant. Each block up to 200 MW for a total capacity of up to 600 MW.
- Each block comprises of two (2) gas turbine generators, two (2) heat recovery steam generator and a steam turbine generator.



- Cooled by means of air-cooled steam condensers.
- A 120 MW for 1-hour (120 MWh) battery storage facility
- High voltage 220 kV Substation
- Raw water treatment building
- Firewater storage tanks and fire water pumps
- Under the CRU's Decision Paper CER/09/001 5 days continuous Secondary Fuel storage will be stored on site, equating to approximately 11,000 cubic metres.
- The 220 kV cable(s) will run 5 km east under the L-1010 road to the Eirgrid Killpaddockue 220 kV substation.



**Figure 2. Impression of proposed Power Plant only development and 120MW – 1 hr Battery Storage System.**

## 2 Purpose

The purpose of the MATTE study is to identify potential scenarios associated with Major Accidents for the proposed STEP power plant involving dangerous substances which can pose a credible threat of damage to the environment, as defined and governed by COMAH Regulations.

## 3 Scope

This MATTE study is concerned with credible MATTE Scenarios associated with a Major Accident, as defined by COMAH regulations [3] and industry guidance [1], [2], [4], [5], for the Power Plant Only development (ABP-311233-21).

The scope of the proposed Power Plant considered in this MATTE study includes:

- Site access point and main administration building
- Process building, Electrical substations, security building, Maintenance / warehouse and equipment building
- Power plant
- Secondary diesel fuel storage for the power plant (11,500 m<sup>3</sup>, equivalent to approximately 10,000 tonnes)
- AGI
- Construction laydown
- Battery storage facility
- Drainage outfall pipe
- Fire water retention pond

### 3.1 Exclusions to the scope

Major accidents scenarios which can give rise to serious injury to people are addressed separately in a dedicated QRA report.

Routine environmental emissions associated with the operation of an establishment are a matter for the local authority or the Environmental Protection Agency (EPA), as relevant, and are subject to separate permitting/licensing requirements. Routine emissions are not considered within the scope of this report.

## 4 Governing regulations and definitions

HSA Guidance on technical land-use planning advice for planning authorities and COMAH establishment operators [1] considers that in addition to assessment of risk to human health, there is also a requirement to assess risks to the environment by applying the source-pathway-receptor model.

[1] interprets Health and Safety Authority (HSA) policy on technical land-use planning (TLUP) advice under the Seveso-III Directive (Directive 2012/18/EU of the European Parliament and of the Council of 4 July 2012 on the control of major-accident hazards involving dangerous substances, amending and subsequently repealing Council Directive 96/82/EC), as implemented by the COMAH Regulations 2015 (Chemicals Act (Control of Major Accident Hazards involving Dangerous Substances) Regulations 2015, S.I. No. 209 of 2015, the “COMAH Regulations” [3]).

The COMAH Regulations implement the Seveso III Directive (2012/18/EU) [6].

### 4.1 MATTE definitions and thresholds

As neither the regulations nor the Directive define the term MATTE. The Competent Body refer to the HSA Guidance on technical land-use planning advice for planning authorities and COMAH establishment operators and the Guidance to Inspectors on the Assessment of Safety Reports under the COMAH Regulations 2015 Rev 4 Jan 2017, which specify the CDOIF guidance [4] which defines the term.

The term MATTE is used by industry and the Competent Authorities (CAs) to indicate when a major accident has caused serious harm to the environment (or when it has potential to do so):

- a Major Accident which could cause serious harm to the environment (i.e. lead to serious danger) is a potential MATTE (i.e. a Major Accident with MATTE potential);
- a Major Accident which has caused serious harm to the environment is a MATTE.

In accordance with the definitions for of a MATTE and a Major Accident, a MATTE would be taken to require harm or damage to the environment above defined thresholds when considering key environmental receptors in relation to a designated area.

MATTE thresholds defined in the CDOIF guidance concern [4]:

- Extent and Severity; and
- Duration of harm

Designated areas and potential receptors considered within the CDOIF definitions concern [4]:

- Nationally important: SSSI and National Nature Reserves
- Internationally important: SACs, SPAs & Ramsar sites
- Other designated land (ESA's, AONB's LNRs, NSA's etc.)
- Scarce habitat
- Widespread habitat (land/water)
- Groundwater
- Soil or sediment (land/water)
- Built environment (land, man-made)
- Particular species (land, water, air)
- Marine (water)
- Freshwater and estuarine habitats (water)

## 4.2 MATTE Scenarios

MATTEs are most frequently due to liquid releases (including firewater) impacting on land and water. The prevention measures of most relevance to environmental protection are those which reduce the risk of accidental liquid releases or enable their retention on site [1].

MATTE incidents caused by aerial dispersion are less frequent, but aerial pathways should not be overlooked. Where the potential for such a MATTE has been identified, efforts should be focused on measures for prevention and mitigation [1].

## 4.3 Compliance requirements

### 4.3.1 COMAH

COMAH requires all Upper Tier and Lower Tier establishment operators to submit a safety report to the Competent Authority (CA) that demonstrates the environmental risk for the whole COMAH establishment has been reduced to a tolerable level.

### 4.3.2 Land use planning

In the context of land use planning (LUP), the prevention of MATTEs will be the primary objective and it is expected that accident pathways will be prevented. Where this is not practicable, or in the context of significant modifications at existing COMAH establishments, the assessment of major accidents to the environment focuses on the specific risks to sensitive receptors within the local environment, the extent of consequences to such receptors and the ability of such receptors to recover: environmental damage may be relatively long-lasting but is not necessarily irreversible. Recovery of habitats within a reasonable period of time is possible, depending on the dangerous substance involved.

Emphasis is initially placed on the prevention phase, the control of potential pollution routes and available response measures, rather than on the development of a quantitative risk assessment approach and use of risk based criteria [1].

### 4.3.3 Assessment expectations

Assessment is based on a Source-Pathway-Receptor model. For new establishments, the CA will focus on the removal of accident pathways to receptors (through the use of additional technical measures: appropriate containment, within the confines of current good practice and ALARP, for example).

Irrespective of whether the approach is qualitative or quantitative, the HSA expect the following items to be considered when assessing a MATTE:


- environmentally sensitive areas in the vicinity,
- presence of endangered species,
- protected water resources/biospheres,
- types of accident that can cause environmental damage (firewater run-off, for example),
- contamination routes (watercourses, for example),
- measures in place to protect the environment and their reliability,
- hard/reliable measures in place to contain run-off in the context of internal and external emergency plans,
- recovery periods with and without intervention,
- clean-up and remediation plans and resources, and
- if necessary, tolerability of assessed risk.

Under COMAH, operators are required to use best practicable means, specifically:

- to prevent a major emission of dangerous substances resulting from uncontrolled developments in an establishment into the environment, and
- for rendering harmless and inoffensive the substances emitted.

## 5 MATTE assessment methodology overview

The general approach to environmental risk assessment followed by Vysus, applies industry guidelines such as the DEFRA Guidelines for Environmental Risk Management [5] whilst considering COMAH Regulations and CDOIF guidance. The basic outline for the DEFRA approach to environmental risk assessment is summarized in the model below.



**Figure 3. A framework for environmental risk assessment and management.**

The DEFRA risk assessment model allows the re-appraisal of the proposed design in a systematic manner, whereby:

- the conceptual model and problem formulation is informed by the revised design features.
- the approach to hazard identification and risk assessment is progressed by applying the source, pathway, receptor concept.
- residual risk identified by confirmation of the Source, Pathway, Receptor linkage can be assessed, eliminated, mitigate and / or managed to ALARP. Environmental risk assessment follows the source-pathway-receptor method, which requires that a linkage (pathway) must exist between the source and receptor in order for an accident to occur. Therefore any assessment of potential MATTE events will require the presence of a material that could harm the environment, a scenario for the release of the material, some pathway through which the material could pass to the environment, and some feature of the environment that could be significantly harmed.

The source, pathway concept methodology considers the features of a conceptual model to identify:

- sources of environmental impact from a major accident e.g. fire water or diesel spill
- pathway for pollutant to reach a receptor e.g. surface drain
- receptor e.g. groundwater aquifer, habitat.

An example of identifying and representing the S-P-R linkages regarding leakage from an underground gasoline storage tank that contains benzene.

**Table 1. Example, source, pathway, receptor linkage concept [5]**

Hazard	Source	Pathway	Receptor	S-P-R Linkage
Benzene	Underground fuel storage tank	Leaching Groundwater supply	Groundwater supply	Yes
			Public water supply	Yes

## 5.1 Sources

Sources are inventories of materials within the facility that are major environmental hazards (i.e. that have the potential to result in significant impact on the environment if released and reach an environmental receptor). The evaluation of sources includes quantity, location and properties of environmentally hazardous materials present on the site.

## 5.2 Pathways

Pathways may have a number of features; including the initial release of material, secondary failures and local factors.

Possible sources of release of materials that may be hazardous to the environment are primarily due to failure of containment. A range of possible causes of loss of containment exist and are typically due to:

- Impact by vehicle, machinery or dropped object;
- Dropped or punctured container;
- Corrosion, erosion or chemical attack;
- Overpressurisation or vacuum;
- Overfilling of equipment;
- Internal explosion (where flammable materials are present);
- Runaway chemical reaction or mixing of incompatible chemicals;
- Overheating or overcooling of equipment;
- On site events such as fires or explosions; or,
- Offsite events that may affect the area, such as earthquakes, landslip, flooding or extreme weather;

Secondary factors are those where some barrier or safeguard fails. For releases of liquids a secondary failure may be a damaged drain or bund, or the failure to treat a material if discharged into an effluent treatment system.

Pathways will also depend upon the type of surface onto which a material is released and drainage systems.

Local factors that influence pathways are often related to environmental conditions. For example, where releases could enter rivers, the hydraulic state of the river may be a factor. For releases to air, the



atmospheric conditions (wind speed, stability and direction) and rainfall could influence the consequences of a release. Releases to air may also include vapours generated by pools of spilt liquid.

### 5.3 Receptors

The assessment of major accidents to the environment focuses on the specific risks to sensitive receptors within the local environment, the extent of consequences to such receptors and the ability of such receptors to recover, noting that environmental damage may be long-lasting but not necessarily permanent.

Consideration of local environmental receptors and their sensitivity is required in order to allow an assessment of the consequences of a release from an establishment and whether it would be classified as a MATTE.

## 6 Environmental setting, sensitivities and impact assessment

The information presented in this section has been sourced from the original AECOM EIA report to enable the Vysus team to apply a Source, Pathway, Receptor approach to the review of the potential for a MATTE associated with the Power Plant only ABP Application.

Note: The potential impact of operations, abnormal events and accidents on the local environment not covered by COMAH regulations are outside the scope of this review and are not addressed here.

### 6.1 Site setting and operation

The area to be developed within the Proposed Development site is characterised by predominantly improved grassland in an agricultural setting. Field boundaries predominantly comprise hedgerows with small drainage ditches. A small section of the Ralappane Stream is located in the southernmost part of the Proposed Development site.

The Shannon Estuary comprises 500 square kilometres (km<sup>2</sup>) of navigable water extending from Loop Head, in Co. Clare, and Kerry Head, in Co. Kerry, eastwards to the city of Limerick, a distance of approximately 100 km. The naturally occurring deep and sheltered waters of the estuary are connected to the Atlantic Ocean and are accessible to large ocean-going vessels of varying types and sizes [7].

The location of the Proposed Development is within the protected area of the Shannon Estuary (the Lower River Shannon SAC, the River Shannon and River Fergus Estuaries SPA and the Ballylongford Bay pNHA). Therefore, the highest standards of environmental protection will be incorporated into the design of the Proposed Development [7].

### 6.2 Major accidents and disasters

The risk of a major accident occurring, is considered to be very low, however a detailed pollution response plan, emergency equipment and procedures will be in place prior to construction and throughout the lifetime of the Proposed Development.

The Proposed Development site location has been carefully chosen and there is a very low risk of natural disasters occurring such as flooding and earthquakes.

There is a very low risk of a major accident or disaster occurring at the Proposed Development. The facility will be regulated as a Lower Tier COMAH Installation and the highest levels of safety and environmental protection will be in place for the lifecycle of the facility, from prior to construction and throughout the operational lifetime. Detailed risk analyses for the Proposed Development such as Quantitative Risk Assessment (QRA) and Environmental Risk Assessment (ERA) will be carried to analyse the potential for further risk reduction.

The facilities associated with the Proposed Development will be designed, constructed and operated by specialist, experienced organisations who will adhere to all applicable national regulations and internationally recognised best practice in the design and operation of the facility, controlling the risks and delivering essential gas supplies to the national network [7].

### 6.3 Major accident scenarios

The Power Plant will contain process equipment such as natural gas compressors, turbine generators and electrical transformers, containing flammable and combustible substances. Consequently, a fire has been identified in this assessment as the most significant potential major accident in this area of the Proposed Development.

A number of fire prevention and protection measures are included in the design of the Proposed Development, which are as follows:

Layout of the Proposed Development to minimise the potential for an incident in one area affecting other areas;

Passive fire protection systems will be installed in appropriate areas, which allows certain systems to withstand a fire for a defined period of time to enable the emergency response plan to be initiated [7]:

- A network of fire and gas detectors, audible and visual fire alarms will be installed throughout the Proposed Development to alert operations personnel who will initiate the emergency response; and
- Active fire protection systems will be installed onsite, supplied by large firewater storage tanks and activated on demand from the fire and gas system or manually initiated from the central control room.

## 7 MATTE assessment

The MATTE study for the proposed power plant only development has been conducted as a desk study using the DEFRA Guidelines for Environmental Risk Management whilst taking account of the COMAH regulations and CDOIF.

The basic approach to the study was to apply the Source, Pathway, Receptor methodology to identify hazards and assess any residual environmental risk (MATTE) associated with a major accident.

### 7.1 Sources

Materials that have been identified as present at the STEP are shown in the table below.

**Table 2. Materials and Inventory**

Material	CAS Number	Inventory	Annual Use	Form	Containment	Use
Natural Gas	74-82-8	Natural Gas: <50 tonnes	Unknown	Gas	Piping and equipment containing gas	Process material (gas supply)
Ammonia hydroxide (19%)	1336-21-6	1,500 litres	13,140 litres	Liquid	Tote 1,500 litres	pH control
Tri-Sodium Phosphate	7601-54-9	1,500 litres	13,140 litres	Liquid	Tote 1,500 litres	pH buffer and harness/scale treatment
Sodium Bisulphite (30% - 50%)	7631-90-5	1,500 litres	3,500 litres	Liquid	Tote 1,500 litres	Dechlorination agent
Sulphuric Acid (77-100%)	7664-93-9	3,000 litres	Unknown	Liquid	Storage tank and Batteries	pH Control
Diesel	68476-34-6	11,500 m <sup>3</sup>	Unknown	Liquid	Diesel Tanks	Fuel
Transformer oil (Mineral oil, petroleum distillates)	Varies depending on supplier	110 m <sup>3</sup>	Unknown	Liquid	Within transformers	Electrical system cooling

Additional materials including antiscalants, biocides, corrosion inhibitors, antifreeze, cleaning chemicals, paints, hydraulic oil, grease and lubricating oils are expected to be present on site in small quantities. These materials, whilst present at the site, are not anticipated to be present in sufficient quantities to materially affect the outcome of this assessment.

A review of the Material Safety Data Sheets (MSDS) [9][10][11][12][13], the Globally Harmonized System of Classification and Labelling of Chemicals (GHS) [8] and the COMAH Regulations [3] has provided details of the classification and ecotoxicity of the materials listed in the table above. The findings from this review are summarised in the table below. Where the material classification is not directly available from GHS relevant data then data from the Material Safety Data Sheets (MSDS) has been used.

Any materials that are identified as 'Dangerous Substances' under the COMAH Regulations or have Hazard Classifications indicating the potential for significant environmental damage on release have been identified.

**Table 3. Material Classification and Ecotoxicity**

Chemical [CAS No.]	GHC Classification	Hazard Statement	Environmental Effects			COMAH Classification
			Toxicity	Biodegradability	Bioaccumulation	
Natural Gas	Flam. Gas 1 Press. Gas	H220	No environmental toxicity identified.	No data available	No data available	<b>Flammable gases</b>
Ammonia Hydroxide	Harmful if swallowed. Causes severe skin burns and eye damage. May cause respiratory irritation. Very toxic to aquatic life.	H302 H314 H335 <b>H400</b>	LD50 Oral – Rat – 350 mg/kg (Ammonium hydroxide) LC50 – Fish – 0.44 mg/l – 96 h (Ammonium hydroxide) LC50 – Daphnia magna (Water flea) – 25.4 mg/l – 48 h (Ammonium hydroxide)	No data available	Does not bioaccumulate	<b>Hazardous to the Aquatic Environment</b>
Tri-Sodium Phosphate	Causes skin irritation Causes serious eye irritation May cause respiratory irritation	H315 H319 H335	LD50 Oral – Rat – female - > 2,000 mg/kg LC50 Inhalation – Rat – male and female – 4 h - > 0.83 mg/l LD50 Dermal – Rat – male and female - > 2,000 mg/kg LC50 – Oncorhynchus mykiss (rainbow trout) - > 100 mg/l – 96 h EC50 – Daphnia magna (Water flea) - > 100 mg/l – 48 h ErC50 – Desmodesmus subspicatus (green algae) - > 100 mg/l – 72 h Toxicity to bacteria static test EC50 – activated sludge - > 1,000 mg/l – 3 h	Not applicable to inorganic materials	No data available	None
Sodium Bisulphite	Exempt from Regulation (EC) No 1272/2008.	-	No data available	No data available	Not bioaccumulative	None

Chemical [CAS No.]	GHC Classification	Hazard Statement	Environmental Effects			COMAH Classification
			Toxicity	Biodegradability	Bioaccumulation	
Diesel	Flam. Liquid Skin Corrosion/Irritation Aspiration Hazard STOT SE Carcinogenicity Aquatic Chronic Eye Damage/ Irritation	H226 H315 H304 H336 H350 <b>H411</b> H319	Inhalation LC50 Rat >6 mg/l/4h Acute Toxicity LD50 Dermal Rabbit >5000 mg/kg Acute Toxicity LD50 Oral Rabbit >5000 mg/kg Toxic to aquatic organisms based on an acute basis LC50/EC50 >1 but < 10 mg/L in the most sensitive species. Material is a long-term aquatic hazard based on a chronic basis (C50/EC50 >1 but < 10 mg/L in the most sensitive species.	No data available	No data available	<b>Named: Petroleum products (gas oils)</b>
Transformer Oil (1)	May be fatal if swallowed and enters airways. Harmful to aquatic life with long lasting effects.	H304 <b>H412</b>	LD50 (Rat): > 2,860 mg/kg LC50 (Rat): > 5.2 mg/l, 4 h	No Data available.	No data available.	<b>Hazardous to the Aquatic Environment</b>

Notes:

(1) Transformer oil classification based on review of a range of oil MSDS, the H412 categorisation may not be applicable to some transformer oils.

Of the materials listed in Table 2 those classified with the following categories are the most hazardous to the environment. Specifically:

- H400 – Very toxic to aquatic life (Ammonia hydroxide);
- H411 – Long-term (chronic) aquatic hazard (Category 2) (Diesel); and,
- H412 – Harmful to aquatic life with long lasting effects (Transformer Oil).

## 7.2 Pathways

A review of the processes undertaken and measures provided on the site has identified the following possible onsite pathways (refer to the following subsections), which have been considered, where appropriate, for the assessment of MATTE scenarios.

### 7.2.1 Drainage systems on site

The Environmental Impact Assessment Report (EIAR) [7] describes the details of the drainage systems on the site, which is summarised in this subsection.

A surface water drainage network consisting of piped drainage and swales/ catch basins will be constructed to collect, convey, and attenuate the surface water runoff generated.

The access road levels will be profiled to drain road runoff to an engineered swale adjacent to the road, the majority of which will drain to the engineered storm drainage system at the Power Plant site and discharge to the shared constructed outfall to the Shannon Estuary.

There will also be a stormwater discharge point at the Ralappane D1 stream crossing located 50m from the site entrance (Drawing Ref: 198291-1STF-S3001), and a second stormwater discharge point will be located at the D2 stream crossing located 20m from the construction laydown area (Drawing Ref: 198291-1STF-S3002). Both will be fitted with Class 1 hydrocarbon interceptors.

Stormwater collected from roof drains and permeable areas will discharge directly to the estuary via the final discharge monitoring station. All bunded areas within the Proposed Development site will have valved discharge points as part of their connection to the drainage network (see Figure 4 and Appendix A).

Groundwater seepages from springs or at the toe of cut slopes will be collected via a groundwater drainage network which will then discharge directly to the Shannon Estuary via the same discharge outfall pipe as the surface water.

Silt traps will be incorporated in all groundwater drainage points prior to discharge.

During the operational phase, all drainage from the Proposed Development site will be controlled and monitored in compliance with the terms of the IE licence.

A firewater retention pond is included in the Proposed Development and sized according to EPA Guidance on Retention Requirements for Firewater Runoff, as the most effective and suitable measure for retaining firewater. The retention pond will be rendered impermeable by use of an appropriate liner, and integrity-tested in line with the requirements of the site's licence. All process area site drainage will pass through the retention pond. An automatic shut-off valve linked to the site's fire detection system will be installed on the drainage outlet point.

### 7.2.2 Releases into Bunded Areas

Bunds are designed to contain liquid releases from bulk storage tanks. Where bunds are correctly designed, operated and maintained, the only release to the environment will be due to evaporation from

liquid that is contained in the bund. All bunds will be sized to contain the full storage tank inventory plus an additional allowance for safety where appropriate. These bunds will have valved discharge points as part of their connection to the drainage network. Prior to draining of rainwater from bunded areas, checks will be carried out to ensure that the material discharged is not contaminated.

Possible failure of bunds may be due to poor design, substandard construction, damage, overtopping, overfilling and the failure of systems for rainwater removal. Depending upon the failure type and location, possible outcomes of bund failure could be a release to unmade ground below the bund, release onto plant areas that are covered in broken stone, or release into the surface water drains. Bund failures that are coincident with a release of dangerous substance from the primary containment, while discussed in this assessment, are considered to be very low probability events.

### **7.2.3 Releases in the Power Plant Area**

All stormwater collected from paved and impermeable areas within the Power Plant will pass through a class 1 hydrocarbon interceptor prior to discharge to the Shannon Estuary.

At the end of the system there is a valve which is normally open to allow rainwater to discharge to the estuary but can be closed in an emergency to prevent discharge.

Stormwater collected from roof drains and permeable areas within the power plant will discharge directly to the estuary via the final discharge monitoring station.

### **7.2.4 Releases to the Storm Water Drain System**

The access road levels will be profiled to drain road runoff to an engineered swale adjacent to the road, the majority of which will drain to the engineered storm drainage system at the Power Plant site and discharge to the shared constructed outfall to the Shannon Estuary.

There will also be a stormwater discharge point at the Ralappane D1 stream crossing located 50m from the site entrance (Drawing Ref: 198291-1STF-S3001), and a second stormwater discharge point will be located at the D2 stream crossing located 20m from the construction laydown area (Drawing Ref: 198291-1STF-S3002). Both will be fitted with Class 1 hydrocarbon interceptors.

Releases to the Shannon Estuary are only possible if there is a failure to control discharge from the sumps or through the drains.

### **7.2.5 Releases to Ground/Ground Water from permeable areas**

Ground water from permeable areas will be collected by means of a ground water drainage network that will collect the ground water and discharge where possible into either the existing stream/drainage ditches within the site or directly to the estuary via same discharge outfall pipe as the storm water. Silt traps will be incorporated onto all groundwater drainage points prior to discharge.

As the site groundwater drains are only located along the outside perimeter of the developed site, away from process equipment, roadways and buildings it is thought that a release into these drains is not possible.

### **7.2.6 Releases into Storage Buildings/Warehouses**

Building areas used for chemical or hydrocarbon storage on the site, Power Station and AGI will have impermeable floors with no drains. Therefore, any spillage in these building areas should be contained.

### **7.2.7 Releases at the AGI Area**


Water collected on the paved and impermeable areas of the AGI will be collected and discharged to the storm water drain system after passing through an interceptor located at the AGI. The drainage route from the AGI Interceptor through the storm water drains pass through a second interceptor located near the



instrument air package prior to discharge into the fire water retention pond. The fire water retention pond discharges to the estuary.

#### **7.2.8 Fires**

Any fires on site will release combustion products, and in some cases may release unburned material to atmosphere. Systems will be installed on site for preventing and mitigating fires (e.g. inerting systems, minimisation of ignition sources and water or firefighting systems).



**Figure 4. Proposed Site Drainage**

### 7.3 Receptors

The Proposed Development site is in pasture, comprising primarily improved grassland with some wet grassland adjacent to the Shannon Estuary, as shown on the aerial photograph below.




**Figure 5. Proposed Development Site**


The Lower Shannon Special Area of Conservation (SAC) is partly within and adjacent to the site along the northern/ north-western boundary and also along part of the eastern boundary of the Proposed Development site (see below). The Ballylongford Bay Natural Heritage Area (NHA) is adjacent to a part of the north-western boundary of the Proposed Development site (see below). The Shannon-Fergus Estuary Special Protection Area (SPA) is to the west of the Proposed Development site (at a distance of approximately 750 m from the western extremity of the terrestrial elements of the Proposed Development site).

For the purpose of this assessment only the possible impacts to the most sensitive receptors will be considered (NHA, SPA and SAC). It is recognised that there are criteria for harm to other receptors but the criteria for extent and duration of harm for these receptors is less stringent than those for SACs, SPAs and NHAs.





**Figure 6. Proposed National Heritage Areas (NHA)**



**Figure 7. SPA and SAC**

## 7.4 COMAH materials

Materials that are covered by the COMAH Regulations as either Named Substances or by their hazardous characteristics, such as flammability or toxicity require specific assessment as their release may lead to a MATTE, as detailed in the 'COMAH Classification' column of Table 3.

Materials that fall into this category are:

- Natural gas;
- Ammonia hydroxide;
- Diesel; and,
- Transformer oil.

### 7.4.1 Natural gas

Natural gas is not toxic to the environment, hazards are associated with exposure to fires if a release of natural gas is ignited. Environmental receptors at risk are flora and fauna in the NHA and SAC to the west of the site.

There is no MATTE associated with the natural gas used on the facility as it does not have any liquid constituents.

### 7.4.2 Ammonia Hydroxide

Up to 4 tonnes of ammonia hydroxide solution will be stored at the Power Plant in 1,500 litre totes. It will be used for Power Plant feedwater treatment.

Ammonia hydroxide solution is considered to be toxic to the environment under the COMAH Regulations as it classified as H400 "Very toxic to aquatic life".

A possible worst case release for ammonia solution is the loss of the contents of a tote. This could occur during offloading or during storage. Any releases within the storage building would be contained by the building's impermeable flooring or bund and could be cleaned up (e.g. using absorbent material) and disposed of safely. Releases outside the building onto roadways could possibly enter the roadway storm water drains and flow through the drainage system to the estuary. However action can be taken to contain spillages and prevent flow to the estuary by closing the storm water drainage system valve.

The loss of the contents of a Tote of ammonia solution to the estuary is likely to have short term environmental effects at the point of discharge. However, it is thought that the release would not be of sufficient size to result in a MATTE.

Spillages onto ground covered in broken stone have not been considered as possible events, as ammonia solution is not used or transported over areas with this surfacing.

Spillage of ammonia solution will lead to a pungent odour close to the spillage. For a release of a tote of ammonia hydroxide solution the odour will not lead to off-site concentrations of concern as the solution is an aqueous solution and only small quantities of ammonia will be released from it to atmosphere.

### 7.4.3 Diesel

Diesel is present onshore within the STEP in a number of locations, provisionally identified as:

- Power Plant CCGT Standby Diesel Generator; 3,200 litres (three off);
- Power Plant CCGT Diesel Fire Pump; 1,400 litres; and,
- Power Plant CCGT secondary diesel fuel storage for the power plant, 11,500m<sup>3</sup>.

Diesel is considered to be toxic to the environment under the COMAH Regulations as it classified as H411 "Long-term (chronic) aquatic hazard".

The use of localised small inventory storage tanks for the items of equipment listed above means that the largest credible spillage of diesel (from the secondary diesel fuel storage) would be 11,500 m<sup>3</sup>. This is above the Lower Tier threshold of 2,500 tonnes for petroleum products, but below the Upper Tier threshold of 25,000 tonnes [3]. The volume of diesel is less than the Lower Tier threshold for a “Long-term (chronic) aquatic hazard” of 100 tonnes.

Tertiary containment, bunding and associated pipework will be designed in accordance with EPA Guidance Note on Storage and Transfer of Materials for Scheduled Activities. The tanks will be located in a bunded area, which will allow for either 110% of the largest tank within the bund or 25% of the total volume of substance within the bund, whichever is the larger, in accordance with CIRIA C736, Containment systems for the prevention of pollution: Secondary, tertiary and other measures for industrial and commercial premises, (CIRIA, 2014). The distillate oil will be supplied to the Site by HGV tanker at an unloading station adjacent to the storage tanks, which will feed the distillate oil into one of the three day-tanks. Further details are provided in Oil and Hazardous and Noxious Substances (HNS) Spill Plan.

Distillate Oil will be supplied to site by HGV tankers, which will connect to one of the three 2,000 m<sup>3</sup> storage tanks. It is not envisaged that distillate oil would not be used in the normal course of events other than for about three hours per annum for test firing. Containment arrangements to at the distillate tanker unloading area are as follows

1. Distillate oil will be stored in fixed steel tanks (primary containment) which are located within impermeable bunded areas with weather protection (secondary containment sized to contain greater than 110% of the largest tank volume or 25% of the total stored substances). The tanks and bunds will be subject to a formal risk-based inspection programme conducted by specialist accredited contractors.
2. All drains at this tanker unloading area will pass through Class 1 hydrocarbon interceptors. The interceptors will collect any accidental spills of fuels or oils used in vehicles onsite. Spill kits will be located at strategic points around the Proposed Development to ensure a quick response to any spillages should they occur. Any used spill kits will be disposed of using a hazardous waste disposal contractor and in accordance with all relevant EU and Irish waste management legislation (i.e. the Waste Management Acts 1996-2011 and any regulations made thereunder, and the Waste Framework Directive).
3. A firewater retention pond is included in the establishment and sized according to the EPA Guidance on Retention Requirements for Firewater Runoff (2019). The retention pond will be rendered impermeable by use of an appropriate liner, and integrity-tested in line with the requirements of the Site's licence. All drainage from the tanker unloading area will pass through the retention pond. An automatic shut-off valve linked to the site's fire detection system will be installed on the drainage outlet point. This tertiary system could be used for the containment of any distillate that is not contained by the secondary containment system.
4. During distillate oil offloading operations, protective systems will be in place to prevent a loss of containment such as dry-break hose couplings and vehicle chocks to prevent 'drive-away' incidents.
5. The design equipment and pipework will be to industry codes and standards to reduce the potential for a loss of containment, including the use of welded connections to avoid potential leak sources (flanges).
6. Fuel pipework safety systems such as cathodic protection will be installed along with operational controls and monitoring.
7. Instrumentation and control systems will continuously monitor the process and leaks causing a loss of pressure would be rapidly detected.



8. Alarms, both audible and visual, would be raised in the event of a deviation from set points such as pressure levels, vessel levels, etc. alerting site operators.
9. During commissioning, when distillate oil will be introduced to the site, detailed method statements, plans and assessments will be produced to carry out these activities safely.
10. The Establishment will be operated and managed by experienced, highly trained personnel in accordance with all Regulatory requirements, including COMAH.
11. The design will be subject to numerous formal process safety studies to identify and mitigate hazards, such as Hazard and Operability (HAZOP) studies.

The tertiary containment system for the diesel tanks, designed and operated in line with EPA Guidance Note on Storage and Transfer of Materials for Scheduled Activities, with 2 bunded areas contains the diesel within the bunds and prevents the diesel from spreading to the water.

The low release frequency combined with the tertiary containment system means that the likelihood of release of diesel occurring and reaching the water is considered extremely low.

#### 7.4.4 Transformer Oil

There is transformer oil present in four transformers, each of 25,000 litres capacity.

For the purpose of this assessment Transformer oil is considered to be toxic to the environment under the COMAH Regulations as it is classified as H412 "Harmful to aquatic life with long lasting effects". It should be noted that this assumption of this classification is conservative as transformer oils that do not pose a significant effect to the environment are available.

If a release of transformer oil was to enter into the storm water drainage system it would be contained by the Class 1 petrol interceptor. If the interceptor was unable to contain the release and the shut off valve on the storm water drainage system was not closed, there could be a discharge of transformer oil to the estuary. Possibly resulting in a surface layer of hydrocarbons on the estuary. In unfavourable conditions it is conceivable that this could affect the SAC/SPA. A MATTE is therefore considered to be possible, but only if the release of transformer oil was very large. However, the volume of transformer oil is less than the Lower Tier threshold for an H412 category fluid of 200 tonnes.

### 7.5 Non-COMAH Materials

Materials that are not rated as hazardous to the environment under the COMAH Regulations require MATTE assessment where it is credible that they could be released, as the result of an incident involving a material that is covered by the COMAH Regulations [3].

The conservative assumption that incidents involving natural gas could lead to the release of any of the non-COMAH materials listed in Table 2 has been made. It should be noted that, due to the separation distances between the natural gas systems and areas where these materials are present, the likelihood of secondary releases of this type are very low.

Materials considered are:

- Tri-Sodium Phosphate;
- Sodium Bisulphite (30% - 50%); and,
- Sulphuric Acid (77-100%).

In addition, releases of cleaning chemicals, laboratory chemicals, paints and fires have been considered at a high level.

### 7.5.1 Tri-sodium Phosphate

Tri-sodium phosphate will be used for feedwater treatment. It is a solid material that will be stored in 1,500 kg Totes at the Power Plant water treatment store. It is not classed as hazardous to the environment under the COMAH Regulations. The material has been identified as being toxic to fish.

A possible worst-case release for tri-sodium phosphate solution is the loss of the contents of a tote. This could occur during offloading or during storage. Any releases within the storage building would be contained by the building's impermeable flooring or bund and could be cleaned up (e.g. using absorbent material) and disposed of safely. Releases outside the building onto roadways could possibly enter the roadway storm water drains and flow through the drainage system to the estuary. However action can be taken to contain spillages and prevent flow to the estuary by closing the storm water drainage system shut off valve.

The loss of the contents of a Tote of tri-sodium phosphate ammonia solution to the estuary is likely to have short term environmental effects at the point of discharge. However, it is considered that the release would not be of sufficient size to result in a MATTE.

### 7.5.2 Sodium Bisulphite

Sodium bisulphite solution will be used for feedwater treatment. It is a liquid material that will be stored in 1,500 kg Totes at the Power Plant water treatment store. It is not classed as hazardous to the environment under the COMAH Regulations. The material has been identified as being toxic to fish.

A possible worst-case release for sodium bisulphite solution is the loss of the contents of a tote. This could occur during offloading or during storage. Any releases within the storage building would be contained by the building's impermeable flooring or bund and could be cleaned up (e.g. using absorbent material) and disposed of safely. Releases outside the building onto roadways could possibly enter the roadway storm water drains and flow through the drainage system to the estuary. However, action can be taken to contain spillages and prevent flow to the estuary by closing the storm water drainage system shut off valve.

The loss of the contents of a Tote of sodium bisulphite solution to the estuary is likely to have short term environmental effects at the point of discharge. However, it is considered that the release would not be of sufficient size to result in a MATTE as a release would be limited to a single tote.

Even if a pathway between the material and an environmental receptor could be identified, release of the material would not result in a MATTE.

### 7.5.3 Sulphuric Acid

Approximately 3 m<sup>3</sup> of sulphuric acid will be present on the Power station, and also used within uninterruptable power supply (UPS) batteries.

Sulphuric acid is a mineral acid that is corrosive and toxic to the aquatic environment at low levels. As sulphuric acid is not classified as being dangerous to the environment under the COMAH Regulations, as events requiring consideration are those that are due to an incident involving a COMAH material. In the Power Plant area this could be due to an incident involving natural gas that damaged the sulphuric acid containment systems or batteries.

A possible event taken for MATTE assessment is the release of sulphuric acid on the Power Plant. A worst case scenario would be the release of the entire tank contents due to failure of both the tank and leakage from or overtopping of the bund. In this scenario up to 3 m<sup>3</sup> of acid could be released. As the tank is located at some distance from the buried natural gas supply line to the Power Plant, the likelihood of a release of this size is considered to be very unlikely. However, in such an event, a release of sulphuric acid into the storm water drains may be possible.

At the end of the storm water system there is a shut off valve which is normally open to allow the rainwater to discharge to the estuary. This valve can be closed in the event of spillage, as required. A spillage of sulphuric



acid could potentially be released to the estuary through this route if the shut off valve was not closed. As the quantities released would be small, and sulphuric acid is not highly toxic to the environment, it is judged that a MATTE from a leak of sulphuric acid is not credible.

#### 7.5.4 Cleaning Chemicals, Laboratory Chemicals and Paints

Various types of laboratory chemicals, paints and cleaning materials will be stored in Maintenance & Warehouse Buildings and will be used throughout the STEP. Details of the properties of these materials are not available but it is likely that some of the materials will be hazardous to the environment or flammable.

These types of materials are commonly stored and transported on site in small containers and if accidentally spilled can be treated, absorbed into inert materials and disposed of safely. Any releases in storage areas will be contained by impermeable flooring. On this basis it is concluded that a MATTE from the release of laboratory chemicals, paints and cleaning materials is not credible.

#### 7.5.5 Storage Building Fires

A variety of materials such as laboratory chemicals, paints, cleaning materials, oils and process chemicals will be present in storage buildings on the site. Storage building fires may occur as a consequence of a natural gas fire and a range of materials stored in the buildings could combust, be carried into the atmosphere in the smoke plume, be released to the building floor (liquids) or enter firewater.

In the event of a storage building fire the materials being released to atmosphere will be primarily carbon dioxide, carbon monoxide, water vapour, soot and unburned materials that may be carried in the smoke plume.

Local environmental factors such as wind speed and direction will influence which environmental receptors are likely to be affected and the potential for dry deposition of materials in the plume. Washout of material from the plume may occur if it is raining, leading to deposition of materials.

The primary combustion products (carbon monoxide, carbon dioxide and water vapour) in fire plumes will have short term environmental effects as they are not considered to be highly hazardous to the environment and will not produce long term contamination. Soot deposited from the plume may lead to short-term marking of vegetation but is also unlikely to lead to long term or acute environmental damage. Therefore, a MATTE from a storage building fire smoke plume is not thought to be a credible event.

Fire water run-off from a storage building fire will be expected to be contained on site and will only reach the Shannon estuary if a very large quantity of firewater is used. In this event, water contaminated with materials that may be hazardous to the environment could enter the estuary. If such a release was prolonged, and contained materials that are ecotoxic, it is possible that the local SAC/SPA could be affected, possibly leading to a MATTE. With the measures proposed for preventing building fires and controlled discharge of fire water to the estuary, the risk of a MATTE from fire water run-off is considered to be very low.

### 7.6 MATTE risk evaluation

The evaluation of risk associated with the identified MATTE events is provided below.

**Table 4. MATTE Sources for the Power Plant only design.**

Material	Risk of MATTE
Diesel	Low - the proposed 11,500 m <sup>3</sup> diesel stored on site falls within the Qualifying quantity (>2,500 tonnes) of dangerous substances as referred to in the COMAH Regulations, but the low likelihood of a release occurring combined with the tertiary containment system means that it is very unlikely for a release to occur resulting in the material entering the estuary (pathway).

Material	Risk of MATTE
Transformer oil	Very low - measures on site would prevent the material entering the estuary (pathway)
Firefighting Water	Very low – measures on site would prevent the material entering the estuary (pathway)

A review of the escalation potential, vulnerabilities, and potential environmental impacts is provided below:

### Escalation

In respect of the risks of escalation, facilities will be designed to incorporate separation distances to prevent major accidents such as fires and explosions originating in one area from spreading to another area or escalating via domino effects, based on established engineering guidance for industrial site layout. Further the development will be partitioned into fire zones, where equipment is grouped by nature and / or homogeneous level of risk. The consequences of a fire, flammable gas leak or an explosion corresponding to the credible event likely to occur in one fire zone shall not impact other fire zones.

### Vulnerability

In terms of the vulnerability of the project to potential disasters/accidents, including both natural and man-made disasters it is noted that the application is accompanied by a flood risk assessment, which concludes that with the exception of crossings of Ralapanne Stream by the access road, there is no development proposed within either Flood Zones A or B. The proposed watercourse crossings have been sized to have a minimal impact on the hydraulic regime in the area and provide an adequate freeboard for a 1% AEP fluvial event. The site is also remote from other major accident sites and would not be at risk from events at such sites.

### Environmental impacts

**Table 5. Review of Environmental Impacts**

Phase	Impact	Effect	Comment
Land & Soils			Impacts that are predicted to arise in relation to Land and Soils would be avoided managed and mitigated by the measures which form part of the proposed scheme and the proposed mitigation measures. The proposed development would not have any unacceptable direct, indirect or cumulative impacts in terms of Lands and Soils.
Construction phase	Accidental spills and leakage of oils and fuels.	Minimal	
Operational	Spillages of fuel, oil, wastewater or other hazardous substances	Minimal	
Cumulative effects	N/A	N/A	

Phase	Impact	Effect	Comment
Water	Accidental spills and leaks from use and storage of liquid chemicals, oils and fuels.	Minimal	Impacts in relation to Water would be avoided, managed and mitigated by the measures which form part of the proposed scheme and by appropriate conditions. The proposed development would not have any unacceptable direct, indirect or cumulative impacts in terms of Water. See also the assessment of effects on Marine Ecology below.
Marine ecology	Accidental large-scale oil spill during operations -Habitats, Marine Mammals, Fish and crustacean species of the estuary and SAC, birds of the SPA	Not significant	Impacts that are predicted to arise in relation to Marine Ecology, would be avoided managed and mitigated by the measures which form part of the proposed scheme. The proposed development would not have any unacceptable direct, indirect or cumulative impacts in terms of Marine Ecology.
Terrestrial Ecology	N/A	N/A	N/A
Major Accidents and Disasters	Loss / spillage of other contaminants. Potential for release of contaminants in firewater.	Not significant	Impacts in relation to major accidents and disasters would be satisfactorily avoided, managed and mitigated by the measures which form part of the proposed scheme and by appropriate conditions. The proposed development would not have any unacceptable direct, indirect or cumulative impacts in terms of major accidents and disasters

## 7.7 MATTE assessment summary

The table below provides the results of the MATTE assessment for the Power Plant only design.

**Table 6. MATTE potential for the Power Plant only design**

Material	MATTE	MATTE Risk
Diesel	Yes	Low - The proposed 11,500 m <sup>3</sup> diesel stored on site falls within the Qualifying quantity (>2,500 tonnes) of dangerous substances as referred to in the COMAH Regulations, but the low likelihood of a release occurring combined with the tertiary containment system means that it is very unlikely for a release to occur resulting in the material entering the estuary (pathway).
Transformer oil	Yes	Very low - measures on site would prevent the material entering the estuary (pathway)
Firefighting Water	Yes	Very low – measures on site would prevent the material entering the estuary (pathway)
Natural Gas	No	N/A Not a MATTE
Ammonia Hydroxide	No	N/A Not a MATTE
Tri-Sodium Phosphate	No	N/A Not a MATTE
Sodium Bisulphite	No	N/A Not a MATTE
Sulphuric acid	No	N/A Not a MATTE
Cleaning materials, laboratory chemicals and paints	No	N/A Not a MATTE

## 8 Conclusions

The results from the MATTE assessment are summarised in the table below.

Qualitative assessment of possible scenarios for accidental releases associated with the STEP has indicated that releases or accidents of large quantities of some materials have the potential for causing a MATTE; specifically diesel and Transformer Oil. Release of firefighting water to the estuary could result in a MATTE if it is contaminated with ecotoxic materials.

**Table 7. MATTE assessment summary**

Material	Potential MATTE?	Evaluation	MATTE Risk
Diesel	Yes	The proposed 11,500 m <sup>3</sup> diesel stored on site falls within the Qualifying quantity (>2,500 tonnes) of dangerous substances as referred to in the COMAH Regulations, but the low likelihood of a release occurring combined with the tertiary containment system means that it is very unlikely for a release to occur resulting in the material entering the estuary (pathway).	Low
Transformer oil	Yes	Transformer oil may be hazardous to the environment depending on its chemical composition and a significant release to the estuary could result in a MATTE. Measures on site would prevent the material entering the estuary (pathway)	Very low
Firefighting Water	Yes	Firefighting the water may be contaminated with materials that are toxic to the environment and, as such, a release of a large quantity of firefighting water into the Shannon estuary may lead to a MATTE. Measures on site would prevent the material entering the estuary (pathway)	Very low
Natural Gas	No	There is no MATTE associated with the natural gas used on the facility as it does not have any liquid constituents.	N/A Not a MATTE
Ammonia Hydroxide	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Tri-Sodium Phosphate	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Sodium Bisulphite	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Sulphuric acid	No	Small quantities of material that is not significantly ecotoxic with low possibility of entering the marine environment.	N/A Not a MATTE
Cleaning materials, laboratory chemicals and paints	No	Materials may be harmful to the environment but only present in small quantities with low possibility of entering the marine environment.	N/A Not a MATTE

All of the identified MATTE events are described as low or very low risk, as the likelihood of a release occurring is low and measures for prevention of discharge to the estuary are present within the plant design and operating philosophy.

It is noted that the risks associated with the facility are in accordance with HSA criteria.

## 9 References

- [1] Guidance on technical land-use planning advice. For planning authorities and COMAH establishment operators. HSA, version 2, February 2023.
- [2] Health and safety authority Guidance to Inspectors on the Assessment of Safety Reports under the COMAH Regulations 2015, Rev. 4 Jan 2017
- [3] Chemicals Act (Control of Major Accident Hazards Involving Dangerous Substances) Regulations 2015. SI No. 209 of 2015.
- [4] Chemicals and Downstream Oil Industries Forum (CDOIF). Guideline – Environmental Risk Tolerability for COMAH Establishments v2.0.
- [5] DEFRA. (2011). Guidelines for Environmental Risk Assessment, Green Leaves III. DEFRA
- [6] Official Journal of the European Union. (2012). Directive 2012/18/EU of the European Parliament and of the Council of 4 July 2012 on the control of major-accident hazards involving dangerous substances, amending and subsequently repealing Council Directive 96/82/EC
- [7] Shannon Technology and Energy Park Environmental Impact Assessment Report, AECOM.
- [8] Globally Harmonized System of Classification and Labelling of Chemicals (GHS). [About the GHS | UNECE](#)
- [9] Olin Chlor Alkali Products Material Safety Data Sheets. [www.olinchloralkali.com](http://www.olinchloralkali.com)
- [10] Sciencelab Material Safety Data Sheets. [www.sciencelab.com](http://www.sciencelab.com)
- [11] Sigma Aldrich Material Safety Data Sheets. [www.sigmaaldrich.com](http://www.sigmaaldrich.com)
- [12] Robinsons Brothers Material Safety Data Sheet for Odorant NB. 3/03/2013 Revision No. 7.
- [13] Air Liquide Material Safety Data Sheets. [www.uk.airliquide.com](http://www.uk.airliquide.com)
- [14] [Policy & Approach of the Health and Safety Authority to COMAH Risk-based Land-use Planning, 19<sup>th</sup> March 2010.](#)

# Appendix A. Drainage




Figure 2-24 Proposed Development Water Flows

Prepared for: Shannon LNG Limited

AECOM  
2-48

