


Our Case Number: ABP-321029-24



An
Bord
Pleanála

Department of Defence
Property Management Branch
Station Road
Newbridge
Co. Kildare
W12AD93

Date: 12 November 2024

Re: 10 year planning permission for wind energy development consisting of 17 no. wind turbines and related works
Located on land at Cummeennabuddoge (County Kerry), Clydaghroe (County Kerry), Glashacormick (County Kerry), Cummeenavrick (County Kerry), and Caherdowney (County Cork). (www.cummeennabuddogeplanning.ie)

Dear Sir / Madam,

An Bord Pleanála has received your submission in relation to the above mentioned proposed development and will take it into consideration in its determination of the matter.

The Board will revert to you in due course in respect of this matter.

Please be advised that copies of all submissions / observations received in relation to the application will be made available for public inspection at the offices of the local authority and at the offices of An Bord Pleanála when they have been processed by the Board.

More detailed information in relation to strategic infrastructure development can be viewed on the Board's website: www.pleanala.ie.

If you have any queries in the meantime please contact the undersigned officer of the Board. Please quote the above mentioned An Bord Pleanála reference number in any correspondence or telephone contact with the Board.

Yours faithfully,

Ellen Moss

Ellen Moss
Executive Officer
Direct Line: 01-8737285

PA09

Tel	Tel	(01) 858 8100
Glaó Áitiúil	LoCall	1800 275 175
Facs	Fax	(01) 872 2684
Láithreán Gréasáin	Website	www.pleanala.ie
Ríomhphost	Email	bord@pleanala.ie

64 Sráid Maoilbhríde	64 Marlborough Street
Baile Átha Cliath 1	Dublin 1
D01 V902	D01 V902

Ellen Moss

From: Bord
Sent: 04 November 2024 11:10
To: Marine
Subject: FW: ABP ref. 321029
Attachments: 2024-10-31 Observation Letter to ABP re. ABP 321029-24.pdf
Categories: Ellen Case

From: Defence Property Management Planning <PropertyManagementPlanning@defence.ie>
Sent: Monday, November 4, 2024 11:09 AM
To: Bord <bord@pleanala.ie>
Subject: ABP ref. 321029

Caution: This is an **External Email** and may have malicious content. Please take care when clicking links or opening attachments. When in doubt, contact the ICT Helpdesk.

A Chara,

Please find attached, observation letter in respect of An Bord Pleanlá ref. ABP 321029-24

Application by Cummeennabuddoge Wind , for a windfarm comprising of 17 no. Wind Turbines.
Located: **Located on land at Cummeennabuddoge (County Kerry), Clydaghroe (County Kerry), Glashacormick (County Kerry), Cummeenavrick (County Kerry), and Caherdowney (County Cork).**

Is mise, le meas,
Paul

Paul Farrell

Property Management Branch

An Roinn Cosanta

Department of Defence

Bóthar an Stáisiúin, An Droichead Nua, Contae Chill Dara, W12 AD93.

Station Road, Newbridge, Co.Kildare, W12 AD93.

T+353 (045) 452086

E-mail: paul.farrell@defence.ie

www.defence.ie

Follow us on Twitter: [Department of Defence](#) | [Civil Defence](#) | [Office of Emergency Planning](#)

Fógra faoi Rúndacht: Tá an ríomhphost seo agus aon iatán a ghabhann leis rúnda. Is leis an duine / nó daoine sin amháin a bhfuil siad seolta chucu a bhaineann siad agus ní ceart iad a léamh ná a scaoileadh chuig aon tríú páirtí gan cead roimh ré ón Roinn Cosanta.

Notice re Confidentiality: This e-mail and any attachment transmitted with it are confidential. They are intended solely for the use of the intended recipient and should not be read or released to any third party without the prior consent of the Department of Defence.



An Bord Pleanála
64 Marlborough Street,
Dublin 1
D01V902
31 October 2024

Re: PLANNING REGISTRATION NO: ABP 321029

Dear Sir/Madam,

I write with regard to the above planning application by Cummeennabuddoge Wind Designated Activity Company for construction of a wind energy development consisting of 17 no. wind turbines located on land at Cummeennabuddoge (County Kerry), Clydaghróe (County Kerry), Glashacormick (County Kerry), Cummeenavrick (County Kerry), and Caherdowney (County Cork).

Following consultations with our Air Corps colleagues at Casement Aerodrome, The Department of Defence would like to make the following observations:

All turbines should be illuminated by Type C, Medium intensity, Fixed Red obstacle lighting with a minimum output of 2,000 candela to be visible in all directions of azimuth and to be operational H24/7 days a week.

Obstacle lighting should be incandescent or, if LED or other types are used, of a type visible to Night Vision equipment. Obstacle lighting used must emit light at the near Infra-Red (IR) range of the electromagnetic spectrum, specifically at or near 850 nanometres (nm) of wavelength. Light intensity to be of similar value to that emitted in the visible spectrum of light.

Any Irish Air Corps (IAC) requirements for are separate to Irish Aviation Authority (IAA) requirements.

Please contact me if you have any queries in this regard.

Yours faithfully,

Sent via e-mail

Paul Farrell
Property Management Branch
Department of Defence
Station Road
Newbridge
Co. Kildare W12 AD93
045 4520
paul.farrell@defence.ie