Attachments:

ACP-323461.25 - Responce to Submission received on 9-10-25.pdf

From: Oisin O'Connor < ooconnor@sligococo.ie Sent: Wednesday 5 November 2025 13:11

To: LAPS < laps@pleanala.ie>

Subject: Case Number ACP-323461.25 - Response to Submission received on 9/10/2025

Caution: This is an **External Email** and may have malicious content. Please take care when clicking links or opening attachments. When in doubt, contact the ICT Helpdesk.

Dear Breda,

Thank you for your correspondence with regard to Case Number ACP-323461.25 and the submission received from Uisce Eireann and the opportunity to respond to the same.

Please find attached our response to the submission as raised.

Regards

Oisín O'Connor

Innealtóir Feidhmiúcháin

Executive Engineer

Dearadh Bóithre – Comhairle Contae Shligigh

Road Design - Sligo County Council

Cois Abhann, Sligeach, F91A7KC

Riverside, Sligo F91A7KC

+353-719111382

> +353-879858081

ooconnor@sligococo.ie









An Coimisiún Pleanála 61-64 Marlborough Street Dublin

Sent via e-mail to laps@pleanala.ie

COMHAIRLE CONTAE SHLIGIGH

ÁRAS CONTAE COIS ABHAINN SLIGEACH

ACP Case Number ACP-323461.25 5^{tth} November 2025

RE: ACP-323461.25 - Sligo County Council: Proposed Repair and Refurbishment of Markievicz Bridge, Bridge Street Sligo, Co Sligo.

A Chairde,

D01V902

We refer to your correspondence dated 9th October 2025 regarding a submission received from Uisce Éireann in relation to case number ACP-323461.25 Pursuant to Sligo County Council's application under section 177AE of the Planning and Development Act 2000 (as amended) for approval for Repair and Refurbishment of Markievicz Bridge, Bridge Street Sligo, Co Sligo.

Following a review of the submission we can confirm the following:

- We are aware of the Uisce Éireann watermains located withing the Bridge Structure (within existing footpath, Downstream side). No building works are proposed within minimum separation distance as per ÚE requirement of 500mm (IW-CDS-5020-03 clause 3.6.2.).
- We are aware of the Uisce Éireann Sewer located adjacent to the Structure (Riverbed Downstream side - between 3-7m upstream of the structure). No building works are proposed within the minimum separation distance as per ÚE requirement of 1m (IW-CDS-5030-03 clause 3.20.7.).
- We have no issues complying with the proposed UÉ standard Conditions as applicable.



Is mise le meas,

Oisín O'Connor

Executive Engineer

Road Design

Sligo County Council