

THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL
OTHER RELEVANT DRAWINGS, THE SPECIFICATION AND
THE SAFETY AND HEALTH PLAN.

1. NO PART OF THIS DRAWING MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF MALONE O'REGAN CONSULTING ENGINEERS AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DRAWING WAS ORIGINALLY ISSUED.

2. ALL DIMENSIONS IN mm UNLESS NOTED OTHERWISE.
3. ALL LEVELS ARE TO POOLBEG DATUM

 LUMINAIRE A : TWEET NEO S1-X1 2BSLB12 ERL + COUPE
FLUX COUPE FLUX 500MA 38W LAMP OSLON² GEN5 MF 0.90.
MOUNTING HEIGHT - 6 METERS HIGH.

 LUMINAIRE C : TREK (BORNE) 1BLSB8 EAH 700MA 19W
2700K IRC70 LAMP OSLON² GEN5 MF 0.90.
MOUNTING HEIGHT - 1 METER HIGH.

LUMINAIRE D : KERIS 3 10BLSB12 ERE 850MA 310W

2700K IRC70 LAMP OSLO[®] GEN5 MF 0.90.
MOUNTING HEIGHT - 10 TO 20 METERS HIGH
(DEPENDANT ON MAST HEIGHT & LOCATION) REFER TO
LIGHTING REPORT AND SITE LAYOUT FOR ID TAG.

 LUMINAIRE E : PIXOL200 PAR 34W XB UNID 2700K. DALI
LAMP 4462517.840 MF 0.90.
MOUNTING HEIGHT - 3 METERS HIGH.

 LUMINAIRE F : STONE-S180 10W UNIDIR. ON/OFF-2700K
LAMP IMPORT MF 0.90.
MOUNTING HEIGHT - 0.1 METER HIGH (100mm HIGH).

0	PLANNING ISSUE	05.09.2025	JD	ES
Rev.	Description	Date	Drawn	Chkd



MALONE O'REGAN
CONSULTING ENGINEERS

3-4 Canada Street
Waterford
Co. Waterford.
X91 V52K
Tel: +353 51 876 855
Email: waterford@morce.ie
Web: www.maloneoregan.com

Offices also in:

DUBLIN : Tel: +353 1 260 2655	Email: dublin@morce.ie
GALWAY: Tel: +353 91 531 069	Email: galway@morce.ie
LONDON: Tel: +44 208 5281685	Email: london@morce.ie

Client  PORT OF WATERFORD
COMPANY

Job PROPOSED OFFSHORE RENEWABLE ENERGY
CAPABLE TERMINAL ON A 250m WHARF EXTENSION &
ANCILLARY OPERATIONAL SUPPORT INFRASTRUCTURE

Drawing
PROPOSED LIGHTING LAYOUT
SHEET 1

Job No	Revision	Approver	Scale	Sheet
W20088	0	ES	A1 1:500 A3 1:1,000	A1

Drg No
W20088-XX-XXX-DR-MOR-CE-01221