

DO NOT SCALE FROM THIS DRAWING USE FIGURED DIMENSIONS IN ALL CASES.

VERIFY DIMENSIONS ON SITE AND REPORT ANY DISCREPANCIES TO THE DESIGNERS IMMEDIATELY. THIS DRAWING TO BE READ IN CONJUNCTION WITH THE DESIGNERS SPECIFICATION.

© THIS DRAWING IS COPYRIGHT AND MAY ONLY BE REPRODUCED WITH THE DESIGNERS PERMISSION.

## NOTES:

- ALL DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT SPECIFICATIONS, BILLS OF QUANTITIES,
- ARCHITECTURAL, SERVICES AND ENGINEERING DRAWINGS. ALL LEVELS ARE IN **METRES** RELATED TO ORDNANCE DATUM MALIN HEAD OSGM15.
- ALL CO-ORDINATES ARE TO IRISH TRANSVERSE MERCATOR (ITM) AND IN METERS.
- ANY DISCREPANCIES BETWEEN THESE DOCUMENTS SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER.
- DRAWINGS ARE NOT TO BE SCALED. 6. ALL DIMENSIONS ARE IN **MILLIMETRES**, UNLESS NOTED

REFERENCE DRAWINGS: DRAWING No. DRAWING TITLE

## TRENCH NOTES:

. ALL DUCTING TO BE RED ESB SPEC.

STRAIGHT DUCTS TO BE USED WHERE POSSIBLE.

- 2. DUCTING TO BE 160mm/200mm HDPE AND 50mm HDPE COIL .
  3. DUCTING SURROUND TO BE SAND/PEA GRAVEL OR SUITABLE QUARRY DUST. WHERE DUCTS CROSS ROADS, HARDSTANDS ETC, BACK FILL TO CONSIST OF A CBM4 GRADE LEAN MIX SURROUND.
- TRENCHES TO BE BACKFILLED ON TOP OF STONE FREE MATERIAL WITH A SUITABLE BACKFILL MATERIAL. DUE CARE TO BE TAKEN TO ENSURE THAT ALL BACKFILLED IS FREE FROM STONES, TREE ROOTS OR OTHER DEBRIS
- THAT COULD DAMAGE INSTALLATION. 5. MANDREL, DRAW ROPE (MINIMUM 12mm Ø), 160mm & 200mm POWER CABLES TO BE PULLED THROUGH INSTALLED DUCT BY CIVIL
- CONTRACTOR. DUCT TO BE CERTIFIED AS INTACT, CLEANED AND CAPPED AT BOTH ENDS PRIOR TO ANY CABLE PULLING ACTIVITY. . MINIMUM DISTANCE BETWEEN ANY POWER CIRCUITS WITHIN A TRENCH AS SHOWN.
- 8. WHERE MANUFACTURED BENDS ARE REQUIRED, SLOW BENDS ARE TO BE USED (15° OR LESS OVER 1200mm). 9. JOINT BAYS LOCATION TO BE ADVISED BY EBOP CONTRACTOR.
- 10. DISTANCES BETWEEN PULLING PITS TO BE CONFIRMED BY THE CABLE INSTALLATION TEAM. 11.EXACT LOCATION OF DUCTS TO BE DECIDED BY CIVIL CONTRACTOR.
- 12. CABLE MARKERS SHALL BE ERECTED @100m c/c, AT ALL ROAD CROSSINGS, CHANGES IN DIRECTION, LAND OWNER BOUNDARY & WATER
- CROSSINGS. FOR CROSS COUNTRY SECTIONS CABLE MARKERS WILL BE PLACED ON BOTH SIDES OF THE TRENCH. 3.BACKFILL MATERIAL AND DUCTING SURROUND MATERIAL THERMAL RESISTIVITY PROPERTIES TO BE CONFIRMED BY ELECTRICAL DESIGNERS.
- CERTIFICATES TO BE PROVIDED BY CIVIL CONTRACTOR. 14. WHERE THE CABLE DUCT IS TO RUN UP EXPOSED UPFILL, IT SHOULD BE CUT INTO THE UPFILL, LAID & SURROUNDED IN CONCRETE.

BALLINLA WIND FARM

INTERNAL CABLE TRENCH DETAILS

BALLINLA WIND FARM LIMITED

O.R. P.C. A/S 23882 MAR'25 FOR APPROVAL S4

23882 - MWP - 00 - 00 - DR-C - 5407