



A = 160mm: Outer Diameter HDPE ESB Approved Duct, SDR= 21.0 (Power) [ESB Code: 9317560]  
B = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (Comms) [ESB Code: 9317552]  
C = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6 (ECC) [ESB Code: 9317552]

# 110kV Double Circuit Ducting Section Through Access Track

SCALE 1:10

**Note:**

- This drawing is subject to ESB design approval and should not be used for construction.
- This drawing is to be read in conjunction with relevant drawings, specifications and reports.
- Dimensions are in millimeters, unless noted otherwise.
- Drawings are not to be scaled use figured dimensions only.

**ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH ACCESS TRACK DESIGN REQUIREMENTS**

Reinstatement details based on Guidelines for Managing Openings in Public Roads - SD14



Head Office  
Beenreigh,  
Abbeydorney,  
Tralee, Co. Kerry  
Ireland  
Tel: 00353 66 7135710



CLIENT  
PROJECT  
Shancloon 110kV Substation

PROJECT NUMBER  
05-1021

SHEET NUMBER  
051021-DR-118

SHEET TITLE  
110kV Double Circuit Ducting through  
Access Track

DRAWING STATUS  
For Planning

ISSUE/REVISION		
P00	18.10.24	Issued for Planning
N0	12.04.24	Issued for Information
I/R	DATE	DESCRIPTION