



TYPE 1 CULVERT

SCALE 1:50





TYPE 3 CULVERT **SCALE 1:50**

NOTE:

CULVERTS ARE TO BE OF ADEQUATE SIZE TO CARRY PEAK FLOWS CORRESPONDING TO A 1 IN 100 YEAR STORM EVENT, WITH A MINIMUM DIAMETER OF 900mm. THEY SHOULD BE INSTALLED TO CONFORM WHEREVER POSSIBLE TO THE NATURAL SLOPE AND ALIGNMENT OF THE STREAM OR DRAINAGE LINE. CULVERTS GREATER THAN 1m DIAMETER SHOULD BE BURIED TO A MINIMUM DEPTH OF 300mm BELOW THE STREAMBED AND THE ORIGINAL BED MATERIAL PLACED IN THE BOTTOM OF THE CULVERT.

- 1. FORMATION LEVEL TO BE DETERMINED BY THE CIVIL WORKS DESIGNER. REFER TO SITE INVESTIGATIONS REPORT.
- 2. SUB BASE MATERIAL TO CONFORM TO THE FOLLOWING:

IMPORTED MATERIAL TO CONFORM TO TYPE 6F1 IN ACCORDANCE WITH TABLE 6/2 OF THE NRA SPECIFICATION


FOR ROAD WORKS. SITE WON MATERIAL

ROCK WON IN EXCAVATION OF TURBINES MUST BE CRUSHED AND GRADED ON SITE. THE MAXIMUM SIZE OF AGGREGATE TO BE 125mm. THE AGGREGATE GRADING TO BE AGREED WITH THE ENGINEER.

3. SURFACE LAYER TO BE CLAUSE 804. THIS LAYER MAY BE APPLIED IMMEDIATELY BEFORE TURBINE DELIVERY.

- FIGURED DIMENSIONS ONLY TO BE TAKEN FROM THIS DRAWING 2. ALL DRAWINGS TO BE CHECKED BY THE CONTRACTOR ON SITE 2. ENGINEER TO BE INFORMED OF ANY DISCREPANCIES BEFORE ANY WORK COMMENCES.
- ANY WORK COMMENCES.
 THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.

THIS DRAWING IS NOT TO BE USED AS A CONSTRUCTION DRAWING.



CONSTANT ENERGY LTD

Project

TIRAWLEY WIND FARM CO. MAYO

PLANNING

DRAINAGE DETAILS SHEET 4 OF 4

AS NOTED @ A3

urveyed Prepared Checked Approved Date MG / DT DK



JENNINGS O'DONOVAN AND PARTNERS LIMITED

FINISKLIN SLIGO IRELAND Tel (+353) 719 161 416 Email. info@jodireland.com www.jodireland.com

Drawing no. 6289 PL-203