






NOTES:

- 1 FIGURED DIMENSIONS ONLY TO BE TAKEN FROM THIS DRAWING.
- 2 ALL DRAWINGS TO BE CHECKED BY THE CONTRACTOR ON SITE.
- 3 ENGINEER TO BE INFORMED OF ANY DISCREPANCIES BEFORE ANY WORK COMMENCES.
- 4 THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.

150mm RC floor slab with A252 mesh top and bottom,
on 95mm high density extruded polystyrene insulation
(Kingspan Styrozone or similar) on 50mm sand screed
on layers of compacted clause 804 on Foundation Slab
on sand screed and monarflex R.M.B 300
or similar approved radon barrier.
40mm GRP Floor Panels ESB Approved over cable
ducts.

Section



Client				
CONSTANT ENERGY LTD				
Project				
TIRAWLEY WIND FARM CO. MAYO				
Stage				
PLANNING				
Title				
PROPOSED ELECTRICAL SUBSTATION LAYOUT PLAN - 110kV				
Scales				
1:100 @ A1				
Surveyed	Drawn	Checked	Approved	Date
OSI	JB	MG / DT	DK	07/2025



 @JOD_Sligo
  Jennings O'Donovan & Partners
  Jennings O'Donovan

Job Ref.	Drawing No.	Revision
6289	PL-802	0

NOTE:
THIS IS A TYPICAL DESIGN: BEFORE CONSTRUCTION, THE CONTRACTOR WILL COMPLETE A SITE-SPECIFIC ASSESSMENT AND DESIGN OF BUILDING TO DETERMINE THE TYPE, SIZES AND MATERIAL SELECTION AND GET APPROVAL FORM THE CLIENT AND CO.COUNCIL.

P:\Jed-jcb\6289 Trowley NF\700 Drawings\703 Planning\800 - Substation\6289-PL-802-803_PROPOSED ELECTRICAL SUBSTATION_110kV.dwg