

CI.804 compacted in layers finished with screenings

Yellow Marker Warning Tape 500mm Wide ESBN Approved Material Only.

Backfill with selected backfill material compacted, (Max grain size 75mm) in layers of 150mm to avoid residual consolidation and to improve thermal properties.

I x Red Cable Marker Strip 400mm Wide x 2.5mm ESBN Approved Material Only.

12mm Diameter Pull Ropes in All Ducts.

I x Red Cable Marker Strip 400mm Wide x 2.5mm ESBN Approved Material Only.

Ducts laid in CBGM B (CL 822), Full tests required. Compacted to Cl. 813.10 of TII specification for roadworks (15n/mm² after 7

12mm Diameter Pull Ropes in All Ducts.

A = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6

B = 160mm: Outer Diameter HDPE ESB Approved Duct, SDR= 21

C = 125mm: Outer Diameter HDPE ESB Approved Duct, SDR=17.6

Section Through Access Road

SCALE 1:10

Note:

- This drawing is to be read in conjunction with relevant drawings, specifications and reports
- Dimensions are in millimeters, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNERS REQUIREMENTS



Head Office Beenreigh, Abbeydorney, Tralee, Co. Kerry Ireland Tel: 00353 66 7135710 CLIENT

Futur=nergy

Scart Mountain Wind Farm
110 kV Grid Connection

PROJECT NUMBER 05-854

SHEET NUMBER 05854-DR-207

SHEET TITLE

Ducting through Access Road

DRAWING STATUS
For Planning

ISSUE/REVISION		
P1	09.11.2023	Issued for Planning
I/R	DATE	DESCRIPTION