



GENERAL NOTES

ANY DISCREPANCIES OR OMISSIONS TO BE REPORTED TO JAK CONSULTING ENGINEERS IMMEDIATELY.


DO NOT SCALE - WORK FROM FIGURED DIMENSIONS ONLY.


THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL CIVIL ENGINEERS, STRUCTURAL ENGINEERS, ARCHITECTS & ALL OTHER RELEVANT DRAWINGS & SPECIFICATIONS RELATING TO THE PROJECT.


ALL DIMENSIONS TO BE CONFIRMED ON SITE.


THIS DRAWING IS THE PROPERTY OF JAK CONSULTING ENGINEERS AND IT OR ITS CONTENTS CANNOT BE COPIED, REPRODUCED OR OTHERWISE USED WITHOUT THE PERMISSION & CONSENT OF JAK CONSULTING ENGINEERS. ©

LEGEND:

 MICRO PILLAR (MCP-00)

 DENOTES NEW 110mmØ PUBLIC LIGHTING DUCT ROUTE

 DENOTES EXISTING 110mmØ PUBLIC LIGHTING DUCT ROUTE

 NEW ESB MINIPILLAR & CHAMBER

PUBLIC LIGHTING NOTES:

- This Public Lighting Scheme for the development has been designed to provide high quality public lighting throughout the public realm of the site. The external lighting design for this development has been designed by an independent lighting design specialist (VeeLite Lighting Ltd.) to achieve the necessary performance requirements as set out in the following standards:
 - National Rules for Electrical Installation IS10101:2020
 - BS8300:2018 Design of an accessible and inclusive built environment
 - Dun Laoghaire Rathdown County Council Public Lighting In Residential and Industrial Areas Guidance Document: January 2022
 - Institution of Lighting Professionals - Guidance for the Reduction of Obtrusive Light GN01:2011
 - BS EN 13201-2 (2015), Road Lighting Part 2:Performance Requirements
 - BS5489-1 (2013) Code of Practice for the Design of Road Lighting
 - Chartered Institution of Building Services Engineers - Lighting Guide 6: The Exterior Environment
 - Bats and Lighting - Guidance Notes for Planners, Engineers, Architects and Developers (Bat Conservation Ireland, 2010). Subject To Report Findings
 - Bats and Lighting in the UK-Bats and the Built Environment Series (Institute of Lighting Professionals, 2018, Subject To Report Findings
- Ducting shall comply with BSEN 50086-1-2-3-4 latest edition & shall be single wall, coloured RED & manufactured from high density Polypropylene. The nominal external diameter of the duct shall be 107mm with a minimal wall thickness of 5mm. Each length of duct shall be stamped with the words "Public Lighting" or alternatively "Street Lighting", in 18mm BLACK lettering at 0° degrees text alignment. At one metre intervals, duct shall be laid with this legend facing upwards. Duct shall be laid in a straight line close to the line of the column locations and shall contain a continuous draw-wire of 8KN strength. All ducts shall be proven with brush and mandrill. Polypropylene roped and plugged and compliant with IS 10101 requirements. RED Duct shall be used for exteriors lighting cables.
- A minimum depth of 450mm covers is required in Urban Pathways & a minimum of 600mm cover is required for grass margins, pedestrian ways, laneways and gateway entrances & a minimum depth of 750mm is required at road crossings or in carriageways.
- All equipment to be suitably I.P. rated for the environment they are being installed.
- All electrical supplies to the Public Lighting Scheme shall be from un-metered Micro-Pillars, Supplied From Mini-Pillars as shown. The proposed Public Lighting Scheme is to be Taken In Charge by Dunlaoghaire Rathdown County Council Public Lighting Division once all design has been accepted and verified.
- Lighting Column Setback shall be 0.8M from Kerb in accordance with BS5489-1 Table 2.
- Where necessary, the Contractor to include a Light Shield to be fitted on each luminaire to avoid Back Spill.

I01	INFORMATION	AB	MO	26/11/2025	
PL1	DRAFT PLANNING	AJ	ID	17/06/2025	
REV	Description	DRN	APP	Date	

JAK
Consulting Engineers

Mechanical, Electrical & Sustainability Consultants
DCC Centre
12 Camden Row, Dublin 8, Ireland

Ph: +353(1)479 0500
E: info@jak.ie
www.jak.ie

PROJECT/CLIENT:
CORNAMADDY, ATHLONE
RESIDENTIAL DEVELOPMENT

ARCHITECT:

DRAWING TITLE:
SITE SERVICES LAYOUT
PUBLIC LIGHTING SITE LUX LEVELS

DRAWING REFERENCE:
J727(6-J02)

DRAWING/PROJECT STATUS:
INFORMATION

REVISION REF:
I01

FILENAME:
J727(6-J01-02)

DATE:
26/11/2025

DRAWN:
AB

SCALE @ A1:
1:300