


Our Case Number: ACP-323932-25



**An
Coimisiún
Pleanála**

Uisce Éireann
Colvill House
24-26 Talbot Street
Dublin 1
D01 NP86

Date: 07 January 2026

Re: Proposed development comprising of 94 no dwelling units, Lissywollen, Westmeath
Lissywollen, County Westmeath

Dear Sir / Madam,


An Coimisiún Pleanála has received your recent submission in relation to the above mentioned proposed development and will take it into consideration in its determination of the matter.

Please note that the proposed development shall not be carried out unless the Commission has approved it with or without modifications.

If you have any queries in relation to the matter please contact the undersigned officer of the Commission at laps@pleanala.ie

Please quote the above mentioned An Coimisiún Pleanála reference number in any correspondence or telephone contact with the Commission.

Yours faithfully,


Lauren Griffin
Executive Officer
Direct Line: 01-8737244

AA02

Teil
Glao Áitiúil
Facs
Láithreán Gréasáin
Ríomhphost

Tel
LoCall
Fax
Website
Email

(01) 858 8100
1800 275 175
(01) 872 2684
www.pleanala.ie
communications@pleanala.ie

64 Sráid Maoilbhríde
Baile Átha Cliath 1
D01 V902

64 Marlborough Street
Dublin 1
D01 V902

Lauren Griffin

Subject: FW: An Coimisiún Pleanála - Case reference: JP25M.323932
Attachments: An Coimisiún Pleanála - Case reference JP25M323932.pdf

From: Planning <Planning@water.ie>
Sent: Tuesday 6 January 2026 15:30
To: SIDS <sids@pleanala.ie>
Subject: An Coimisiún Pleanála - Case reference: JP25M.323932

Caution: This is an **External Email** and may have malicious content. Please take care when clicking links or opening attachments. When in doubt, contact the ICT Helpdesk.

Dear Sir/Madam,

In response to case An Coimisiún Pleanála - Case reference: JP25M.323932 relating to a Proposed development comprising of 94 no dwelling units, Lissywollen, Westmeath- <https://www.pleanala.ie/en-ie/case/323932>.

Please find attached Uisce Éireann's observations.

I hope you find this information helpful. If you have any queries please do not hesitate to contact me.

Kind regards,

Martha Gilligan
Planning Application Specialist

Uisce Éireann
Teach Colvill, 24–26 Sráid Thalbóid, Baile Átha Cliath 1, D01 NP86, Éire
Uisce Éireann
Colvill House, 24–26 Talbot Street, Dublin 1, D01 NP86, Ireland
T + 01 932 5582
M +353 86 932 5582
jbloggs@water.ie
www.water.ie
[Facebook](#) | [Twitter](#) | [LinkedIn](#)

Is don duine amháin nó don eintiteas amháin ainmnithe ar an seoladh an fhaisnéis agus d'fhéadfadh ábhar faoi rún, faoi phribhléid nó ábhar atá íogair ó thaobh na tráchtála de a bheith mar chuid den fhaisnéis. Tá toirmeasc ar aon daoine nó aon eitis; nach dóibh siúd an fhaisnéis- aon athbhreithniú a dhéanamh, aon atarchur a dhéanamh nó aon athdháileadh a dhéanamh, nó aon úsáid eile a bhaint as an bhfaisnéis, nó aon ghníomh a bhraithfeadh ar an bhfaisnéis seo a dhéanamh agus d'fhéadfaí an dlí a shárú dá ndéanfaí sin. Séanann Uisce Éireann dliteanas as aon ghníomh agus as aon iarmhairt

bunaithe ar úsáid neamhúdraithe na faisnéise seo. Séanann Uisce Éireann dliteanas maidir le seachadadh iomlán agus ceart na faisnéise sa chumarsáid seo agus séanann Uisce Éireann dliteanas maidir le haon mhoill a bhaineann leis an bhfaisnéis a fháil. Má tá an ríomh-phost seo faighte agat trí dhearmad, déan teagmháil leis an seoltóir más é do thoil é agus scríos an t-ábhar ó gach aon ríomhaire. D'fhéadfadh ríomhphost a bheith so-ghabhálach i leith truailithe, idircheaptha agus i leith leasuithe neamhúdraithe. Séanann Uisce Éireann aon fhreagracht as athruithe nó as idircheapadh a rinneadh ar an ríomhphost seo nó as aon dochar do chórais na bhfaighteoirí déanta ag an teachtaireacht seo nó ag a ceangaltáin tar éis a sheolta. Tabhair faoi deara go bhféadfadh monatóireacht a bheith á dhéanamh ar theachtairreachtaí chuig Uisce Éireann agus ó Uisce Éireann d'fhonn ár ngnó a chosaint agus chun a chinntiú go bhfuiltear ag teacht le beartais agus le caighdeáin Uisce Éireann. Is cuideachta gníomhaíochta ainmnithe é Uisce Éireann atá faoi theorainn scaireanna, a bunaíodh de bhun fhorálacha na n-Achtanna um Sheirbhísí Uisce 2007-2022, a bhfuil a bpríomh-ionad gnó ag Teach Colvill, 24-26 Sráid na Talbóide, BÁC 1.

Go raibh maith agat as d'aird a thabhairt.

The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential, commercially sensitive and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited and may be unlawful. Uisce Éireann accepts no liability for actions or effects based on the prohibited usage of this information. Uisce Éireann is neither liable for the proper and complete transmission of the information contained in this communication nor for any delay in its receipt. If you received this in error, please contact the sender and delete the material from any computer. E-Mail may be susceptible to data corruption, interception and unauthorised amendment. Uisce Éireann accepts no responsibility for changes to or interception of this e-mail after it was sent or for any damage to the recipients systems or data caused by this message or its attachments. Please also note that messages to or from Uisce Éireann may be monitored to ensure compliance with Uisce Éireann's policies and standards and to protect our business. Uisce Éireann is a designated activity company limited by shares, established pursuant to the Water Services Acts 2007-2022, having its principal place of business at Colvill House, 24-26 Talbot Street, Dublin 1.

Thank you for your attention.

Is don duine amháin nó don eintiteas amháin ainmnithe ar an seoladh an fhaisnéis agus d'fhéadfadh ábhar faoi rún, faoi phribhléid nó ábhar atá íogair ó thaobh na tráchtála de a bheith mar chuid den fhaisnéis. Tá toirmeasc ar aon daoine nó aon eititis; nach dóibh siúd an fhaisnéis- aon athbhreithniú a dhéanamh, aon atarchur a dhéanamh nó aon athdháileadh a dhéanamh, nó aon úsáid eile a bhaint as an bhfaisnéis, nó aon ghníomh a bhraithfeadh ar an bhfaisnéis seo a dhéanamh agus d'fhéadfaí an dlí a shárú dá ndéanfaí sin. Séanann Uisce Éireann dliteanas as aon ghníomh agus as aon iarmhairt bunaithe ar úsáid neamhúdraithe na faisnéise seo. Séanann Uisce Éireann dliteanas maidir le seachadadh iomlán agus ceart na faisnéise sa chumarsáid seo agus séanann Uisce Éireann dliteanas maidir le haon mhoill a bhaineann leis an bhfaisnéis a fháil. Má tá an ríomh-phost seo faighte agat trí dhearmad, déan teagmháil leis an seoltóir más é do thoil é agus scríos an t-ábhar ó gach aon ríomhaire. D'fhéadfadh ríomhphost a bheith so-ghabhálach i leith truailithe, idircheaptha agus i leith leasuithe neamhúdraithe. Séanann Uisce Éireann aon fhreagracht as athruithe nó as

idircheapadh a rinneadh ar an ríomhphost seo nó as aon dochar do chórais na bhfaighteoírí déanta ag an teachtaireacht seo nó ag a ceangaltáin tar éis a sheolta. Tabhair faoi deara go bhféadfadh monatóireacht a bheith á dhéanamh ar theachtairreachtaí chuig Uisce Éireann agus ó Uisce Éireann d'fhonn ár ngnó a chosaint agus chun a chinntiú go bhfuiltear ag teacht le beartais agus le caighdeáin Uisce Éireann. Is cuideachta gníomhaíochta ainmnithe é Uisce Éireann atá faoi theorainn scaireanna, a bunaíodh de bhun fhorálacha na n-Achtanna um Sheirbhísí Uisce 2007-2022, a bhfuil a bpríomh-ionad gnó ag Teach Colvill, 24-26 Sráid na Talbóide, BÁC 1.

Go raibh maith agat as d'aird a thabhairt.

The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential, commercially sensitive and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited and may be unlawful. Uisce Éireann accepts no liability for actions or effects based on the prohibited usage of this information. Uisce Éireann is neither liable for the proper and complete transmission of the information contained in this communication nor for any delay in its receipt. If you received this in error, please contact the sender and delete the material from any computer. E-Mail may be susceptible to data corruption, interception and unauthorised amendment. Uisce Éireann accepts no responsibility for changes to or interception of this e-mail after it was sent or for any damage to the recipients systems or data caused by this message or its attachments. Please also note that messages to or from Uisce Éireann may be monitored to ensure compliance with Uisce Eireann's policies and standards and to protect our business. Uisce Éireann is a designated activity company limited by shares, established pursuant to the Water Services Acts 2007-2022, having its principal place of business at Colvill House, 24-26 Talbot Street, Dublin 1.

Thank you for your attention.

Uisce Éireann's Ref: PN25000035364

Planning Ref: An Coimisiún Pleanála - Case reference: JP25M.323932

Planning Authority: Westmeath County Council

Issue Date: 6 January 2026

Uisce Éireann
Bosca OP 448
Oifig Sheachadta na
Cathrach Theas
Cathair Chorcaí

Uisce Éireann
PO Box 448
South City
Delivery Office
Cork City

www.water.ie

Development Location: Lissywollen, County Westmeath

Development Description: Proposed development comprising of 94 no dwelling units, Lissywollen, Westmeath

A Chara,

Uisce Éireann (UE) has reviewed the plans and particulars submitted with the application and has the following observations;

The applicant has engaged with Uisce Éireann via a Pre-Connection Enquiry (our ref.: CDS24008612) and Uisce Éireann can confirm that a Confirmation of Feasibility has been issued to the applicant advising that a water connection is feasible subject to upgrades and that a wastewater connection is feasible subject to land access agreements.

Uisce Éireann respectfully requests any grant of permission be conditioned as follows;

1. The applicant shall enter into a Connection Agreement with Uisce Éireann to provide for service connections to the public water supply and wastewater collection network and adhere to the standards and conditions set out in that agreement.
2. The applicant / developer shall fund the extension of the potable water network required to provide a connection to the proposed development - approximately 210 metres of 150mm diameter watermain - in accordance with the particulars of the Connection Agreement.
3. The Uisce Éireann owned foul network is located in private lands to the Northwest of the proposed development site. Prior to commencement, the applicant shall secure permission from the private land owner to allow for the connection works to be undertaken by Uisce Éireann contractors.
4. The applicant shall obtain any permissions/consents and wayleaves for the connection pipework within third party lands.
5. All development shall be carried out in compliance with Uisce Éireann's Standard Details and Codes of Practice.

Stiúrthóirí / Directors: Jerry Grant (Cathaoirleach / Chairperson), Niall Gleeson (POF / CEO), Gerard Britchfield, Douglas Millican, Michael Nolan, Patricia King, Eileen Maher, Cathy Mannion, Paul Reid, Michael Walsh.

Oifig Chláraithe / Registered Office: Teach Colvill, 24-26 Sráid Thalbóid, Baile Átha Cliath 1, D01 NP86 / Colvill House, 24-26 Talbot Street, Dublin, Ireland D01NP86
Is cuideachta ghníomhaíochta ainmnithe atá faoi theorainn scaireanna é Uisce Éireann / Uisce Éireann is a designated activity company, limited by shares.
Cláraithe in Éirinn Uimh.: 530363 / Registered in Ireland No.: 530363.

6. Uisce Éireann does not permit Build Over of its assets. Where the applicant proposes to build over or divert existing water or wastewater services the applicant shall have received written Confirmation of Feasibility (COF) of Diversion(s) from Uisce Éireann prior to any works commencing.

To ensure adequate provision and protection of water and wastewater facilities, Uisce Éireann recommends the following;

1. Where the applicant seeks a connection to the public network, the applicant shall enter into a connection agreement with Uisce Éireann prior to the commencement of the development and adhere to the standards and conditions set out in that agreement.
2. There shall be no build over of public infrastructure from these proposals. Separation distances as per Uisce Éireann's Standards Codes & Practices shall be achieved where public infrastructure is in situ within and/or adjacent to site boundaries*.
3. The development shall not impact public drinking water sources and/or abstraction point(s) and/or abstraction infrastructure**.
4. The design and construction of the Water & Wastewater pipes and related infrastructure to be installed in this Development shall comply with the Uisce Éireann Connections and Developer Services Standard Details and Codes of Practice.

Queries relating to the terms and observations above should be directed to planning@water.ie

Yours sincerely,



Dermot Phelan
Connections and Developer Services

Advisory Note(s):

*Uisce Éireann does not permit build over of its assets. Separation distances from public infrastructure, as per Uisce Éireann's Standards Codes and Practices must be achieved. It is the applicant's responsibility to submit a diversion enquiry to Uisce Éireann Diversions Section (diversions@water.ie) prior to construction, where a potential build over of public assets is in question and/or where the applicants proposals cannot achieve separation distances from public infrastructure as per UÉ Standards & Codes of Practice.

** Protection of drinking water source(s) from potentially adverse impacts is a priority for Uisce Éireann. It is Uisce Éireann's current policy to maintain safe and secure drinking water supplies and ensure that development will not give rise to any deterioration in water quality. Development proposals shall not impact public drinking water sources and/or abstraction point(s). It is also a requirement of the Water Framework Directive that waters used for the abstraction of drinking water are protected to avoid deterioration in quality. Development proposals shall not impact public drinking water sources and/or abstraction point(s).

Any person discharging trade effluent** to a sewer, must have a Trade Effluent License issued pursuant to section 16 of the Local Government (Water Pollution) Act, 1977 (as amended). More information and an application form for a Trade Effluent License can be found at the following

link: <https://www.water.ie/business/trade-effluent/about/> . Trade effluent is defined in the Local Government (Water Pollution) Act, 1977 (as amended).

Uisce Éireann does not permit surface waters into the public sewer network.

Uisce Éireann's Ref: PN25000034326

Planning Ref: Part X for the Development of 94 no. dwelling units at (Cornamddy, Athlone)

Planning Authority: Westmeath County Council

Issue Date: 7 January 2026

Uisce Éireann
Bosca OP 448
Oifig Sheachadta na
Cathrach Theas
Cathair Chorcaí

Uisce Éireann
PO Box 448
South City
Delivery Office
Cork City

www.water.ie

Development Location: Cornamddy, Athlone) lands 150m north of the N55, Lissywollen Td., Athlone, co. Westmeath

Development Description: Part X for the Development of 94 no. dwelling units at (Cornamddy, Athlone) lands 150m north of the N55, Lissywollen Td., Athlone, co. Westmeath

A Chara,

Uisce Éireann (UÉ) has reviewed the plans and particulars submitted with the application and has the following observations;

The applicant has engaged with Uisce Éireann via a Pre-Connection Enquiry (our ref.: CDS24008612) and Uisce Éireann can confirm that a Confirmation of Feasibility has been issued to the applicant advising that a water connection is feasible subject to upgrades and that a wastewater connection is feasible subject to land access agreements.

Uisce Éireann respectfully requests any grant of permission be conditioned as follows;

1. The applicant shall enter into a Connection Agreement with Uisce Éireann to provide for service connections to the public water supply and wastewater collection network and adhere to the standards and conditions set out in that agreement.
2. The applicant / developer shall fund the extension of the potable water network required to provide a connection to the proposed development - approximately 210 metres of 150mm diameter watermain - in accordance with the particulars of the Connection Agreement.
3. The Uisce Éireann owned foul network is located in private lands to the Northwest of the proposed development site. Prior to commencement, the applicant shall secure permission from the private land owner to allow for the connection works to be undertaken by Uisce Éireann contractors.
4. The applicant shall obtain any permissions/consents and wayleaves for the connection pipework within third party lands.

5. All development shall be carried out in compliance with Uisce Éireann's Standard Details and Codes of Practice.

6. Uisce Éireann does not permit Build Over of its assets. Where the applicant proposes to build over or divert existing water or wastewater services the applicant shall have received written Confirmation of Feasibility (COF) of Diversion(s) from Uisce Éireann prior to any works commencing.

To ensure adequate provision and protection of water and wastewater facilities, Uisce Éireann recommends the following;

1. Where the applicant seeks a connection to the public network, the applicant shall enter into a connection agreement with Uisce Éireann prior to the commencement of the development and adhere to the standards and conditions set out in that agreement.
2. There shall be no build over of public infrastructure from these proposals. Separation distances as per Uisce Éireann's Standards Codes & Practices shall be achieved where public infrastructure is in situ within and/or adjacent to site boundaries*.
3. The development shall not impact public drinking water sources and/or abstraction point(s) and/or abstraction infrastructure**.
4. The design and construction of the Water & Wastewater pipes and related infrastructure to be installed in this Development shall comply with the Uisce Éireann Connections and Developer Services Standard Details and Codes of Practice.

Queries relating to the terms and observations above should be directed to planning@water.ie

Yours sincerely,



Dermot Phelan
Connections and Developer Services

Advisory Note(s):

*Uisce Éireann does not permit build over of its assets. Separation distances from public infrastructure, as per Uisce Éireann's Standards Codes and Practices must be achieved. It is the applicant's responsibility to submit a diversion enquiry to Uisce Éireann Diversions Section (diversions@water.ie) prior to construction, where a potential build over of public assets is in question and/or where the applicants proposals cannot achieve separation distances from public infrastructure as per UÉ Standards & Codes of Practice.

** Protection of drinking water source(s) from potentially adverse impacts is a priority for Uisce Éireann. It is Uisce Éireann's current policy to maintain safe and secure drinking water supplies and ensure that development will not give rise to any deterioration in water quality. Development proposals shall not impact public drinking water sources and/or abstraction point(s). It is also a requirement of the Water Framework Directive that waters used for the abstraction of drinking water are protected to avoid deterioration in quality. Development proposals shall not impact public drinking water sources and/or abstraction point(s).

Any person discharging trade effluent** to a sewer, must have a Trade Effluent License issued pursuant to section 16 of the Local Government (Water Pollution) Act, 1977 (as amended). More

information and an application form for a Trade Effluent License can be found at the following link: <https://www.water.ie/business/trade-effluent/about/> . Trade effluent is defined in the Local Government (Water Pollution) Act, 1977 (as amended).

Uisce Éireann does not permit surface waters into the public sewer network.