



APPENDIX 12-7

PREDICTED NOISE LEVELS

APPENDIX 12-7. PREDICTED CUMULATIVE NOISE LEVELS

Table 12-7-1 presents the cumulative predicted noise levels among the scenarios for each NSL and windspeed.

Table 12-7-1. Predicted Noise Level at Noise-sensitive locations

House	Parameter	Predicted Noise Level, dB L _{A90} , at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H001	Predicted	17.9	20.2	24.0	28.3	28.7	28.9	28.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H002	Predicted	18.0	20.2	24.1	28.4	28.8	29.0	29.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H003	Predicted	18.4	20.6	24.5	28.8	29.2	29.4	29.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H004	Predicted	18.4	20.7	24.5	28.8	29.2	29.4	29.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H005	Predicted	18.9	21.2	25.1	29.4	29.8	30.0	30.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H006	Predicted	18.7	21.0	24.9	29.2	29.6	29.8	29.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H007	Predicted	19.0	21.3	25.2	29.5	29.9	30.1	30.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H008	Predicted	19.4	21.7	25.6	29.9	30.3	30.5	30.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H009	Predicted	19.4	21.7	25.6	29.9	30.3	30.5	30.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H010	Predicted	19.6	21.9	25.8	30.1	30.5	30.7	30.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H011	Predicted	19.8	22.0	26.0	30.3	30.6	30.8	30.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H012	Predicted	20.2	22.5	26.4	30.7	31.1	31.4	31.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H013	Predicted	20.3	22.6	26.6	30.9	31.2	31.5	31.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H014	Predicted	20.1	22.4	26.4	30.7	31.1	31.3	31.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H015	Predicted	20.2	22.6	26.5	30.8	31.2	31.4	31.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H016	Predicted	20.3	22.6	26.5	30.8	31.2	31.4	31.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H017	Predicted	21.4	23.4	27.3	31.4	32.0	32.2	32.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H018	Predicted	21.4	23.4	27.3	31.4	32.0	32.2	32.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H019	Predicted	20.5	22.8	26.8	31.1	31.5	31.7	31.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H020	Predicted	22.2	24.1	28.0	32.0	32.7	32.9	33.0
	Daytime Criterion	40	40	40	40	45	45	45

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H021	Predicted	22.1	24.1	28.0	32.0	32.7	32.8	33.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H022	Predicted	22.3	24.3	28.2	32.2	32.8	33.0	33.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H023	Predicted	20.5	22.8	26.8	31.1	31.4	31.6	31.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H024	Predicted	20.6	23.0	26.9	31.2	31.6	31.8	31.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H025	Predicted	22.4	24.4	28.3	32.3	33.0	33.2	33.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H026	Predicted	20.5	22.8	26.8	31.1	31.5	31.7	31.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H027	Predicted	20.5	22.8	26.8	31.1	31.5	31.7	31.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H028	Predicted	22.2	24.5	28.6	32.8	33.2	33.5	33.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H029	Predicted	20.5	22.8	26.8	31.1	31.5	31.7	31.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H030	Predicted	22.3	24.6	28.6	32.9	33.3	33.6	33.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Excess	--	--	--	--	--	--	--
H031	Predicted	23.0	25.3	29.3	33.5	34.0	34.2	34.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H032	Predicted	23.3	25.3	29.2	33.3	33.9	34.1	34.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H033	Predicted	23.4	25.4	29.4	33.4	34.1	34.2	34.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H034	Predicted	23.4	25.6	29.7	33.9	34.4	34.6	34.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H035	Predicted	23.5	25.6	29.5	33.6	34.2	34.4	34.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H036	Predicted	23.5	25.8	29.8	34.0	34.5	34.7	34.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H037	Predicted	20.8	23.0	27.0	31.4	31.7	31.9	31.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H038	Predicted	23.6	25.7	29.6	33.7	34.3	34.5	34.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H039	Predicted	23.7	25.7	29.7	33.8	34.4	34.6	34.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H040	Predicted	23.8	26.0	30.0	34.2	34.7	34.9	35.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H041	Predicted	23.7	26.0	30.0	34.2	34.7	34.9	34.9

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H042	Predicted	20.7	23.0	27.0	31.3	31.7	31.9	31.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H043	Predicted	24.0	26.2	30.2	34.5	34.9	35.1	35.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H044	Predicted	17.8	20.1	24.0	28.3	28.7	28.9	28.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H045	Predicted	23.7	25.5	29.4	33.1	34.2	34.3	34.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H046	Predicted	24.1	26.3	30.4	34.6	35.1	35.3	35.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H047	Predicted	18.2	20.5	24.4	28.7	29.1	29.3	29.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H048	Predicted	24.0	26.3	30.4	34.7	35.1	35.3	35.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H049	Predicted	24.3	26.5	30.6	34.8	35.2	35.5	35.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H050	Predicted	24.0	26.1	30.1	34.2	34.8	35.0	35.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H051	Predicted	24.6	26.9	31.1	35.4	35.8	36.0	36.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H052	Predicted	20.7	23.0	27.0	31.3	31.7	31.9	31.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H053	Predicted	18.8	21.1	25.0	29.3	29.7	29.9	29.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H054	Predicted	24.2	26.3	30.3	34.5	35.0	35.2	35.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H055	Predicted	24.4	26.6	30.6	34.9	35.3	35.6	35.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H056	Predicted	24.6	26.9	30.9	35.2	35.6	35.8	35.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H057	Predicted	24.6	26.8	31.0	35.3	35.7	35.9	35.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H058	Predicted	20.9	23.2	27.2	31.5	31.9	32.1	32.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H059	Predicted	24.8	27.0	31.0	35.3	35.7	36.0	36.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H060	Predicted	25.1	27.4	31.5	35.8	36.2	36.4	36.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H061	Predicted	24.9	27.2	31.2	35.5	35.9	36.2	36.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H062	Predicted	24.6	26.8	30.8	35.0	35.5	35.7	35.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H063	Predicted	25.3	27.5	31.7	36.0	36.4	36.6	36.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H064	Predicted	24.9	27.1	31.1	35.4	35.8	36.0	36.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H065	Predicted	24.2	26.0	29.9	33.7	34.7	34.8	35.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H066	Predicted	25.6	27.9	32.1	36.4	36.8	37.0	37.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H067	Predicted	19.5	21.8	25.8	30.0	30.4	30.6	30.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H068	Predicted	21.0	23.2	27.2	31.6	31.9	32.2	32.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H069	Predicted	25.6	27.9	32.1	36.4	36.8	37.0	37.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H070	Predicted	25.8	28.0	32.2	36.5	36.9	37.1	37.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H071	Predicted	25.2	27.4	31.5	35.7	36.2	36.4	36.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H072	Predicted	25.3	27.5	31.6	35.8	36.3	36.5	36.5
	Daytime Criterion	40	40	40	40	45	45	45

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H073	Predicted	26.2	28.5	32.7	37.0	37.4	37.6	37.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H074	Predicted	25.3	27.5	31.6	35.8	36.3	36.5	36.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H075	Predicted	20.3	22.6	26.6	30.9	31.2	31.5	31.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H076	Predicted	25.8	28.0	32.2	36.4	36.8	37.0	37.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H077	Predicted	24.6	26.5	30.4	34.2	35.2	35.4	35.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H078	Predicted	19.8	22.1	26.0	30.3	30.7	30.9	30.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H079	Predicted	27.1	29.4	33.7	38.0	38.4	38.6	38.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H080	Predicted	21.0	23.4	27.3	31.6	32.0	32.2	32.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H081	Predicted	18.7	21.0	24.9	29.2	29.6	29.8	29.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H082	Predicted	27.4	29.7	34.0	38.3	38.7	38.9	38.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Excess	--	--	--	--	--	--	--
H083	Predicted	20.6	22.9	26.9	31.1	31.6	31.8	31.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H084	Predicted	24.0	25.8	29.8	33.4	34.7	34.7	34.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H085	Predicted	24.5	26.4	30.4	34.0	35.3	35.3	35.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H086	Predicted	24.0	25.8	29.8	33.4	34.7	34.8	34.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H087	Predicted	26.1	28.3	32.5	36.7	37.2	37.4	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H088	Predicted	24.0	25.9	29.8	33.4	34.7	34.8	34.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H089	Predicted	23.9	25.7	29.7	33.3	34.6	34.7	34.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H090	Predicted	24.7	26.6	30.5	34.2	35.4	35.5	35.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H091	Predicted	24.9	26.7	30.7	34.4	35.6	35.6	35.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H092	Predicted	28.3	30.7	35.0	39.3	39.7	39.9	39.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H093	Predicted	26.2	28.3	32.4	36.6	37.1	37.3	37.4

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H094	Predicted	29.2	31.5	35.9	40.2	40.6	40.8	40.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.2	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H095	Predicted	25.0	27.0	30.9	34.8	35.7	35.8	36.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H096	Predicted	26.5	28.6	32.7	36.9	37.4	37.6	37.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H097	Predicted	28.5	30.8	35.2	39.5	39.9	40.1	40.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H098	Predicted	27.6	30.0	34.3	38.6	39.0	39.2	39.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H099	Predicted	24.0	26.4	30.5	34.7	35.2	35.4	35.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H100	Predicted	24.9	26.8	30.8	34.5	35.7	35.8	35.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H101	Predicted	18.3	20.7	24.6	28.7	29.2	29.5	29.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H102	Predicted	25.7	27.6	31.6	35.3	36.4	36.5	36.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H103	Predicted	27.8	30.1	34.3	38.6	39.0	39.2	39.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H104	Predicted	28.2	30.5	34.8	39.1	39.5	39.7	39.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H105	Predicted	21.4	23.9	27.9	32.0	32.5	32.8	32.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H106	Predicted	26.5	28.9	33.2	37.4	37.8	38.0	38.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H107	Predicted	28.4	30.6	34.9	39.2	39.6	39.8	39.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H108	Predicted	21.3	23.8	27.8	31.9	32.4	32.7	32.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H109	Predicted	26.0	28.4	32.7	36.9	37.3	37.5	37.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H110	Predicted	27.0	29.4	33.7	38.0	38.4	38.6	38.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H111	Predicted	26.3	28.3	32.4	36.4	37.1	37.3	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H112	Predicted	26.0	28.1	32.1	36.1	36.8	37.0	37.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H113	Predicted	26.1	28.1	32.1	36.1	36.9	37.0	37.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H115	Predicted	26.7	29.1	33.4	37.6	38.0	38.2	38.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H116	Predicted	26.1	28.5	32.7	36.9	37.3	37.6	37.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H117	Predicted	26.2	28.2	32.3	36.3	37.0	37.2	37.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H118	Predicted	24.7	27.2	31.3	35.5	35.9	36.2	36.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H119	Predicted	28.6	30.9	35.1	39.4	39.8	40.0	40.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H120	Predicted	25.9	27.8	31.8	35.7	36.6	36.8	36.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H121	Predicted	29.7	32.0	36.3	40.6	41.0	41.2	41.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H122	Predicted	29.1	31.3	35.6	39.8	40.2	40.4	40.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H123	Predicted	30.4	32.6	37.0	41.3	41.7	41.9	41.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.3	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H124	Predicted	25.4	27.9	32.1	36.2	36.7	36.9	37.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H125	Predicted	24.7	27.2	31.3	35.5	36.0	36.2	36.2
	Daytime Criterion	40	40	40	40	45	45	45

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H126	Predicted	21.6	24.2	28.2	32.2	32.8	33.1	33.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H127	Predicted	25.4	27.4	31.4	35.1	36.4	36.5	36.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H128	Predicted	25.3	27.3	31.3	35.0	36.3	36.4	36.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H129	Predicted	20.3	22.9	26.9	30.8	31.4	31.8	31.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H130	Predicted	26.9	28.9	32.9	36.8	37.7	37.8	37.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H131	Predicted	24.4	26.9	31.0	35.2	35.6	35.9	35.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H132	Predicted	25.4	27.4	31.4	35.1	36.4	36.4	36.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H134	Predicted	18.5	21.2	25.1	28.9	29.6	30.0	30.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H135	Predicted	29.6	32.0	36.4	40.6	41.0	41.2	41.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H136	Predicted	27.2	29.3	33.3	37.3	38.1	38.2	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Excess	--	--	--	--	--	--	--
H137	Predicted	24.6	26.7	30.7	34.4	35.6	35.7	35.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H138	Predicted	23.9	25.9	29.9	33.7	34.9	35.0	35.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H139	Predicted	30.8	33.1	37.4	41.7	42.1	42.3	42.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.7	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H140	Predicted	26.5	28.6	32.6	36.3	37.6	37.6	37.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H141	Predicted	24.0	26.0	30.0	33.8	34.9	35.0	35.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H142	Predicted	24.0	26.0	30.0	33.8	35.0	35.1	35.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H143	Predicted	28.1	30.5	34.8	39.0	39.4	39.7	39.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H144	Predicted	19.1	21.8	25.8	29.5	30.2	30.7	30.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H145	Predicted	31.0	33.3	37.6	41.9	42.3	42.5	42.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.9	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H146	Predicted	21.2	23.9	27.9	31.8	32.4	32.8	32.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H147	Predicted	19.3	22.0	26.0	29.7	30.4	30.9	30.9

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H148	Predicted	31.5	33.8	38.2	42.5	42.9	43.0	43.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	2.5	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	0.1
H150	Predicted	31.3	33.7	38.1	42.4	42.8	42.9	42.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	2.4	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H151	Predicted	31.4	33.6	38.0	42.3	42.7	42.9	42.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	2.3	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H152	Predicted	31.2	33.6	38.0	42.2	42.6	42.8	42.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H153	Predicted	19.3	22.0	26.0	29.7	30.5	30.9	31.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H154	Predicted	19.3	22.1	26.1	29.8	30.5	31.0	31.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H155	Predicted	20.1	22.8	26.8	30.5	31.2	31.7	31.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H156	Predicted	29.0	31.1	35.3	39.4	40.0	40.2	40.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H157	Predicted	31.9	34.2	38.6	42.8	43.3	43.4	43.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	2.8	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	0.3	0.4	0.5
H158	Predicted	20.0	22.8	26.7	30.4	31.2	31.6	31.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H159	Predicted	20.6	23.4	27.3	31.1	31.8	32.2	32.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H160	Predicted	20.0	22.7	26.7	30.4	31.2	31.6	31.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H161	Predicted	32.0	34.3	38.7	43.0	43.4	43.6	43.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	3.0	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	0.4	0.6	0.6
H162	Predicted	29.0	31.1	35.2	38.9	40.2	40.3	40.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H163	Predicted	21.3	24.1	28.0	31.8	32.5	32.9	33.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H164	Predicted	32.1	34.3	38.8	43.0	43.4	43.6	43.6
	Daytime Criterion	40	40	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	0.4	0.6	0.6
H165	Predicted	20.8	23.6	27.6	31.3	32.0	32.4	32.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H166	Predicted	21.2	24.0	28.0	31.8	32.5	32.9	32.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H167	Predicted	26.8	29.3	33.5	37.6	38.1	38.4	38.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H168	Predicted	29.6	31.8	35.8	39.6	40.9	40.9	41.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H169	Predicted	21.5	24.2	28.2	32.0	32.7	33.1	33.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H170	Predicted	27.5	29.6	33.7	37.7	38.5	38.6	38.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H171	Predicted	20.8	23.7	27.6	31.3	32.0	32.5	32.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H173	Predicted	22.2	24.8	28.8	32.8	33.4	33.7	33.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H174	Predicted	29.9	32.3	36.6	40.8	41.2	41.4	41.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.8	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H175	Predicted	22.1	24.8	28.7	32.6	33.2	33.6	33.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H176	Predicted	22.2	24.8	28.8	32.8	33.4	33.7	33.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H177	Predicted	25.2	27.3	31.3	35.1	36.2	36.3	36.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H178	Predicted	20.8	23.7	27.6	31.3	32.1	32.5	32.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H179	Predicted	23.3	25.9	29.9	33.9	34.5	34.8	34.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H180	Predicted	23.4	26.0	30.1	34.1	34.6	35.0	35.0
	Daytime Criterion	40	40	40	40	45	45	45

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H181	Predicted	23.4	26.0	30.0	34.0	34.6	34.9	34.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H182	Predicted	23.4	26.0	30.0	34.0	34.6	34.9	34.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H183	Predicted	20.8	23.8	27.7	31.3	32.1	32.6	32.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H184	Predicted	23.6	26.2	30.2	34.2	34.8	35.1	35.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H185	Predicted	24.6	27.2	31.2	35.2	35.8	36.0	36.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H186	Predicted	20.8	23.8	27.8	31.3	32.1	32.6	32.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H187	Predicted	24.9	27.4	31.5	35.5	36.0	36.3	36.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H188	Predicted	24.5	27.1	31.1	35.1	35.6	35.9	35.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H189	Predicted	20.8	23.9	27.8	31.3	32.2	32.7	32.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H190	Predicted	20.7	23.8	27.7	31.2	32.0	32.6	32.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Excess	--	--	--	--	--	--	--
H191	Predicted	28.1	30.2	34.2	38.2	39.1	39.2	39.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H192	Predicted	20.3	23.4	27.4	30.8	31.7	32.2	32.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H193	Predicted	28.1	30.2	34.2	38.1	39.1	39.2	39.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H194	Predicted	28.1	30.3	34.3	38.4	38.9	39.2	39.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H195	Predicted	26.0	28.4	32.5	36.5	37.0	37.3	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H196	Predicted	26.5	28.9	33.0	37.0	37.6	37.8	37.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H197	Predicted	29.1	31.3	35.5	39.6	40.3	40.4	40.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H198	Predicted	25.9	28.1	32.2	36.3	37.0	37.2	37.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H199	Predicted	27.6	29.9	33.9	37.9	38.5	38.7	38.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H200	Predicted	28.8	31.0	35.2	39.2	39.9	40.1	40.2
	Daytime Criterion	40	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H201	Predicted	29.0	31.3	35.3	39.4	39.9	40.1	40.1

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H202	Predicted	28.8	31.0	35.0	39.1	39.6	39.9	39.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H203	Predicted	29.0	31.2	35.4	39.5	40.1	40.3	40.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H204	Predicted	29.7	31.8	35.9	39.7	40.8	40.9	41.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H205	Predicted	29.4	31.7	35.7	39.8	40.3	40.5	40.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H206	Predicted	29.2	31.4	35.4	39.3	40.3	40.4	40.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H207	Predicted	26.0	28.3	32.4	36.4	37.1	37.3	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H208	Predicted	26.1	28.3	32.4	36.4	37.1	37.4	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H209	Predicted	29.4	31.5	35.6	39.4	40.5	40.6	40.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H210	Predicted	29.4	31.6	35.6	39.4	40.5	40.6	40.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H211	Predicted	29.7	31.9	35.9	39.8	40.9	41.0	41.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H212	Predicted	30.4	32.7	36.7	40.8	41.3	41.6	41.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.8	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H213	Predicted	25.4	27.6	31.6	35.5	36.3	36.6	36.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H214	Predicted	29.6	31.8	35.8	39.6	40.7	40.9	40.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H215	Predicted	31.2	33.5	37.5	41.6	42.1	42.3	42.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H216	Predicted	26.2	28.9	32.8	36.4	37.2	37.7	37.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H217	Predicted	22.3	25.5	29.4	32.6	33.6	34.3	34.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H218	Predicted	22.9	26.1	30.0	33.2	34.2	34.9	34.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H219	Predicted	29.3	31.7	35.4	39.2	39.9	40.2	40.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H220	Predicted	30.2	32.4	36.5	40.5	41.2	41.4	41.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.5	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H221	Predicted	26.7	29.4	33.3	36.9	37.7	38.1	38.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H222	Predicted	28.7	31.1	34.9	38.6	39.3	39.7	39.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H223	Predicted	22.6	25.8	29.8	32.9	34.0	34.6	34.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H224	Predicted	28.2	30.5	34.4	38.3	39.3	39.5	39.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H225	Predicted	22.8	26.0	29.9	33.0	34.1	34.8	34.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H226	Predicted	24.0	26.9	30.7	33.9	34.9	35.6	35.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H227	Predicted	34.0	36.2	40.4	44.5	45.0	45.2	45.3
	Daytime Criterion	40	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	0.2	0.3
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	1.5	2.0	2.2	2.3
H228	Predicted	27.1	30.0	33.8	37.3	38.2	38.7	38.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H229	Predicted	27.8	30.6	34.3	37.7	38.6	39.2	39.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H230	Predicted	30.2	32.6	36.3	39.9	40.7	41.1	41.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H231	Predicted	26.3	28.6	32.4	36.2	37.2	37.5	37.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H232	Predicted	30.9	33.1	36.7	40.6	41.2	41.5	41.6
	Daytime Criterion	40	40	40	40	45	45	45

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	0.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H233	Predicted	30.4	32.6	36.4	40.4	41.1	41.5	41.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.4	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H234	Predicted	30.6	32.8	36.7	40.7	41.4	41.8	41.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.7	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H235	Predicted	31.5	33.7	37.4	41.2	41.8	42.2	42.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.2	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H236	Predicted	31.0	33.2	36.8	40.6	41.2	41.6	41.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H237	Predicted	27.2	29.6	33.4	37.2	38.1	38.4	38.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H238	Predicted	26.6	29.8	33.6	36.7	37.8	38.5	38.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H239	Predicted	32.9	35.2	39.2	43.4	43.9	44.2	44.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	3.4	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	0.4	0.9	1.2	1.3
H240	Predicted	24.6	27.7	31.6	34.6	35.8	36.6	36.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H241	Predicted	25.6	28.7	32.6	35.6	36.7	37.5	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H242	Predicted	31.3	33.8	37.3	40.8	41.6	42.1	42.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.8	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Excess	--	--	--	--	--	--	--
H243	Predicted	32.8	35.1	39.1	43.2	43.7	44.0	44.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	3.2	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	0.2	0.7	1.0	1.1
H244	Predicted	32.6	34.9	38.9	43.0	43.5	43.9	44.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	3.0	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	0.5	0.9	1.0
H246	Predicted	31.6	34.1	37.6	41.3	42.0	42.4	42.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.3	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H247	Predicted	28.5	31.6	35.3	38.5	39.5	40.2	40.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H248	Predicted	31.5	33.8	37.2	40.8	41.6	42.0	42.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.8	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H249	Predicted	32.1	34.4	37.8	41.4	42.2	42.6	42.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.4	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H250	Predicted	32.2	34.6	37.9	41.5	42.3	42.7	42.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.5	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H251	Predicted	28.4	31.6	35.4	38.5	39.5	40.3	40.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H253	Predicted	32.7	34.9	38.2	41.6	42.5	42.9	43.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H254	Predicted	32.6	34.9	38.1	41.6	42.4	42.8	42.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H255	Predicted	28.3	31.6	35.4	38.4	39.5	40.3	40.3

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H256	Predicted	32.8	35.1	38.3	41.8	42.6	43.0	43.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.8	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	0.1
H257	Predicted	31.6	34.0	37.7	41.6	42.2	42.7	42.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H258	Predicted	30.7	33.7	37.4	40.6	41.6	42.2	42.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H259	Predicted	26.9	29.0	32.4	36.1	37.1	37.4	37.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H260	Predicted	24.4	27.5	31.3	34.2	35.4	36.2	36.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H261	Predicted	31.4	34.0	37.4	40.9	41.7	42.1	42.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.9	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H262	Predicted	33.3	35.5	38.7	42.1	43.0	43.4	43.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	2.1	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	0.4	0.5
H263	Predicted	26.3	28.3	31.7	35.3	36.4	36.7	36.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H264	Predicted	32.5	34.8	38.0	41.5	42.4	42.8	42.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.5	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H265	Predicted	26.8	28.9	32.2	35.8	36.9	37.2	37.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H266	Predicted	27.6	30.1	33.6	37.3	38.3	38.6	38.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H267	Predicted	25.6	28.6	32.4	35.4	36.6	37.4	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H268	Predicted	26.1	29.2	33.1	36.0	37.2	38.0	38.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H269	Predicted	27.0	29.0	32.4	35.9	37.0	37.4	37.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H270	Predicted	33.4	35.8	39.0	42.3	43.2	43.7	43.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	2.3	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	0.2	0.7	0.7
H271	Predicted	28.8	31.2	34.6	38.2	39.2	39.6	39.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H272	Predicted	27.6	29.7	32.9	36.5	37.5	37.9	38.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H273	Predicted	33.2	35.4	38.3	41.6	42.5	43.0	43.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	1.6	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	0.1
H274	Predicted	28.8	31.2	34.6	38.2	39.1	39.6	39.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H275	Predicted	27.7	30.0	33.2	36.8	37.8	38.2	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H276	Predicted	27.8	30.2	33.4	36.9	38.0	38.4	38.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H277	Predicted	28.8	31.2	34.3	37.8	38.9	39.3	39.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H278	Predicted	26.4	29.2	32.5	36.1	37.1	37.5	37.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H279	Predicted	27.2	29.8	33.0	36.5	37.5	38.0	38.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H280	Predicted	26.8	29.5	32.8	36.2	37.3	37.7	37.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H281	Predicted	26.8	29.6	32.8	36.3	37.4	37.8	37.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H282	Predicted	27.3	29.8	33.0	36.4	37.5	37.9	38.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H283	Predicted	28.7	31.1	34.3	37.8	38.8	39.2	39.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H284	Predicted	35.3	37.8	40.7	43.9	44.9	45.4	45.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	0.7	3.9	--	0.4	0.4
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	0.9	1.9	2.4	2.4
H285	Predicted	27.2	29.8	33.1	36.6	37.6	38.0	38.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H286	Predicted	27.1	29.8	33.0	36.4	37.5	37.9	38.0
	Daytime Criterion	40	40	40	40	45	45	45

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H287	Predicted	27.1	29.8	33.0	36.5	37.5	38.0	38.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H288	Predicted	27.3	29.8	32.9	36.4	37.4	37.9	38.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H289	Predicted	30.3	32.5	35.8	39.6	40.3	40.9	41.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H290	Predicted	28.3	30.8	34.1	37.6	38.6	39.0	39.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H291	Predicted	28.2	30.9	34.0	37.4	38.5	38.9	39.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H292	Predicted	27.5	30.1	33.2	36.6	37.7	38.2	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H293	Predicted	27.5	30.1	33.2	36.7	37.7	38.2	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H294	Predicted	28.3	30.8	34.0	37.5	38.5	39.0	39.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H295	Predicted	27.5	30.0	33.1	36.6	37.6	38.1	38.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H296	Predicted	27.9	30.3	33.3	36.7	37.8	38.2	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Excess	--	--	--	--	--	--	--
H297	Predicted	28.2	31.0	34.0	37.5	38.6	39.0	39.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H298	Predicted	29.8	32.0	35.3	39.0	39.8	40.4	40.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H299	Predicted	28.0	30.5	33.5	36.9	38.0	38.4	38.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H300	Predicted	35.5	37.8	40.8	43.8	44.9	45.4	45.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	0.8	3.8	--	0.4	0.4
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	0.8	1.9	2.4	2.4
H301	Predicted	28.2	30.7	33.7	37.1	38.2	38.6	38.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H302	Predicted	28.2	30.7	33.7	37.1	38.2	38.7	38.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H303	Predicted	28.2	30.7	33.7	37.1	38.2	38.7	38.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H304	Predicted	28.3	30.8	33.8	37.2	38.3	38.7	38.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H305	Predicted	28.3	30.8	33.8	37.2	38.3	38.8	38.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H306	Predicted	27.8	30.0	33.2	36.6	37.7	38.1	38.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H307	Predicted	27.7	29.9	33.0	36.5	37.6	38.0	38.1

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H308	Predicted	28.8	31.1	34.2	37.7	38.7	39.2	39.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H309	Predicted	29.3	31.6	34.8	38.4	39.3	39.9	40.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H310	Predicted	27.8	30.1	33.2	36.7	37.7	38.1	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H311	Predicted	27.2	29.4	32.4	36.0	37.0	37.4	37.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H312	Predicted	28.7	31.1	34.1	37.4	38.5	39.0	39.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H313	Predicted	27.1	29.3	32.4	35.9	36.9	37.3	37.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H314	Predicted	27.9	30.2	33.2	36.7	37.7	38.2	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H315	Predicted	27.5	29.7	32.8	36.3	37.3	37.7	37.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H316	Predicted	29.2	31.5	34.7	38.3	39.2	39.8	39.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H317	Predicted	28.7	31.2	34.1	37.5	38.6	39.0	39.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H318	Predicted	29.2	31.5	34.7	38.3	39.2	39.8	39.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H319	Predicted	27.2	29.3	32.4	35.9	36.9	37.3	37.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H320	Predicted	28.8	31.1	34.1	37.4	38.5	39.0	39.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H321	Predicted	28.0	30.2	33.3	36.7	37.7	38.2	38.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H322	Predicted	27.0	29.1	32.1	35.6	36.6	37.1	37.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H323	Predicted	27.0	29.0	32.1	35.5	36.6	37.0	37.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H324	Predicted	28.1	30.4	33.4	36.8	37.9	38.3	38.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H325	Predicted	26.9	28.8	31.9	35.4	36.4	36.8	37.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H326	Predicted	35.9	37.9	40.6	43.6	44.7	45.2	45.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	0.6	3.6	--	0.2	0.2
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	0.6	1.7	2.2	2.2
H327	Predicted	28.1	30.4	33.4	36.8	37.9	38.3	38.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
H328	Predicted	28.1	30.4	33.4	36.8	37.9	38.3	38.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H329	Predicted	28.1	30.4	33.4	36.8	37.9	38.3	38.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H330	Predicted	27.1	29.1	32.1	35.6	36.7	37.1	37.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H331	Predicted	36.4	38.3	40.9	43.9	45.0	45.4	45.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	0.9	3.9	--	0.4	0.5
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	0.9	2.0	2.4	2.5
H332	Predicted	36.4	38.3	40.9	43.9	45.0	45.4	45.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	0.9	3.9	--	0.4	0.5
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	0.9	2.0	2.4	2.5
H333	Predicted	26.9	28.9	31.9	35.4	36.4	36.8	37.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H334	Predicted	36.2	38.4	41.1	44.1	45.2	45.6	45.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	1.1	4.1	0.2	0.6	0.7
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	1.1	2.2	2.6	2.7
H335	Predicted	27.7	29.7	32.7	36.1	37.2	37.6	37.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H336	Predicted	28.1	30.0	32.8	36.2	37.3	37.7	37.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H337	Predicted	28.3	30.4	33.5	36.8	37.9	38.4	38.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H338	Predicted	26.9	28.8	31.9	35.4	36.4	36.8	36.9
	Daytime Criterion	40	40	40	40	45	45	45

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H339	Predicted	27.2	29.3	32.3	35.8	36.8	37.2	37.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H340	Predicted	26.9	28.9	31.9	35.4	36.4	36.8	37.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H341	Predicted	28.2	30.3	33.2	36.6	37.7	38.1	38.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H342	Predicted	26.9	28.8	31.8	35.4	36.4	36.8	36.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H343	Predicted	26.9	28.8	31.8	35.3	36.3	36.8	36.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H344	Predicted	27.5	29.6	32.6	36.1	37.2	37.6	37.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H345	Predicted	26.3	28.6	31.8	35.4	36.3	36.8	36.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H346	Predicted	26.3	28.6	31.8	35.4	36.3	36.8	36.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H347	Predicted	26.3	28.6	31.8	35.3	36.3	36.7	36.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H348	Predicted	26.3	28.5	31.8	35.3	36.3	36.7	36.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Excess	--	--	--	--	--	--	--
H349	Predicted	26.3	28.5	31.8	35.3	36.3	36.7	36.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H350	Predicted	26.3	28.5	31.7	35.3	36.3	36.7	36.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H351	Predicted	27.6	29.8	32.8	36.2	37.3	37.7	37.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H352	Predicted	28.4	30.8	34.0	37.4	38.4	39.0	39.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H353	Predicted	26.2	28.4	31.6	35.2	36.1	36.6	36.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H354	Predicted	28.7	30.7	33.6	36.9	38.1	38.5	38.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H355	Predicted	26.2	28.3	31.5	35.1	36.0	36.5	36.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H356	Predicted	29.3	31.7	34.6	38.0	39.1	39.6	39.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H357	Predicted	30.4	32.6	35.6	39.1	40.0	40.5	40.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H358	Predicted	25.5	27.7	30.8	34.3	35.3	35.8	35.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H359	Predicted	30.4	32.4	35.1	38.4	39.5	40.0	40.1

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H360	Predicted	29.2	31.1	33.9	37.2	38.3	38.8	38.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H361	Predicted	29.9	31.5	34.2	37.5	38.6	39.1	39.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H362	Predicted	25.9	28.1	31.3	34.7	35.7	36.3	36.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H363	Predicted	32.7	34.5	37.2	40.4	41.5	42.0	42.1
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.4	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H364	Predicted	40.6	41.9	43.8	46.4	47.7	48.0	48.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	0.6	1.9	3.8	6.4	2.7	3.0	3.0
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	0.8	3.4	4.7	5.0	5.0
H365	Predicted	32.1	33.6	36.0	39.1	40.3	40.8	40.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H366	Predicted	32.2	33.8	36.1	39.2	40.4	40.9	41.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H367	Predicted	26.4	28.6	31.5	34.8	35.9	36.4	36.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H368	Predicted	32.3	34.4	37.2	40.4	41.5	42.1	42.2
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.4	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H369	Predicted	26.4	28.6	31.5	34.8	35.9	36.4	36.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--

House	Parameter	Predicted Noise Level, dB LA90, at wind speed at standardised 10m height, m/s						
		3	4	5	6	7	8	9
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H370	Predicted	27.5	29.9	32.9	36.2	37.3	37.8	37.9
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H371	Predicted	33.2	34.5	36.7	39.7	41.0	41.5	41.5
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H372	Predicted	34.4	35.6	37.6	40.5	41.8	42.2	42.3
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.5	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H373	Predicted	33.7	35.1	37.2	40.2	41.4	41.9	42.0
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	0.2	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H374	Predicted	25.1	27.5	31.7	35.8	36.3	36.5	36.6
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H375	Predicted	28.3	30.5	34.7	39.0	39.4	39.6	39.7
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H376	Predicted	27.3	29.6	34.0	38.2	38.6	38.8	38.8
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H380	Predicted	29.4	31.8	35.5	39.3	40.0	40.4	40.4
	Daytime Criterion	40	40	40	40	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--