



## **APPENDIX 12-4**

### **PREDICTED NOISE LEVELS**

## APPENDIX 12-4 PREDICTED NOISE LEVELS

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
H001	Predicted	28.4	28.4	33.8	37.6	38.0	38.0	38.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H002	Predicted	30.6	30.6	35.9	39.6	40.2	40.2	40.2
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H003	Predicted	30.8	30.8	36.0	39.7	40.2	40.3	40.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H004	Predicted	28.8	28.8	34.1	37.9	38.4	38.4	38.4
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H005	Predicted	28.6	28.6	34.0	37.8	38.2	38.2	38.2
	Daytime Criterion	55	55	55	55	55	55	55
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	55	55	55	55	55	55	55
	Night-time Excess	--	--	--	--	--	--	--
H006	Predicted	29.2	29.2	34.4	38.2	38.7	38.7	38.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H007	Predicted	28.3	28.3	33.6	37.4	37.9	37.9	37.9
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H008	Predicted	30.6	30.6	35.9	39.7	40.1	40.1	40.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H009	Predicted	28.7	28.7	34.1	37.9	38.3	38.3	38.3
	Daytime Criterion	45	45	45	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H010	Predicted	28.4	28.4	33.8	37.6	38.0	38.0	38.0
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H011	Predicted	28.6	28.6	34.0	37.8	38.2	38.2	38.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H012	Predicted	31.0	31.0	36.4	40.2	40.6	40.6	40.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H013	Predicted	30.2	30.2	35.6	39.4	39.8	39.8	39.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H014	Predicted	29.7	29.7	35.0	38.8	39.2	39.2	39.2
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H015	Predicted	28.7	28.7	34.1	37.8	38.2	38.2	38.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H016	Predicted	27.6	27.6	32.9	36.7	37.2	37.2	37.2
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H017	Predicted	26.6	26.6	32.0	35.8	36.2	36.2	36.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H018	Predicted	27.8	27.8	32.7	36.5	37.3	37.4	37.4
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H019	Predicted	29.6	29.6	35.0	38.8	39.2	39.2	39.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H020	Predicted	27.8	27.8	33.2	36.9	37.3	37.3	37.3
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H021	Predicted	28.0	28.0	33.4	37.1	37.6	37.6	37.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H022	Predicted	28.2	28.2	33.3	37.1	37.8	37.8	37.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H023	Predicted	27.6	27.6	33.0	36.8	37.2	37.2	37.2
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H024	Predicted	29.0	29.0	34.4	38.2	38.6	38.6	38.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H025	Predicted	29.2	29.2	34.6	38.3	38.8	38.8	38.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H026	Predicted	27.4	27.4	32.8	36.6	37.0	37.0	37.0
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H027	Predicted	28.1	28.1	33.3	37.1	37.7	37.7	37.7
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H028	Predicted	27.8	27.8	33.2	36.9	37.4	37.4	37.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H029	Predicted	27.3	27.3	32.6	36.4	36.8	36.8	36.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H030	Predicted	27.2	27.2	32.3	36.1	36.7	36.7	36.8
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H031	Predicted	29.1	29.1	34.5	38.3	38.7	38.7	38.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H032	Predicted	26.4	26.4	31.7	35.5	36.0	36.0	36.0
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H033	Predicted	27.6	27.6	33.0	36.7	37.1	37.1	37.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H034	Predicted	27.4	27.4	32.3	36.1	36.8	36.9	36.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H035	Predicted	29.0	29.0	33.8	37.5	38.3	38.3	38.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H036	Predicted	27.5	27.5	32.8	36.6	37.0	37.0	37.0
	Daytime Criterion	45	45	45	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H037	Predicted	27.4	27.4	32.8	36.6	37.0	37.0	37.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H038	Predicted	27.2	27.2	32.5	36.3	36.8	36.8	36.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H039	Predicted	27.8	27.8	33.0	36.8	37.4	37.4	37.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H040	Predicted	27.0	27.0	32.3	36.1	36.6	36.6	36.6
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H041	Predicted	27.3	27.3	32.6	36.4	36.9	36.9	36.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H042	Predicted	25.8	25.8	31.1	34.9	35.4	35.4	35.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H043	Predicted	27.3	27.3	32.7	36.5	36.9	36.9	36.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H044	Predicted	27.9	27.9	32.5	36.3	37.3	37.4	37.4
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H045	Predicted	26.8	26.8	32.1	35.8	36.3	36.3	36.3
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H046	Predicted	25.9	25.9	31.2	35.0	35.5	35.5	35.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H047	Predicted	26.8	26.8	32.2	36.0	36.4	36.4	36.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H048	Predicted	27.1	27.1	32.5	36.3	36.7	36.7	36.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H049	Predicted	27.2	27.2	32.5	36.3	36.7	36.7	36.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H050	Predicted	27.1	27.1	32.5	36.2	36.7	36.6	36.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H051	Predicted	26.8	26.8	31.9	35.7	36.4	36.4	36.4
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H052	Predicted	25.4	25.4	30.8	34.6	35.0	35.0	35.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H053	Predicted	25.1	25.1	30.5	34.2	34.7	34.7	34.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H054	Predicted	25.4	25.4	30.7	34.5	34.9	34.9	34.9
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H055	Predicted	27.1	27.1	32.5	36.3	36.7	36.7	36.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H056	Predicted	25.6	25.6	30.8	34.6	35.2	35.2	35.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H057	Predicted	25.5	25.5	30.8	34.6	35.1	35.2	35.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H058	Predicted	26.4	26.4	31.7	35.5	36.0	36.0	36.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H059	Predicted	25.8	25.8	31.1	34.8	35.4	35.4	35.4
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H060	Predicted	26.8	26.8	32.2	36.0	36.4	36.4	36.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H061	Predicted	24.8	24.8	30.1	33.8	34.5	34.5	34.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H062	Predicted	25.8	25.8	31.1	34.9	35.4	35.4	35.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H063	Predicted	26.0	26.0	31.3	35.1	35.5	35.5	35.5
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H064	Predicted	25.8	25.8	31.1	34.9	35.4	35.4	35.4
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H065	Predicted	24.0	24.0	29.3	33.1	33.5	33.5	33.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H066	Predicted	25.5	25.5	30.9	34.7	35.1	35.1	35.1
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H067	Predicted	27.0	27.0	31.5	35.3	36.3	36.5	36.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H068	Predicted	26.9	26.9	31.4	35.2	36.2	36.4	36.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H069	Predicted	24.5	24.5	29.7	33.5	34.2	34.2	34.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H070	Predicted	26.0	26.0	31.3	35.1	35.5	35.5	35.5
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H071	Predicted	24.4	24.4	29.6	33.4	34.1	34.1	34.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H072	Predicted	27.1	27.1	31.5	35.3	36.4	36.5	36.6
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H073	Predicted	23.7	23.7	29.1	32.8	33.2	33.2	33.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H074	Predicted	26.0	26.0	31.3	35.1	35.6	35.5	35.5
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H075	Predicted	25.2	25.2	30.6	34.3	34.8	34.8	34.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H076	Predicted	22.1	22.1	27.4	31.2	31.6	31.6	31.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H077	Predicted	26.2	26.2	31.5	35.3	35.7	35.7	35.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H078	Predicted	25.3	25.3	30.7	34.4	34.9	34.9	34.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H079	Predicted	26.6	26.6	31.2	35.0	35.9	36.0	36.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H080	Predicted	25.9	25.9	31.2	35.0	35.4	35.4	35.4
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H081	Predicted	24.7	24.7	30.1	33.8	34.3	34.3	34.3
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H082	Predicted	24.7	24.7	30.0	33.8	34.3	34.3	34.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H083	Predicted	22.3	22.3	27.6	31.4	31.8	31.8	31.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H084	Predicted	24.0	24.0	29.1	32.9	33.6	33.7	33.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H085	Predicted	26.0	26.0	31.3	35.1	35.6	35.5	35.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H086	Predicted	22.2	22.2	27.6	31.3	31.8	31.8	31.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H087	Predicted	24.7	24.7	30.0	33.8	34.3	34.3	34.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H088	Predicted	22.6	22.6	28.0	31.7	32.2	32.2	32.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H089	Predicted	23.8	23.8	28.9	32.7	33.5	33.5	33.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H090	Predicted	29.6	29.6	33.5	37.3	38.6	38.8	39.0
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H091	Predicted	24.5	24.5	29.9	33.6	34.0	34.0	34.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H092	Predicted	23.3	23.3	28.6	32.4	32.8	32.8	32.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H093	Predicted	24.8	24.8	30.1	33.9	34.3	34.3	34.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H094	Predicted	20.7	20.7	26.1	29.8	30.2	30.2	30.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H095	Predicted	25.1	25.1	30.4	34.2	34.6	34.6	34.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H096	Predicted	20.7	20.7	26.0	29.8	30.2	30.2	30.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H097	Predicted	19.3	19.3	24.6	28.4	28.8	28.8	28.8
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H098	Predicted	20.6	20.6	25.9	29.7	30.1	30.1	30.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H099	Predicted	22.0	22.0	27.3	31.1	31.5	31.5	31.5
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H100	Predicted	20.5	20.5	25.8	29.6	30.0	30.0	30.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H101	Predicted	20.4	20.4	25.7	29.5	29.9	29.9	29.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H102	Predicted	20.1	20.1	25.4	29.2	29.6	29.6	29.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H103	Predicted	20.3	20.3	25.6	29.4	29.8	29.8	29.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H104	Predicted	23.6	23.6	28.8	32.6	33.3	33.4	33.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H105	Predicted	23.5	23.5	28.6	32.4	33.2	33.3	33.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H106	Predicted	20.0	20.0	25.3	29.0	29.4	29.4	29.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H107	Predicted	25.2	25.2	30.5	34.3	34.7	34.7	34.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H108	Predicted	24.3	24.3	29.6	33.4	33.9	33.9	33.9
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H109	Predicted	23.5	23.5	28.7	32.5	33.0	33.0	33.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H110	Predicted	20.0	20.0	25.4	29.2	29.6	29.6	29.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H111	Predicted	25.2	25.2	30.5	34.3	34.8	34.8	34.8
	Daytime Criterion	55	55	55	55	55	55	55
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	55	55	55	55	55	55	55
	Night-time Excess	--	--	--	--	--	--	--
H112	Predicted	20.8	20.8	26.1	29.8	30.3	30.2	30.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H113	Predicted	28.8	28.8	32.8	36.6	37.9	38.1	38.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H114	Predicted	26.1	26.1	30.9	34.7	35.6	35.6	35.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H115	Predicted	19.7	19.7	25.0	28.8	29.2	29.2	29.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H116	Predicted	25.2	25.2	30.5	34.3	34.8	34.7	34.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H117	Predicted	19.4	19.4	24.7	28.5	28.9	28.8	28.8
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H118	Predicted	19.9	19.9	25.2	29.0	29.4	29.4	29.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H119	Predicted	25.6	25.6	30.9	34.7	35.1	35.1	35.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H120	Predicted	23.2	23.2	28.4	32.2	32.7	32.6	32.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H121	Predicted	25.4	25.4	30.8	34.6	35.0	35.0	35.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H122	Predicted	25.2	25.2	30.5	34.3	34.7	34.7	34.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H123	Predicted	18.3	18.3	23.6	27.4	27.8	27.8	27.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H124	Predicted	19.2	19.2	24.5	28.3	28.7	28.6	28.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H125	Predicted	25.5	25.5	30.8	34.6	35.0	35.0	35.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H126	Predicted	23.0	23.0	28.0	31.8	32.7	32.8	32.8
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H127	Predicted	21.7	21.7	27.0	30.8	31.2	31.2	31.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H128	Predicted	25.6	25.6	30.9	34.7	35.1	35.1	35.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H129	Predicted	19.2	19.2	24.6	28.3	28.7	28.7	28.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H130	Predicted	23.3	23.3	28.2	32.0	32.7	32.7	32.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H131	Predicted	18.7	18.7	24.0	27.7	28.2	28.1	28.1
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H132	Predicted	25.2	25.2	30.5	34.3	34.7	34.7	34.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H133	Predicted	23.1	23.1	28.0	31.8	32.8	32.9	32.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H134	Predicted	18.6	18.6	23.9	27.7	28.1	28.1	28.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H135	Predicted	28.0	28.0	32.0	35.7	37.1	37.3	37.5
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H136	Predicted	25.7	25.7	30.4	34.3	35.2	35.1	35.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H137	Predicted	20.4	20.4	25.7	29.5	29.9	29.9	29.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H138	Predicted	23.2	23.2	28.2	32.0	32.7	32.6	32.7
	Daytime Criterion	55	55	55	55	55	55	55
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	55	55	55	55	55	55	55
	Night-time Excess	--	--	--	--	--	--	--
H139	Predicted	22.8	22.8	27.8	31.6	32.6	32.7	32.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H140	Predicted	18.4	18.4	23.8	27.5	27.9	27.9	27.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H141	Predicted	19.4	19.4	24.8	28.5	28.9	28.9	28.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H142	Predicted	18.4	18.4	23.7	27.5	27.9	27.8	27.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H143	Predicted	22.9	22.9	27.8	31.6	32.7	32.8	32.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H144	Predicted	24.9	24.9	30.1	33.9	34.4	34.4	34.4
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H145	Predicted	16.2	16.2	21.4	25.2	25.6	25.6	25.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H146	Predicted	23.8	23.8	29.1	32.8	33.3	33.3	33.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H147	Predicted	20.2	20.2	25.5	29.2	29.6	29.6	29.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H148	Predicted	20.0	20.0	25.3	29.0	29.4	29.4	29.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H149	Predicted	18.1	18.1	23.4	27.2	27.6	27.6	27.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H150	Predicted	19.0	19.0	24.3	28.1	28.5	28.5	28.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H151	Predicted	23.0	23.0	27.8	31.6	32.8	32.9	32.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H152	Predicted	22.8	22.8	28.1	31.9	32.3	32.3	32.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H153	Predicted	19.8	19.8	25.2	28.9	29.3	29.3	29.3
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H154	Predicted	21.0	21.0	26.3	30.0	30.5	30.5	30.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H155	Predicted	25.3	25.3	30.1	33.9	34.9	34.8	34.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H156	Predicted	17.9	17.9	23.2	27.0	27.4	27.4	27.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H157	Predicted	16.7	16.7	22.0	25.8	26.2	26.2	26.2
	Daytime Criterion	55	55	55	55	55	55	55
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	55	55	55	55	55	55	55
	Night-time Excess	--	--	--	--	--	--	--
H158	Predicted	19.5	19.5	24.8	28.6	29.1	29.0	29.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H159	Predicted	20.6	20.6	25.9	29.7	30.2	30.1	30.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H160	Predicted	25.4	25.4	30.7	34.5	34.9	34.9	34.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H161	Predicted	20.7	20.7	26.0	29.7	30.2	30.2	30.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H162	Predicted	21.5	21.5	26.8	30.6	31.0	31.0	31.0
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H163	Predicted	20.9	20.9	26.2	30.0	30.4	30.4	30.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H164	Predicted	19.8	19.8	25.0	28.8	29.3	29.2	29.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H165	Predicted	17.7	17.7	23.0	26.8	27.2	27.2	27.2
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H166	Predicted	20.8	20.8	26.2	29.9	30.3	30.3	30.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H167	Predicted	23.4	23.4	28.7	32.5	32.9	32.9	32.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H168	Predicted	20.8	20.8	26.1	29.9	30.3	30.3	30.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H169	Predicted	20.4	20.4	25.7	29.4	29.9	29.9	29.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H170	Predicted	19.5	19.5	24.8	28.6	29.0	29.0	29.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H171	Predicted	22.6	22.6	27.6	31.4	32.1	32.1	32.1
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H172	Predicted	23.3	23.3	28.1	32.0	32.9	32.8	32.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H173	Predicted	23.5	23.5	28.8	32.5	33.0	33.0	33.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H174	Predicted	23.2	23.2	27.9	31.8	32.7	32.6	32.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H175	Predicted	20.7	20.7	26.0	29.7	30.2	30.1	30.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H176	Predicted	14.6	14.6	19.9	23.7	24.1	24.1	24.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H177	Predicted	22.9	22.9	28.2	32.0	32.4	32.4	32.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H178	Predicted	25.2	25.2	30.6	34.3	34.8	34.8	34.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H179	Predicted	22.6	22.6	27.6	31.4	32.2	32.1	32.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H180	Predicted	22.2	22.2	27.5	31.2	31.8	31.7	31.7
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H181	Predicted	17.0	17.0	22.3	26.1	26.5	26.5	26.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H182	Predicted	20.6	20.6	25.8	29.6	30.0	30.0	30.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H183	Predicted	19.8	19.8	25.0	28.8	29.2	29.2	29.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H184	Predicted	22.5	22.5	27.7	31.5	32.0	31.9	31.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H185	Predicted	20.0	20.0	25.2	29.0	29.5	29.4	29.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H186	Predicted	22.5	22.5	27.8	31.5	32.0	32.0	32.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H187	Predicted	22.1	22.1	27.1	31.0	31.7	31.6	31.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H188	Predicted	22.3	22.3	27.5	31.3	31.8	31.8	31.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H189	Predicted	22.0	22.0	27.1	30.9	31.5	31.4	31.4
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H190	Predicted	19.3	19.3	24.6	28.4	28.8	28.8	28.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H191	Predicted	22.4	22.4	27.6	31.4	31.9	31.9	31.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H192	Predicted	19.9	19.9	25.1	28.9	29.4	29.4	29.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H193	Predicted	22.8	22.8	28.0	31.8	32.3	32.3	32.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H194	Predicted	29.4	29.4	33.3	37.0	38.4	38.6	38.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H195	Predicted	21.5	21.5	26.8	30.6	31.0	31.0	31.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H196	Predicted	23.0	23.0	27.6	31.6	32.6	32.4	32.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H197	Predicted	18.9	18.9	24.2	27.9	28.4	28.3	28.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H198	Predicted	21.2	21.2	26.5	30.2	30.7	30.7	30.7
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H199	Predicted	22.7	22.7	27.8	31.6	32.3	32.2	32.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H200	Predicted	17.2	17.2	22.5	26.3	26.7	26.7	26.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H201	Predicted	22.2	22.2	27.0	30.9	31.7	31.6	31.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H202	Predicted	20.8	20.8	26.1	29.8	30.2	30.2	30.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H203	Predicted	17.1	17.1	22.4	26.2	26.6	26.6	26.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H204	Predicted	15.6	15.6	20.9	24.7	25.1	25.1	25.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H205	Predicted	20.5	20.5	25.8	29.5	30.0	30.0	30.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H206	Predicted	21.5	21.5	26.4	30.2	31.3	31.4	31.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H207	Predicted	15.5	15.5	20.8	24.5	24.9	24.9	24.9
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H208	Predicted	21.9	21.9	27.1	30.9	31.4	31.4	31.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H209	Predicted	17.5	17.5	22.8	26.5	27.0	26.9	26.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H210	Predicted	16.6	16.6	21.8	25.6	26.0	26.0	26.0
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H211	Predicted	22.8	22.8	28.0	31.8	32.4	32.3	32.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H212	Predicted	21.6	21.6	26.8	30.6	31.1	31.0	31.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H213	Predicted	23.1	23.1	28.3	32.1	32.5	32.5	32.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H214	Predicted	17.2	17.2	22.5	26.2	26.6	26.6	26.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H215	Predicted	16.8	16.8	22.0	25.8	26.2	26.2	26.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H216	Predicted	23.1	23.1	28.3	32.1	32.5	32.5	32.5
	Daytime Criterion	45	45	45	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H217	Predicted	18.4	18.4	23.7	27.4	27.9	27.9	27.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H218	Predicted	21.2	21.2	25.8	29.6	31.2	31.3	31.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H219	Predicted	23.2	23.2	28.5	32.2	32.7	32.6	32.6
	Daytime Criterion	45	45	45	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H220	Predicted	16.5	16.5	21.8	25.6	26.0	25.9	25.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H221	Predicted	15.5	15.5	20.8	24.6	25.0	25.0	25.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H222	Predicted	22.7	22.7	27.9	31.7	32.4	32.4	32.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H223	Predicted	23.4	23.4	28.5	32.3	33.1	33.1	33.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H224	Predicted	16.6	16.6	21.8	25.6	26.0	26.0	26.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H225	Predicted	14.8	14.8	20.1	23.8	24.2	24.2	24.2
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H226	Predicted	16.6	16.6	21.8	25.6	26.0	26.0	26.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H227	Predicted	22.7	22.7	27.8	31.6	32.3	32.3	32.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H228	Predicted	17.0	17.0	22.2	26.0	26.4	26.4	26.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H229	Predicted	22.8	22.8	28.0	31.8	32.4	32.4	32.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H230	Predicted	21.8	21.8	27.0	30.8	31.3	31.2	31.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H231	Predicted	22.7	22.7	27.4	29.9	31.0	31.1	31.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H232	Predicted	16.9	16.9	22.2	25.9	26.3	26.3	26.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H233	Predicted	23.2	23.2	28.0	31.5	32.6	32.7	32.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H234	Predicted	23.0	23.0	28.2	31.9	32.5	32.5	32.5
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H235	Predicted	23.1	23.1	28.1	31.9	32.8	32.8	32.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H236	Predicted	18.4	18.4	23.7	27.5	27.9	27.9	27.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H237	Predicted	23.0	23.0	28.0	31.8	32.7	32.8	32.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H238	Predicted	21.8	21.8	27.0	30.8	31.2	31.2	31.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H239	Predicted	18.9	18.9	24.2	27.9	28.4	28.3	28.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H240	Predicted	16.9	16.9	22.2	25.9	26.3	26.3	26.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H241	Predicted	22.9	22.9	27.9	31.7	32.6	32.6	32.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H242	Predicted	22.4	22.4	27.7	31.5	31.9	31.9	31.9
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H243	Predicted	22.1	22.1	27.4	31.1	31.6	31.6	31.6
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H244	Predicted	22.5	22.5	27.8	31.5	32.0	32.0	32.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H245	Predicted	22.9	22.9	28.0	31.7	32.6	32.6	32.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H246	Predicted	21.9	21.9	27.1	30.9	31.4	31.4	31.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H247	Predicted	22.8	22.8	27.8	31.6	32.5	32.6	32.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H248	Predicted	22.2	22.2	27.5	31.3	31.8	31.7	31.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H249	Predicted	23.4	23.4	28.0	30.8	32.0	32.1	32.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H250	Predicted	21.6	21.6	26.8	30.6	31.1	31.0	31.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H251	Predicted	17.0	17.0	22.3	26.0	26.5	26.4	26.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H252	Predicted	16.2	16.2	21.5	25.2	25.6	25.6	25.6
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H253	Predicted	22.8	22.8	27.8	31.5	32.5	32.6	32.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H254	Predicted	21.8	21.8	27.1	30.8	31.3	31.3	31.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H255	Predicted	20.9	20.9	26.2	29.9	30.4	30.4	30.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H256	Predicted	17.3	17.3	22.5	26.3	26.7	26.6	26.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H257	Predicted	21.5	21.5	26.8	30.5	31.0	31.0	31.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H258	Predicted	21.7	21.7	26.9	30.7	31.1	31.1	31.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H259	Predicted	21.9	21.9	27.2	30.9	31.4	31.4	31.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H260	Predicted	21.8	21.8	27.1	30.8	31.3	31.3	31.3
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H261	Predicted	22.6	22.6	27.6	31.4	32.3	32.3	32.3
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H262	Predicted	21.5	21.5	25.9	29.8	31.5	31.7	31.7
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H263	Predicted	20.5	20.5	25.8	29.6	30.0	30.0	30.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H264	Predicted	21.1	21.1	26.3	30.1	30.5	30.5	30.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H265	Predicted	20.8	20.8	26.1	29.8	30.3	30.2	30.2
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H266	Predicted	20.7	20.7	26.0	29.7	30.2	30.1	30.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H267	Predicted	21.0	21.0	26.2	30.0	30.4	30.4	30.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H268	Predicted	21.3	21.3	25.7	29.6	31.4	31.5	31.5
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H269	Predicted	20.4	20.4	25.6	29.4	29.8	29.8	29.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H270	Predicted	12.9	12.9	18.1	21.9	22.3	22.2	22.2
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H271	Predicted	20.5	20.5	25.8	29.5	30.0	30.0	30.0
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H272	Predicted	20.2	20.2	25.5	29.2	29.7	29.6	29.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H273	Predicted	20.0	20.0	24.4	28.3	30.0	30.1	30.1
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H274	Predicted	20.3	20.3	25.6	29.3	29.8	29.8	29.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H275	Predicted	20.0	20.0	25.3	29.0	29.5	29.4	29.4
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H276	Predicted	20.1	20.1	25.4	29.1	29.6	29.6	29.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H277	Predicted	20.6	20.6	25.0	28.9	30.6	30.8	30.8
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H278	Predicted	22.3	22.3	26.7	30.6	32.4	32.6	32.6
	Daytime Criterion	40	40	40	45	45	45	45
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--
H279	Predicted	24.4	24.4	28.9	32.7	34.5	34.6	34.6
	Daytime Criterion	40	40	40	45	45	45	45

House	Parameter	Predicted Noise Level dB LA90 at Standardised Wind Speed at 10m						
		3	4	5	6	7	8	9
	Daytime Excess	--	--	--	--	--	--	--
	Night-time Criterion	43	43	43	43	43	43	43
	Night-time Excess	--	--	--	--	--	--	--