



A = 125mm: Outer Diameter HDPE ESB Approved Comms Duct, SDR = 17.6
 B = 160mm: Outer Diameter HDPE ESB Approved Power Duct, SDR = 21.0
 C = 125mm: Outer Diameter HDPE ESB Approved ECC Duct, SDR = 17.6

Section Through Access Road

SCALE 1:10

- Notes:**
1. Please note that this is drawing for planning and is not to be used for construction.
 2. This drawing is to be read in conjunction with relevant drawings, specifications and reports.
 3. Dimensions are in millimeters, unless noted otherwise.
 4. Drawings are not to be scaled use figured dimensions only.

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNERS REQUIREMENTS AND GUIDELINES FOR MANAGING OPENINGS IN PUBLIC ROADS



Head Office
 Beenreigh,
 Abbeydorney,
 Tralee, Co. Kerry
 Ireland
 Tel: 00353 66 7135710

CLIENT



PROJECT

Ballincor WF
 110 kV Grid Connection

PROJECT NUMBER
 05-867

SHEET NUMBER
 05867-DR-207

SHEET TITLE

Ducting through Access Road

DRAWING STATUS
 For Planning

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P2	07.07.2025	Issued for Planning
P1	16.08.2024	Issued for Planning