

Culvert Crossing Schedule

No.	Culvert ID.	Description	Dimensions (mm)	Approx. Cover (mm)	Crossing Methodology	Photo
6.	W7	Concrete Pipe	900 Ø	1290	Overcrossing - Flat Formation	
7.	W8	Concrete Pipe	900 Ø	1090	Undercrossing - Flat Formation	
8.	W9	2 x HDPE Plastic Pipe	2 x 300 Ø	1100	Undercrossing - Flat Formation	



Head Office
 Beenreigh, Abbeydorney,
 Tralee, Co. Kerry, Ireland
 Tel: 00353 66 7135710

PROJECT

**Ballincor Wind Farm
 110kV Grid Connection**

CLIENT



CONSULTANTS



NOTES: -

- No structural surveys have been carried out and the proposals are subject to detailed design.
- Crossings are in compliance with EirGrid specification requirements for shallow formation, min depth, etc.
- Additional culverts may be encountered on the route.

LEGEND: -

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P2	07.07.25	Issued for Planning
P1	05.03.25	Issued for Planning

PROJECT NUMBER

05-867

SHEET TITLE

Culvert Crossing Schedule
 Sheet 2 of 2

SHEET NUMBER

05-867-DR-232