



### Typical Section Through Access Road

SCALE: 1:10

**ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LANDOWNERS REQUIREMENTS**

**Note:**

- This drawing is to be read in conjunction with relevant drawings, specifications and reports
- Dimensions are in millimeters, unless noted otherwise
- Drawings are not to be scaled use figured dimensions only
- 325 mm trench width is also acceptable to ESBN
- 3m wide access track specified to ESBN requirements to be installed over cable for longer off-road sections where there is no existing access track in place.



Head Office  
 Beenreigh,  
 Abbeydorney,  
 Tralee, Co. Kerry  
 Ireland  
 Tel: 00353 66 7135710

CLIENT



PROJECT

Ballincor WF  
 110 kV Grid Connection

PROJECT NUMBER  
 05-867

SHEET NUMBER  
 05867-DR-233

SHEET TITLE

MV Ducting Through  
 Access Track

DRAWING STATUS  
 For Planning

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P1	07.07.2025	Issued for Planning