



**LEGEND:**

- Red Cable Marker Strip
- Yellow Marker Warning Tape 500mm Wide
- Ducts Laid In CBGM B (CI 822), Compacted To Cl. 813.10
- Backfill, Compacted (Cl. 804)

A=125mm O.D. HDPE ESB APPROVED DUCT, SDR=17.6  
 D=160mm O.D. HDPE ESB APPROVED DUCT, SDR=21  
 ALL DIMENSIONS IN MILLIMETERS

- Notes:**
1. A surface cable marker (metallic plate; 300mm x150mm to ESB standard) will be placed on the bridge where cable depth is unavoidably shallow.
  2. Requirements of Road Engineer will be facilitated at detailed design stage

rev.	modifications	by	chk	date

Client	Constant Energy Limited			
Project	Proposed Tirawley Wind Farm & 110kV Grid Connection Route			
Stage	Planning			
Title	Grid Connection Route: Trench Cross Section For 160mm Power Ducts In Flat Formation in Public Roads			
Scales	1:10 (A3)			
Surveyed	Drawn	Checked	Approved	Date
	LB	DT/MG	DK	April 2026

**Trench Cross Section For 160mm Power Ducts In Flat Formation - (Transition to Joint Bays)**  
 Scale: 1:10 (A3)

© COPYRIGHT OF  
 JENNINGS O'DONOVAN AND PARTNERS LIMITED  
 FINISKLIN Tel (+353) 719 161 416  
 SLIGO Email. info@jodireland.com  
 IRELAND www.jodireland.com