

PROJECT

**Coom Green Energy Park
 110kV Grid Connection**

CLIENT

**Coom Green Energy
 Park Limited**

CONSULTANTS



NOTES: -

- No structural surveys have been carried out and the proposals are subject to detailed design.
- Crossings are in compliance with EirGrid specification requirements for shallow formation, min depth, etc.
- Additional culverts may be encountered on the route.
- Dimensions are in millimeters, unless noted otherwise.
- Co-Ordinates to ITM Grid.

LEGEND: -

ISSUED FOR PLANNING
28.04.26

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P1	28.04.26	Issued for Planning
N2	02.04.25	Issued for Information
N1	28.01.25	Issued for Information

PROJECT NUMBER

300-100920

SHEET TITLE

Watercourse Crossing Schedule
 Sheet 1 of 3

SHEET NUMBER

300100920-DR-224

Watercourse Crossing Schedule						
Watercourse No.	Location (ITM)	Dimensions (mm)	Material	Approx. Cover (mm)	Crossing Methodology	Photo
1. Bridge 01	X: 582074.53 Y: 594274.05	Single Stone Arch	Masonry Stone	540	HDD	
2. Culvert 01	X: 582026.25 Y: 594308.11	500 x 500	Concrete	350	Undercrossing	
3. Culvert 02	X: 579825.55 Y: 595330.62	200 Ø	Concrete	200	Undercrossing	
4. Culvert 03	X: 578455.09 Y: 595316.17	300 Ø	Twin Wall	1000	Undercrossing	
5. Culvert 04	X: 578628.00 Y: 595256.00	300 Ø	Concrete	600	Undercrossing	