

**PROJECT**

**Coom Green Energy Park  
 110kV Grid Connection**

**CLIENT**

**Coom Green Energy  
 Park Limited**

**CONSULTANTS**



**NOTES: -**

- No structural surveys have been carried out and the proposals are subject to detailed design.
- Crossings are in compliance with EirGrid specification requirements for shallow formation, min depth, etc.
- Additional culverts may be encountered on the route.
- Dimensions are in millimeters, unless noted otherwise.
- Co-Ordinates to ITM Grid.

**LEGEND: -**

ISSUED FOR PLANNING  
28.04.26

**ISSUE/REVISION**

I/R	DATE	DESCRIPTION
P1	28.04.26	Issued for Planning
N2	02.04.25	Issued for Information
N1	28.01.25	Issued for Information

**PROJECT NUMBER**

300-100920

**SHEET TITLE**

Watercourse Crossing Schedule  
 Sheet 3 of 3

**SHEET NUMBER**

300100920-DR-226

Watercourse Crossing Schedule						
Watercourse No.	Location (ITM)	Dimensions (mm)	Material	Approx. Cover (mm)	Crossing Methodology	Photo
11. Culvert 10	X: 572037.32 Y: 593130.91	400 Ø	Concrete	700	Undercrossing	
12. Culvert 11	X: 571954.64 Y: 593252.09	300	Concrete	300	Undercrossing	
13. Culvert 12	X: 571578.60 Y: 593445.92	300	Concrete	300	Undercrossing	