

PROJECT

**Coom Green Energy Park
33kV Interconnection**

CLIENT

**Coom Green Energy
Park Limited**

CONSULTANTS



NOTES: -

- No structural surveys have been carried out and the proposals are subject to detailed design.
- Crossings are in compliance with EirGrid specification requirements for shallow formation, min depth, etc.
- Additional culverts may be encountered on the route.
- Dimensions are in millimeters, unless noted otherwise.
- Co-Ordinates to ITM Grid.

LEGEND: -

Hydraulic & Hydrological Crossing Schedule						
Feature	Location (ITM)	Dimensions (mm)	Material	Approx. Cover (mm)	Crossing Methodology	Comment/Photo
1. Culvert 1	X = 570442.973 Y = 594471.703	N/A	N/A	N/A	N/A	To be constructed as part of permitted Wind Farm access roads
2. Watercourse 01	X = 570093.250 Y = 594420.140	N/A	N/A	0	HDD	
3. Culvert 2	X = 570020.641 Y = 594141.329	N/A	N/A	N/A	N/A	To be constructed as part of permitted Wind Farm access roads
4. Culvert 3	X = 569953.127 Y = 593917.892	N/A	N/A	0	N/A	To be constructed as part of permitted Wind Farm access roads
5. Culvert 4	X = 569896.980 Y = 593750.695	800 Ø	Concrete	500	Undercrossing	

ISSUED FOR PLANNING
10.12.2025

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P1	10.12.25	Issued for Planning
N1	25.07.25	Issued for Information

PROJECT NUMBER

300-100920

SHEET TITLE

Hydraulic & Hydrological
Sheet 1 of 10

SHEET NUMBER

300100920-DR-142