

PROJECT

**Coom Green Energy Park
 33kV Interconnection**

CLIENT

**Coom Green Energy
 Park Limited**

CONSULTANTS



NOTES: -

- No structural surveys have been carried out and the proposals are subject to detailed design.
- Crossings are in compliance with EirGrid specification requirements for shallow formation, min depth, etc.
- Additional culverts may be encountered on the route.
- Dimensions are in millimeters, unless noted otherwise.
- Co-Ordinates to ITM Grid.

LEGEND: -

**ISSUED FOR PLANNING
 10.12.2025**

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P1	10.12.25	Issued for Planning
N1	25.07.25	Issued for Information

PROJECT NUMBER

300-100920

SHEET TITLE

Hydraulic & Hydrological
 Crossing Schedule
 Sheet 2 of 10

SHEET NUMBER

300100920-DR-143

Hydraulic & Hydrological Crossing Schedule

Feature	Location (ITM)	Dimensions (mm)	Material	Approx. Cover (mm)	Crossing Methodology	Photo
6. Culvert 5	X = 569752.000 Y = 593749.000	300 Ø	Concrete	100	Undercrossing	
7. Culvert 6	X = 569669.000 Y = 593763.000	400 Ø	Concrete	400	Undercrossing	
8. Culvert 7	X = 569568.000 Y = 593787.000	400 Ø	Concrete	600	Undercrossing	
9. Culvert 8	X = 569436.211 Y = 593825.591	400 Ø	Concrete	500	Undercrossing	
10. Culvert 9	X = 569171.482 Y = 593899.366	300 Ø	Concrete	400	Undercrossing	