

PROJECT

**Coom Green Energy Park  
 33kV Interconnection**

CLIENT

**Coom Green Energy  
 Park Limited**

CONSULTANTS



NOTES: -

- No structural surveys have been carried out and the proposals are subject to detailed design.
- Crossings are in compliance with EirGrid specification requirements for shallow formation, min depth, etc.
- Additional culverts may be encountered on the route.
- Dimensions are in millimeters, unless noted otherwise.
- Co-Ordinates to ITM Grid.

LEGEND: -

**ISSUED FOR PLANNING  
 10.12.2025**

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P1	10.12.25	Issued for Planning
N1	25.07.25	Issued for Information

PROJECT NUMBER

300-100920

SHEET TITLE

Hydraulic & Hydrological  
 Crossing Schedule  
 Sheet 3 of 10

SHEET NUMBER

300100920-DR-144

**Hydraulic & Hydrological Crossing Schedule**

Feature	Location (ITM)	Dimensions (mm)	Material	Approx. Cover (mm)	Crossing Methodology	Photo
11. Culvert 10	X = 569019.610 Y = 593940.220	900 Ø	Concrete	700	Undercrossing	
12. Culvert 11	X = 568733.000 Y = 593971.000	TBC	TBC	TBC	Undercrossing	
13. Culvert 12	X = 568665.000 Y = 593965.000	300 Ø	Twin wall	500	Undercrossing	
14. Culvert 13	X = 568546.001 Y = 593910.998	300 Ø	Concrete	500	Undercrossing	
15. Culvert 14	X = 568183.000 Y = 593655.000	400 Ø	Concrete	700	Undercrossing	