

PROJECT

**Coom Green Energy Park
 33kV Interconnection**

CLIENT

**Coom Green Energy
 Park Limited**

CONSULTANTS



NOTES: -

- No structural surveys have been carried out and the proposals are subject to detailed design.
- Crossings are in compliance with EirGrid specification requirements for shallow formation, min depth, etc.
- Additional culverts may be encountered on the route.
- Dimensions are in millimeters, unless noted otherwise.
- Co-Ordinates to ITM Grid.

LEGEND: -

ISSUED FOR PLANNING
10.12.2025

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P1	10.12.25	Issued for Planning
N1	25.07.25	Issued for Information

PROJECT NUMBER

300-100920

SHEET TITLE

Hydraulic & Hydrological
 Crossing Schedule
 Sheet 7 of 10

SHEET NUMBER

300100920-DR-148

Hydraulic & Hydrological Crossing Schedule

Feature	Location (ITM)	Dimensions (mm)	Material	Approx. Cover (mm)	Crossing Methodology	Photo
31. Culvert 28	X = 568244.000 Y = 591190.000	600 Ø	Concrete	300	Undercrossing	
32. Culvert 29	X = 568080.000 Y = 590971.000	600 Ø	Concrete	1200	Undercrossing	
33. Culvert 30	X = 568183.000 Y = 593655.000	600 Ø	Twin wall	200	Undercrossing	
34. Culvert 31	X = 568593.000 Y = 590605.000	400 Ø	Twin wall	200	Undercrossing	
35. Culvert 32	X = 568610.000 Y = 590594.000	200 Ø	Twin wall	0	Undercrossing	