


Our Case Number: ACP-324342-26



**An
Coimisiún
Pleanála**

Kenny Ramsey
Ballyederowen
Burnfoot
Donegal
F93 VW72

Date: 14 August 2026

Re: Proposed Burnfoot Flood Relief Scheme
in the townlands of Ballyederowen, Carnashannagh, Monreagh (aka Barr of Kilmacilvenny), and
Inch Level at Burnfoot, County Donegal

Dear Sir / Madam,

An Coimisiún Pleanála has received your recent submission in relation to the above mentioned proposed development and will take it into consideration in its determination of the matter. Please accept this letter as a receipt for the fee of €50 that you have paid.

Please note that the proposed development shall not be carried out unless the Commission has approved it or approved it with conditions.

If you have any queries in relation to the matter please do not hesitate to contact the undersigned officer of the Commission at laps@pleanala.ie

Please quote the above mentioned An Coimisiún Pleanála reference number in any correspondence or telephone contact with the Commission.

Yours faithfully,

Lauren Griffin
Executive Officer
Direct Line: 01-8737244

JA02

Kenny Ramsey

Ballyederowen

Burnfoot

Co. Donegal

F93VW72

Submission relating to Proposed Burnfoot Flood Relief Scheme Case Reference JA05E.324342

Drawing No's IBE2204_BT 105 & 106 detail the construction of an Embankment with Finished level shown @ 6.71m. We cannot understand why this level is required when our dwelling located to the immediate north of this embankment has a threshold level of 6.4m. This will surely leave our home at risk of future flooding.

Regards

Kenny Ramsey