


Our Case Number: ACP-324342-26



An
Coimisiún
Pleanála

Andrew Hamilton
Carnshannagh
Burnfoot
Donegal
F93 F2K5

Date: 18 August 2026

Re: Proposed Burnfoot Flood Relief Scheme
in the townlands of Ballyederowen, Carnashannagh, Monreagh (aka Barr of Kilmacilvenny), and
Inch Level at Burnfoot, County Donegal

Dear Sir / Madam,


An Coimisiún Pleanála has received your recent submission in relation to the above mentioned proposed development and will take it into consideration in its determination of the matter. Please accept this letter as a receipt for the fee of €50 that you have paid.

Please note that the proposed development shall not be carried out unless the Commission has approved it or approved it with conditions.

If you have any queries in relation to the matter please do not hesitate to contact the undersigned officer of the Commission at laps@pleanala.ie

Please quote the above mentioned An Coimisiún Pleanála reference number in any correspondence or telephone contact with the Commission.

Yours faithfully,



Lauren Griffin
Executive Officer
Direct Line: 01-8737244

JA02

Teil
Glao Áitiúil
Láithreán Gréasáin
Ríomhphost

Tel
LoCall
Website
Email

(01) 858 8100
1800 275 175
www.pleanala.ie
communications@pleanala.ie

64 Sráid Maoilbhríde
Baile Átha Cliath 1
D01 V902

64 Marlborough Street
Dublin 1
D01 V902

Teil
Glao Áitiúil
Facs
Láithreán Gréasáin
Riomhphost

Tel
LoCall
Fax
Website
Email

(01) 858 8100
1800 275 175
(01) 872 2684
www.pleanala.ie
communications@pleanala.ie

64 Sráid Maoilbhríde
Baile Átha Cliath 1
D01 V902

64 Marlborough Street
Dublin 1
D01 V902

Andrew Hamilton

Carnshannagh

Burnfoot

Co. Donegal

F93F2K5

Submission relating to Proposed Burnfoot Flood Relief Scheme Case Reference JA05E.324342

Drawing No's IBE2204_BT 109 detail the works to be carried out to the Upper Carnshannagh Culvert. We have concerns around the suitability of the proposed works. Firstly the laneway used to access the culvert does not have the capacity to cater for the heavy machinery required for the construction.

The new culvert will not prevent water discharging to the surrounding fields as over topping takes to the North West of the proposed culvert and flows down the road and into the fields. We would propose to re-camber the road towards the drain and put a ramp on the road at the corner and an embankment in the field to divert water towards the drain. There is currently a pipe in place at the corner which size will need increased.

Regards

Andrew Hamilton