Muirin Gowen

From:	LAPS
Sent:	Monday 28 September 2026 14:29
To:	'Aine Rowan(C)'
Cc:	planning@water.ie
Subject:	RE: UE Response - ACP-324637-26 EIAR Scoping Request EIAR-Dublin Airport passenger cap
Attachments:	LDG-090495-26-Valid Lodgement Confirmation Letter -Uisce Éireann.pdf

A Chara,

Please find correspondence attached related to the above-mentioned application.

It would be greatly appreciated if you could confirm receipt of this email.

Kind regards,
Muirín

Our Case Number: ACP-324637-26

An Coimisiún Pleanála

Uisce Éireann
c/o Aine Rowan
Colvill House
24-26 Talbot Street
Dublin 1
D01 NP86

Date: 28 September 2026

Re: Minister for Transport EIAR scoping request in relation to the Dublin Airport passenger cap, Swords, County Dublin

Dear Sir / Madam,

An Coimisiún Pleanála has received your recent submission in relation to the above-mentioned case. The contents of your submission have been noted.

If you have any queries in relation to the matter, please contact the undersigned officer of the Commission at laps@pleanala.ie

Please quote the above-mentioned An Coimisiún Pleanála reference number in any correspondence or telephone contact with the Commission.

Yours faithfully,

MGowen

Muirin Gowen
Executive Officer
Direct Line: 01-8049323

CH08

Muirin Gowen

From: Aine Rowan(C) <aine.rowan@water.ie>
Sent: Monday 28 September 2026 13:10
To: LAPS; Bord
Cc: SIDS; Planning
Subject: UE Response - ACP-324637-26 EIAR Scoping Request EIAR-Dublin Airport passenger cap
Attachments: UÉ Response ACP-324637-26 Dublin Airport Passenger Cap EIAR Scoping.pdf

Caution: This is an **External Email** and may have malicious content. Please take care when clicking links or opening attachments. When in doubt, contact the ICT Helpdesk.

Dear Sir/Madam,

In response to An Coimisiún Pleanála - Case reference: DAS06F.324637 324637 | An Coimisiún Pleanála - EIAR-Dublin Airport passenger cap

Please find attached Uisce Éireann's observations.

I hope you find this information helpful. If you have any queries, please do not hesitate to contact me.

Aine Rowan
Planning Application Specialist

Uisce Éireann
Teach Colvill, 24–26 Sráid Thalbóid, Baile Átha Cliath 1, D01 NP86, Éire
Uisce Éireann
Colvill House, 24–26 Talbot Street, Dublin 1, D01 NP86, Ireland
www.water.ie
Facebook | Twitter | LinkedIn

Is don duine amháin nó don eintiteas amháin ainmnithe ar an seoladh an fhaisnéis agus d'fhéadfadh ábhar faoi rún, faoi phribhléid nó ábhar atá íogair ó thaobh na tráchtála de a bheith mar chuid den fhaisnéis. Tá toirmeasc ar aon daoine nó aon eititis; nach dóibh siúd an fhaisnéis- aon athbhreithniú a dhéanamh, aon atarchur a dhéanamh nó aon athdháileadh a dhéanamh, nó aon úsáid eile a bhaint as an bhfaisnéis, nó aon ghníomh a bhraithfeadh ar an bhfaisnéis seo a dhéanamh agus d'fhéadfaí an dlí a shárú dá ndéanfaí sin. Séanann Uisce Éireann dliteanas as aon ghníomh agus as aon iarmhairt bunaithe ar úsáid neamhúdaraithe na faisnéise seo. Séanann Uisce Éireann dliteanas maidir le seachadadh iomlán agus ceart na faisnéise sa chumarsáid seo agus séanann Uisce Éireann dliteanas maidir le haon mhoill a bhaineann leis an bhfaisnéis a fháil. Má tá an ríomh-phost seo faighte agat trí dhearmad, déan teagmháil leis an seoltóir más é do thoil é agus scrios an t-ábhar ó gach aon ríomhaire. D'fhéadfadh ríomhphost a bheith so-ghabhálach i leith truaillithe, idircheaptha agus i leith leasuithe neamhúdaraithe. Séanann Uisce Éireann aon fhreagracht as athruithe nó as idircheapadh a rinneadh ar an ríomhphost seo nó as aon dochar do chórais na bhfaighteoirí déanta ag an teachtaireacht seo nó ag a ceangaltáin tar éis a sheolta. Tabhair faoi deara go bhféadfadh monatóireacht a bheith á dhéanamh ar theachtaireachtaí chuig Uisce Éireann agus ó Uisce Éireann d'fhonn ár ngnó a chosaint agus chun a chinntiú go bhfuiltear ag teacht le beartais agus le caighdeáin

Uisce Éireann. Is cuideachta gníomhaíochta ainmnithe é Uisce Éireann atá faoi theorainn scaireanna, a bunaíodh de bhun fhorálacha na n-Achtanna um Sheirbhísí Uisce 2007-2022, a bhfuil a bpríomh-ionad gnó ag Teach Colvill, 24-26 Sráid na Talbóide, BÁC 1.

Go raibh maith agat as d'aird a thabhairt.

The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential, commercially sensitive and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited and may be unlawful. Uisce Éireann accepts no liability for actions or effects based on the prohibited usage of this information. Uisce Éireann is neither liable for the proper and complete transmission of the information contained in this communication nor for any delay in its receipt. If you received this in error, please contact the sender and delete the material from any computer. E-Mail may be susceptible to data corruption, interception and unauthorised amendment. Uisce Éireann accepts no responsibility for changes to or interception of this e-mail after it was sent or for any damage to the recipients systems or data caused by this message or its attachments. Please also note that messages to or from Uisce Éireann may be monitored to ensure compliance with Uisce Eireann's policies and standards and to protect our business. Uisce Éireann is a designated activity company limited by shares, established pursuant to the Water Services Acts 2007-2022, having its principal place of business at Colvill House, 24-26 Talbot Street, Dublin 1.

Thank you for your attention.

Uisce Éireann

na

Cathair Chorcaí

Uisce Éireann
PO Box 448
South City
Delivery Office
Cork City

www.water.ie

Uisce Éireanns Ref: PN26000047949

Planning Ref: ACP-324637-26 EIAR Scoping Request

Planning Authority: An Coimisiún Pleanála (ACP)

Issue Date: 28 September 2026

Development Location: Dublin Airport, County Dublin

Development Description:

Request for EIAR Scoping Submission on Raising of Passenger Cap at Dublin Airport.

A Chara,

Thank you for your recent EIAR Scoping Request which we have reviewed. Uisce Éireann has the following comments for your consideration.

The proposal includes to replace conditions on previous consents relating to the annual limit on the number of air passengers using the infrastructure at Dublin Airport, which would entail an increase in the number of air passengers permitted annually.

No works or other interventions involving alterations to the physical aspects of the site are proposed as part of the application for which the EIAR is being compiled for.

Previous Planning Application Consultation

In December 2024, Uisce Éireann submitted a Statutory Response to a separate planning application at Dublin Airport, Fingal County Council Reference F23A/081.

This application sought to increase the capacity of the airport from the permitted combined capacity of Terminal 1 together with Terminal 2 of 32 million passengers per annum to 40 million passengers per annum and also proposed a range of infrastructure upgrades, to support the increase in passenger numbers.

Stiúrthóirí / Directors: Jerry Grant (Cathaoirleach / Chairperson), Niall Gleeson (POF / CEO), Gerard Britchfield, Douglas Millican, Michael Nolan, Patricia King, Eileen Maher, Cathy Mannion, Paul Reid, Michael Walsh.
Oifig Chláraithe / Registered Office: Teach Colvill, 24-26 Sráid Thalbóid, Baile Átha Cliath 1, D01 NP86 / Colvill House, 24-26 Talbot Street, Dublin, Ireland D01NP86
Is cuideachta ghníomhaíochta ainmnithe atá faoi theorainn scaireanna é Uisce Éireann / Uisce Éireann is a designated activity company, limited by shares.
Cláraithe in Éirinn Uimh.: 530363 / Registered in Ireland No.: 530363.

Connecting to Uisce Éireann Infrastructure

The subject planning application proposes an intensification of use for the existing airport from 32 million passengers per annum to 40 million passengers per annum. Noting there are no physical works proposed as part of the subject application.

The Dublin Airport Authority (DAA) has engaged with Uisce Éireann regarding the provision of water and wastewater services for these proposals previously.

Uisce Éireann has completed a feasibility review and has issued a Confirmation of Feasibility (COF) to the DAA as follows:

Water

Feasible without infrastructure upgrade by Uisce Éireann. At connection application stage, the developer must provide exact on-site storage size and requirement of direct supply/tank filling during day time.

Wastewater

Feasible without infrastructure upgrade by Uisce Éireann. The development is within Dublin Airport area, served by a private pumping station which discharges into the Uisce Éireann 900mm foul sewer. The proposed increase in average flow outlined in December 2024, an increase from the current 17l/s to 22l/s, is acceptable subject to being within the existing total trade effluent discharge license limit for DAA and Dublin Airport.

The EIAR shall consider and assess the impact of the proposal on Uisce Éireann infrastructure (material assets), making reference to the previous engagement outlined herein, and the Applicant shall submit a revised Pre-Connection Enquiry to Uisce Éireann, for the intensification of use proposed, in order to obtain a current Confirmation of Feasibility as part of the EIAR assessment process.

Queries relating to the comments above should be directed to planning@water.ie.

Yours sincerely,

Dermot Phelan

Dermot Phelan
Connections and Developer Services