
ISO A1 594mm x 841mm



Aylward 4 ax truck neck 4 bed 6 Aghada

Overall Length	35.390m
Overall Width	3.000m
Overall Body Height	4.000m
Min Body Ground Clearance	0.250m
Max Track Width	2.500m
Lock-to-lock time	6.00s
Wall to Wall Turning Radius	25.200m

Vehicle Details

Scale: 1: 200

Transformer Delivery - Swept Path Analysis

Scale: 1: 1250

1:1250

25m 0 25m 50m 75m 100m 125m

Project Management Initials: Designer: LP Checked: BG Approved: AC

tli GROUP

Head Office
Beenreigh,
Abbeydorney,
Tralee, Co. Kerry
Ireland
Tel: 00353 66 7135710

Regional Office
Basepoint Business Centre
Stroudley Road, Basingstoke,
Hampshire,
RG24 8UP, UK
Tel: 00 44 1256406664

PROJECT

Cappakeel Solar Farm
110 kV Substation

CLIENT

Perigus Energy

CONSULTANTS

NOTES: -

- This drawing is to be read in conjunction with relevant engineering drawings, specifications and reports.
- Dimensions are in meters, & coordinate system is ITM, unless noted otherwise.
- Drawings are not to be scaled use figured dimensions only.

LEGEND: -

- Access Road
- Temporary Hardcore Surface
- Vehicle Route in
- Vehicle Route out

ISSUE/REVISION

I/R	DATE	DESCRIPTION
P1	16.06.2026	Issued for Planning
P0	20.03.2026	Issued for Planning

PROJECT NUMBER

300-100925

SHEET TITLE

Access Road and Swept Path Analysis For Transformer Delivery

SHEET NUMBER

300100925-DR-111