TOBIN

Rooaunalaghta Green Energy Project

Appendix 12-6

Predicted Noise Levels V136

ROOAUNALAGHTA
Green Energy

BUILT ON KNOWLEDGE

APPENDIX 12-6 PREDICTED NOISE LEVELS

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
1	NML 3	Predicted	17.8	21.7	26.6	30.4	31	30.8	30.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
10	NML 5	Predicted	23.8	27.4	32.3	36	36.7	36.6	36
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
100	NML 3	Predicted	20	23.8	28.7	32.4	33	32.9	32.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
101	NML 3	Predicted	17.8	21.7	26.5	30.3	30.9	30.8	30.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
102	NML 3	Predicted	18.1	22	26.8	30.6	31.2	31.1	30.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
103	NML 3	Predicted	18.4	22.3	27.2	31	31.6	31.4	30.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
105	NML 3	Predicted	23.4	27	31.9	35.7	36.3	36.2	35.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
106	NML 3	Predicted	22.8	26.5	31.4	35.1	35.8	35.6	35.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
107	NML 3	Predicted	22.5	26.2	31.1	34.8	35.5	35.4	34.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
108	NML 3	Predicted	25.6	29.1	34	37.7	38.4	38.3	37.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
109	NML 3	Predicted	25.2	28.8	33.6	37.4	38	37.9	37.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
11	NML 6	Predicted	26.2	29.7	34.6	38.3	39	38.9	38.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
110	NML 3	Predicted	25.8	29.3	34.2	38	38.6	38.5	38
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
111	NML 3	Predicted	26.8	30.3	35.2	38.9	39.5	39.4	39
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
112	Ignore	Predicted	25.4	28.9	33.8	37.5	38.2	38.1	37.6
		Daytime Criterion	55	55	55	55	55	55	55
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	55	55	55	55	55	55	55
		Night-time Excess	--	--	--	--	--	--	--
113	NML 3	Predicted	25.4	28.9	33.8	37.5	38.2	38.1	37.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
114	NML 3	Predicted	24.2	27.8	32.7	36.4	37	37	36.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
115	NML 2	Predicted	20.8	24.6	29.5	33.2	33.8	33.7	33.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
116	NML 3	Predicted	21.6	25.3	30.2	33.9	34.6	34.4	33.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
117	NML 3	Predicted	19.6	23.4	28.2	32	32.6	32.5	31.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
118	NML 3	Predicted	20.1	23.9	28.8	32.6	33.2	33	32.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
119	NML 3	Predicted	25.7	29.2	34.1	37.8	38.4	38.4	37.9
		Daytime Criterion	40	40	40	40	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
12	NML 6	Predicted	26.9	30.3	35.2	38.9	39.6	39.5	39
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
120	NML 3	Predicted	25.6	29.1	34	37.7	38.4	38.3	37.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
121	NML 3	Predicted	26.4	29.9	34.8	38.5	39.2	39.1	38.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
122	NML 3	Predicted	26.4	29.9	34.7	38.5	39.1	39	38.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
123	NML 3	Predicted	23.6	27.2	32.1	35.8	36.4	36.4	35.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
124	NML 3	Predicted	26.7	30.2	35.1	38.8	39.4	39.4	38.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
125	NML 3	Predicted	26.7	30.2	35	38.8	39.4	39.3	38.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
126	NML 3	Predicted	27.9	31.3	36.2	39.9	40.5	40.5	40
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
127	NML 3	Predicted	25.6	29.1	34	37.7	38.4	38.3	37.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
128	NML 2	Predicted	22.3	26	30.8	34.6	35.2	35.1	34.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
129	NML 2	Predicted	20.9	24.7	29.5	33.3	33.9	33.8	33.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
13	NML 6	Predicted	19.2	23.1	28	31.7	32.3	32.2	31.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
130	NML 2	Predicted	21.1	24.9	29.7	33.5	34.1	34	33.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
131	NML 2	Predicted	22	25.7	30.6	34.3	34.9	34.8	34.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
132	NML 2	Predicted	21.2	25	29.8	33.6	34.2	34.1	33.5

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
133	NML 2	Predicted	21.4	25.1	30	33.7	34.3	34.2	33.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
134	NML 2	Predicted	21.5	25.2	30.1	33.8	34.5	34.4	33.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
135	NML 2	Predicted	21.6	25.4	30.2	34	34.6	34.5	33.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
136	NML 2	Predicted	21	24.8	29.6	33.4	34	33.9	33.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
137	NML 3	Predicted	26.9	30.3	35.2	38.9	39.6	39.5	39
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
138	NML 3	Predicted	26.6	30.1	35	38.7	39.4	39.3	38.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
139	NML 3	Predicted	27.6	31	35.9	39.6	40.2	40.2	39.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
14	NML 6	Predicted	20.2	24.1	28.9	32.7	33.3	33.2	32.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
140	NML 3	Predicted	26.2	29.7	34.6	38.3	39	38.9	38.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
141	NML 2	Predicted	25.7	29.2	34.1	37.8	38.5	38.4	37.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
142	NML 2	Predicted	25.6	29.1	34	37.7	38.4	38.3	37.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
143	NML 2	Predicted	25.1	28.6	33.5	37.2	37.9	37.8	37.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
144	NML 2	Predicted	25.3	28.8	33.7	37.4	38.1	38	37.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
145	NML 2	Predicted	19.4	23.2	28.1	31.9	32.5	32.4	31.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
146	NML 2	Predicted	19	22.8	27.7	31.4	32.1	31.9	31.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
147	NML 2	Predicted	19.4	23.3	28.1	31.9	32.5	32.4	31.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
148	NML 2	Predicted	19.4	23.2	28.1	31.8	32.5	32.3	31.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
149	NML 2	Predicted	18.7	22.6	27.5	31.2	31.8	31.7	31
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
15	NML 4	Predicted	20.4	24.3	29.1	32.9	33.5	33.4	32.7
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
150	NML 2	Predicted	19	22.9	27.8	31.5	32.2	32	31.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
151	NML 2	Predicted	19.2	23.1	27.9	31.7	32.3	32.2	31.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
152	NML 2	Predicted	18.1	22	26.8	30.6	31.2	31.1	30.4
		Daytime Criterion	40	40	40	40	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
153	NML 2	Predicted	18.3	22.2	27	30.8	31.4	31.3	30.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
154	NML 2	Predicted	19.8	23.6	28.5	32.3	32.9	32.8	32.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
155	NML 2	Predicted	19.2	23.1	28	31.7	32.4	32.2	31.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
156	NML 2	Predicted	19.1	23	27.8	31.6	32.2	32.1	31.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
157	NML 2	Predicted	23.7	27.3	32.2	35.9	36.6	36.5	35.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
159	NML 2	Predicted	19	22.8	27.7	31.5	32.1	32	31.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
16	NML 4	Predicted	21.1	24.9	29.8	33.5	34.1	34	33.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
160	NML 2	Predicted	18.8	22.7	27.6	31.3	32	31.8	31.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
161	NML 2	Predicted	18.6	22.5	27.3	31.1	31.7	31.6	30.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
163	NML 2	Predicted	29.2	32.6	37.5	41.2	41.8	41.8	41.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	1.2	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
164	NML 2	Predicted	25.5	29	33.9	37.7	38.3	38.2	37.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
165	NML 2	Predicted	25.1	28.7	33.6	37.3	38	37.9	37.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
166	NML 2	Predicted	25	28.6	33.5	37.2	37.8	37.8	37.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
167	NML 2	Predicted	24.6	28.2	33.1	36.8	37.5	37.4	36.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
168	NML 2	Predicted	24.8	28.4	33.3	37	37.6	37.5	37

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
169	NML 2	Predicted	25.6	29.2	34.1	37.8	38.4	38.4	37.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
17	NML 4	Predicted	20.8	24.6	29.5	33.2	33.9	33.7	33.1
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
170	NML 2	Predicted	25.8	29.3	34.2	37.9	38.6	38.5	38
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
171	NML 2	Predicted	25.8	29.4	34.3	38	38.7	38.6	38
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
172	NML 2	Predicted	18.7	22.6	27.4	31.2	31.8	31.7	31
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
173	NML 2	Predicted	18.8	22.6	27.5	31.3	31.9	31.8	31.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
174	NML 2	Predicted	18.6	22.5	27.4	31.1	31.7	31.6	30.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
175	NML 2	Predicted	18.6	22.5	27.3	31.1	31.7	31.6	30.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
176	NML 2	Predicted	18.6	22.5	27.3	31.1	31.7	31.6	30.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
177	NML 2	Predicted	18.6	22.5	27.3	31.1	31.7	31.6	30.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
178	NML 2	Predicted	22.4	26.1	31	34.7	35.4	35.3	34.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
179	Ignore	Predicted	19.7	23.6	28.4	32.2	32.8	32.7	32
		Daytime Criterion	55	55	55	55	55	55	55
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	55	55	55	55	55	55	55
		Night-time Excess	--	--	--	--	--	--	--
18	NML 4	Predicted	20.7	24.5	29.4	33.2	33.8	33.7	33
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
180	NML 2	Predicted	19.5	23.4	28.2	32	32.6	32.5	31.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
181	NML 2	Predicted	19.4	23.3	28.2	31.9	32.5	32.4	31.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
182	NML 2	Predicted	19.4	23.3	28.1	31.9	32.5	32.4	31.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
183	NML 2	Predicted	22.6	26.3	31.2	34.9	35.6	35.4	34.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
184	NML 1	Predicted	27.8	31.2	36.1	39.8	40.5	40.4	39.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
185	NML 1	Predicted	27.8	31.2	36.1	39.8	40.5	40.4	39.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
186	NML 1	Predicted	27.2	30.6	35.5	39.2	39.9	39.8	39.3
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
187	NML 1	Predicted	26.8	30.3	35.2	39	39.6	39.5	39
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
188	NML 2	Predicted	26.3	29.8	34.7	38.4	39.1	39	38.5
		Daytime Criterion	40	40	40	40	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
189	NML 2	Predicted	26.4	29.9	34.8	38.6	39.2	39.1	38.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
19	NML 6	Predicted	20.5	24.3	29.1	32.9	33.5	33.4	32.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
190	NML 2	Predicted	26.3	29.8	34.7	38.5	39.1	39	38.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
191	NML 1	Predicted	18.8	22.6	27.5	31.3	31.9	31.8	31.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
192	NML 1	Predicted	18.8	22.7	27.6	31.3	31.9	31.8	31.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
193	NML 1	Predicted	23.3	27	31.8	35.6	36.2	36.1	35.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
194	NML 1	Predicted	18.5	22.4	27.2	31	31.6	31.5	30.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
195	NML 1	Predicted	18.7	22.6	27.4	31.2	31.8	31.7	31
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
196	NML 1	Predicted	18.1	22	26.8	30.6	31.2	31.1	30.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
197	NML 1	Predicted	17.8	21.8	26.6	30.4	31	30.9	30.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
198	NML 1	Predicted	17.7	21.6	26.5	30.2	30.8	30.7	30
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
199	NML 2	Predicted	18.3	22.2	27	30.8	31.4	31.3	30.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
2	NML 3	Predicted	18	21.9	26.8	30.6	31.2	31	30.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
20	NML 6	Predicted	21.8	25.6	30.5	34.2	34.8	34.7	34.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
200	NML 1	Predicted	26.3	29.8	34.7	38.4	39.1	39	38.5

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
201	NML 1	Predicted	26.4	29.9	34.8	38.5	39.2	39.1	38.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
202	NML 1	Predicted	27.5	31	35.9	39.6	40.2	40.2	39.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
203	NML 1	Predicted	27.9	31.4	36.2	40	40.6	40.5	40.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
204	NML 1	Predicted	26.8	30.3	35.2	38.9	39.5	39.5	39
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
205	NML 1	Predicted	26.1	29.6	34.5	38.3	38.9	38.8	38.3
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
206	NML 3	Predicted	16.9	20.8	25.7	29.4	30	29.9	29.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
207	NML 3	Predicted	16.7	20.7	25.5	29.3	29.9	29.8	29.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
208	NML 3	Predicted	16.8	20.8	25.6	29.4	30	29.8	29.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
209	NML 4	Predicted	19.5	23.4	28.3	32	32.6	32.5	31.8
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
21	NML 4	Predicted	21.9	25.7	30.6	34.3	34.9	34.8	34.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
210	NML 4	Predicted	18.9	22.8	27.6	31.4	32	31.9	31.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
211	NML 4	Predicted	17.6	21.5	26.4	30.1	30.7	30.6	29.9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
212	NML 4	Predicted	17.7	21.6	26.5	30.3	30.9	30.7	30
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
213	NML 3	Predicted	18.1	22	26.9	30.7	31.3	31.2	30.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
214	NML 3	Predicted	18.3	22.2	27	30.8	31.4	31.3	30.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
215	NML 2	Predicted	26.5	30	34.9	38.6	39.3	39.2	38.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
216	NML 2	Predicted	23.6	27.2	32.1	35.9	36.5	36.4	35.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
217	NML 2	Predicted	23.6	27.2	32.1	35.8	36.5	36.4	35.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
218	Landowner	Predicted	21.9	25.6	30.5	34.3	34.9	34.8	34.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
219	NML 7	Predicted	16.6	20.5	25.4	29.2	29.8	29.6	28.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
22	NML 4	Predicted	21.9	25.7	30.6	34.3	35	34.8	34.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
220	NML 7	Predicted	20.8	24.5	29.4	33.1	33.8	33.6	33.1
		Daytime Criterion	40	40	40	40	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
221	NML 7	Predicted	21	24.7	29.5	33.3	33.9	33.8	33.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
222	NML 7	Predicted	22	25.6	30.5	34.3	34.9	34.8	34.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
223	NML 7	Predicted	22.4	26.1	30.9	34.7	35.3	35.2	34.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
224	NML 7	Predicted	22.6	26.2	31.1	34.8	35.4	35.4	34.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
225	NML 7	Predicted	22.7	26.3	31.2	35	35.6	35.5	34.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
226	NML 7	Predicted	18.1	21.9	26.8	30.6	31.2	31	30.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
227	NML 7	Predicted	18.4	22.2	27.1	30.9	31.5	31.3	30.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
228	NML 7	Predicted	17.6	21.5	26.3	30.1	30.7	30.6	29.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
229	NML 7	Predicted	17.3	21.2	26.1	29.9	30.5	30.3	29.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
23	NML 8	Predicted	30.8	34.2	39	42.8	43.4	43.4	42.9
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	0.4	0.4	--
230	NML 7	Predicted	18.2	22.1	26.9	30.7	31.3	31.2	30.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
231	NML 7	Predicted	17.3	21.2	26	29.8	30.4	30.3	29.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
232	NML 1	Predicted	23.2	26.8	31.7	35.5	36.1	36	35.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
233	NML 1	Predicted	22.9	26.6	31.5	35.2	35.9	35.8	35.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
234	NML 1	Predicted	23.6	27.3	32.1	35.9	36.5	36.4	35.8

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
235	NML 1	Predicted	25	28.6	33.4	37.2	37.8	37.7	37.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
236	NML 1	Predicted	24.3	28	32.8	36.6	37.2	37.1	36.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
237	NML 1	Predicted	25.7	29.3	34.2	37.9	38.5	38.4	37.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
238	NML 1	Predicted	24.9	28.5	33.4	37.1	37.7	37.6	37.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
239	NML 1	Predicted	25	28.6	33.5	37.3	37.9	37.8	37.3
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
240	NML 1	Predicted	24.8	28.5	33.3	37.1	37.7	37.6	37.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
242	NML 1	Predicted	23.4	27.1	31.9	35.7	36.3	36.2	35.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
243	NML 1	Predicted	22.4	26.1	31	34.7	35.3	35.2	34.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
244	NML 1	Predicted	22.4	26.1	31	34.8	35.4	35.3	34.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
245	NML 1	Predicted	24.3	27.9	32.8	36.5	37.2	37.1	36.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
246	NML 1	Predicted	22.7	26.4	31.3	35	35.7	35.6	35
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
247	NML 1	Predicted	22.6	26.3	31.2	35	35.6	35.5	34.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
248	Landowner	Predicted	30.7	34	38.9	42.7	43.3	43.2	42.8
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
249	NML 8	Predicted	29.6	33	37.9	41.6	42.3	42.2	41.8
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
25	NML 5	Predicted	28.4	31.8	36.7	40.5	41.1	41	40.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
250	NML 8	Predicted	28.8	32.2	37.1	40.9	41.5	41.4	41
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
251	NML 8	Predicted	26.4	29.9	34.8	38.5	39.2	39.1	38.6
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
252	NML 8	Predicted	25.4	29	33.8	37.6	38.2	38.1	37.6
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
253	NML 8	Predicted	29.6	33	37.9	41.6	42.3	42.2	41.8
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
254	NML 8	Predicted	26.5	30	34.9	38.6	39.2	39.2	38.7
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
255	NML 6	Predicted	24.4	27.9	32.8	36.5	37.2	37.1	36.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
256	NML 6	Predicted	24.6	28.1	33	36.7	37.3	37.2	36.8
		Daytime Criterion	40	40	40	45	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
257	NML 6	Predicted	25	28.6	33.5	37.2	37.8	37.8	37.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
258	Landowner	Predicted	27.2	30.6	35.5	39.2	39.9	39.8	39.3
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
259	NML 6	Predicted	26.9	30.4	35.2	39	39.6	39.6	39.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
26	NML 5	Predicted	30.9	34.3	39.2	42.9	43.5	43.5	43
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	0.5	0.5	--
260	NML 6	Predicted	27	30.5	35.4	39.1	39.8	39.7	39.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
261	NML 6	Predicted	27	30.4	35.3	39.1	39.7	39.6	39.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
262	NML 6	Predicted	21.3	25	29.9	33.7	34.3	34.2	33.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
263	NML 6	Predicted	21.6	25.3	30.1	33.9	34.5	34.4	33.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
264	NML 6	Predicted	21.8	25.5	30.4	34.1	34.8	34.7	34.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
265	NML 6	Predicted	22.3	26	30.8	34.6	35.2	35.1	34.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
266	NML 6	Predicted	22.3	26	30.8	34.6	35.2	35.1	34.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
267	NML 7	Predicted	19.7	23.6	28.4	32.2	32.8	32.7	32
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
268	NML 7	Predicted	19.9	23.7	28.6	32.4	33	32.8	32.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
269	NML 1	Predicted	18.2	22.1	26.9	30.7	31.3	31.2	30.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
27	NML 5	Predicted	28.6	32.1	36.9	40.7	41.3	41.2	40.8

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
270	NML 1	Predicted	18.5	22.4	27.2	31	31.6	31.5	30.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
271	NML 1	Predicted	18	22	26.8	30.6	31.2	31.1	30.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
272	NML 1	Predicted	18.3	22.3	27.1	30.9	31.5	31.4	30.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
273	NML 1	Predicted	18.2	22.2	27	30.8	31.4	31.2	30.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
274	NML 1	Predicted	18.8	22.7	27.6	31.3	31.9	31.8	31.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
275	NML 1	Predicted	20.1	23.9	28.8	32.5	33.2	33	32.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
276	NML 1	Predicted	19.9	23.7	28.6	32.4	33	32.8	32.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
28	NML 5	Predicted	24.4	28	32.9	36.6	37.2	37.2	36.6
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
280	NML 1	Predicted	19.9	23.7	28.6	32.4	33	32.8	32.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
281	NML 8	Predicted	20.3	24.1	29	32.8	33.4	33.2	32.6
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
282	NML 8	Predicted	20.2	24.1	28.9	32.7	33.3	33.2	32.5
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
283	NML 8	Predicted	20.8	24.6	29.4	33.2	33.8	33.7	33.1
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
284	NML 8	Predicted	21.4	25.2	30	33.8	34.4	34.3	33.7
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
285	NML 8	Predicted	21	24.8	29.6	33.4	34	33.9	33.2
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
286	NML 8	Predicted	21.7	25.4	30.3	34.1	34.7	34.6	34
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
287	NML 8	Predicted	20.5	24.3	29.2	32.9	33.5	33.4	32.8
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
288	NML 7	Predicted	20.9	24.7	29.6	33.3	34	33.8	33.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
289	NML 8	Predicted	20.4	24.2	29	32.8	33.4	33.3	32.6
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
29	NML 5	Predicted	24.2	27.9	32.7	36.5	37.1	37	36.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
290	NML 1	Predicted	19.8	23.6	28.5	32.2	32.8	32.7	32.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
292	NML 1	Predicted	19.4	23.3	28.1	31.9	32.5	32.4	31.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
293	NML 1	Predicted	19.1	23	27.8	31.6	32.2	32.1	31.4
		Daytime Criterion	40	40	40	45	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
294	NML 7	Predicted	24.1	27.6	32.5	36.3	36.9	36.8	36.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
295	NML 1	Predicted	19	22.8	27.7	31.5	32.1	32	31.3
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
296	NML 7	Predicted	24.1	27.7	32.5	36.3	36.9	36.8	36.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
297	NML 7	Predicted	24	27.6	32.4	36.2	36.8	36.7	36.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
298	NML 8	Predicted	24.2	27.8	32.7	36.4	37.1	37	36.4
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
299	NML 8	Predicted	24.4	28	32.9	36.6	37.3	37.2	36.6
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
3	NML 6	Predicted	17.1	21	25.9	29.7	30.3	30.1	29.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
30	NML 5	Predicted	24.2	27.8	32.7	36.5	37.1	37	36.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
300	NML 8	Predicted	23.6	27.3	32.2	35.9	36.5	36.4	35.9
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
301	NML 8	Predicted	23.6	27.3	32.1	35.9	36.5	36.4	35.8
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
302	NML 8	Predicted	22.8	26.5	31.4	35.1	35.8	35.6	35
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
303	NML 8	Predicted	22.6	26.4	31.2	35	35.6	35.5	34.9
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
304	NML 8	Predicted	23.6	27.3	32.2	35.9	36.6	36.4	35.9
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
305	NML 8	Predicted	24.3	27.9	32.8	36.5	37.1	37	36.5
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
306	NML 8	Predicted	23.3	27	31.9	35.6	36.2	36.2	35.6

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
307	NML 7	Predicted	24.3	27.9	32.7	36.5	37.1	37	36.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
308	NML 7	Predicted	22.8	26.4	31.3	35.1	35.7	35.6	35.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
309	NML 7	Predicted	23.2	26.8	31.7	35.4	36.1	36	35.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
31	NML 5	Predicted	24.2	27.9	32.8	36.5	37.2	37	36.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
310	NML 7	Predicted	24	27.5	32.4	36.2	36.8	36.7	36.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
311	Landowner	Predicted	22	25.6	30.5	34.2	34.9	34.8	34.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
312	NML 6	Predicted	21.6	25.3	30.2	33.9	34.6	34.5	33.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
313	NML 6	Predicted	22.9	26.5	31.4	35.1	35.8	35.7	35.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
314	NML 6	Predicted	21.4	25.1	30	33.7	34.3	34.2	33.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
315	NML 6	Predicted	21.8	25.5	30.3	34.1	34.7	34.6	34
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
316	NML 6	Predicted	22.2	25.9	30.8	34.5	35.1	35	34.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
317	NML 6	Predicted	23.9	27.4	32.3	36	36.7	36.6	36.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
318	NML 6	Predicted	21.4	25.1	30	33.7	34.4	34.2	33.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
319	NML 7	Predicted	18.7	22.5	27.4	31.1	31.7	31.6	31
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
32	Ignore	Predicted	24.3	28	32.8	36.6	37.2	37.1	36.6
		Daytime Criterion	55	55	55	55	55	55	55
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	55	55	55	55	55	55	55
		Night-time Excess	--	--	--	--	--	--	--
320	NML 7	Predicted	19.1	22.9	27.8	31.5	32.2	32	31.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
321	NML 6	Predicted	19.9	23.7	28.5	32.3	32.9	32.8	32.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
322	NML 6	Predicted	18.1	21.9	26.8	30.6	31.2	31	30.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
323	NML 7	Predicted	20.1	23.8	28.7	32.4	33.1	33	32.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
324	NML 6	Predicted	18	21.8	26.7	30.5	31.1	31	30.3
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
325	NML 6	Predicted	17.8	21.7	26.6	30.4	31	30.8	30.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
326	NML 7	Predicted	16.5	20.4	25.3	29	29.6	29.5	28.8
		Daytime Criterion	40	40	40	40	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
327	NML 7	Predicted	17.4	21.3	26.2	30	30.6	30.4	29.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
328	NML 7	Predicted	17.9	21.7	26.6	30.4	31	30.8	30.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
329	NML 7	Predicted	17.2	21.1	26	29.8	30.4	30.2	29.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
33	NML 5	Predicted	24.3	27.9	32.8	36.6	37.2	37.1	36.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
330	NML 7	Predicted	17.4	21.3	26.1	29.9	30.5	30.4	29.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
331	NML 7	Predicted	18.7	22.5	27.4	31.1	31.7	31.6	31
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
332	NML 8	Predicted	20.4	24.2	29.1	32.8	33.4	33.3	32.7
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
333	NML 8	Predicted	21.3	25	29.9	33.6	34.3	34.2	33.5
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
334	NML 8	Predicted	21.6	25.4	30.2	34	34.6	34.5	33.9
		Daytime Criterion	45	45	45	45	45	46.3	49
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	45.5
		Night-time Excess	--	--	--	--	--	--	--
335	NML 7	Predicted	16.6	20.5	25.4	29.1	29.7	29.6	28.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
336	NML 6	Predicted	16.4	20.4	25.3	29	29.6	29.5	28.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
337	NML 6	Predicted	16.4	20.4	25.3	29	29.6	29.5	28.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
338	NML 6	Predicted	16.6	20.5	25.4	29.2	29.8	29.6	28.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
339	NML 6	Predicted	19.6	23.4	28.2	32	32.6	32.5	31.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
34	NML 5	Predicted	24.2	27.9	32.7	36.5	37.1	37	36.4

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
340	NML 6	Predicted	19.7	23.5	28.4	32.2	32.8	32.7	32
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
341	NML 6	Predicted	20.4	24.2	29	32.8	33.4	33.3	32.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
342	NML 6	Predicted	21.4	25.1	29.9	33.7	34.3	34.2	33.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
343	NML 6	Predicted	15.9	19.9	24.7	28.5	29.1	29	28.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
344	NML 6	Predicted	16.7	20.6	25.5	29.2	29.8	29.7	29
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
345	NML 6	Predicted	17.4	21.4	26.2	30	30.6	30.5	29.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
346	NML 6	Predicted	17.7	21.6	26.5	30.3	30.9	30.8	30.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
347	NML 6	Predicted	18.4	22.2	27.1	30.8	31.4	31.3	30.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
348	NML 6	Predicted	18.3	22.2	27	30.8	31.4	31.3	30.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
349	NML 6	Predicted	18.3	22.2	27.1	30.8	31.4	31.3	30.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
35	NML 5	Predicted	24.6	28.3	33.1	36.9	37.5	37.4	36.9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
350	NML 7	Predicted	16.2	20.2	25	28.8	29.4	29.3	28.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
351	NML 7	Predicted	16.8	20.8	25.6	29.4	30	29.8	29.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
352	NML 3	Predicted	16.4	20.4	25.2	29	29.6	29.5	28.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
353	NML 6	Predicted	19.1	23	27.8	31.6	32.2	32.1	31.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
354	NML 7	Predicted	23.4	27	31.8	35.6	36.2	36.1	35.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
356	Ignore	Predicted	27.8	31.3	36.2	39.9	40.5	40.4	40
		Daytime Criterion	55	55	55	55	55	55	55
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	55	55	55	55	55	55	55
		Night-time Excess	--	--	--	--	--	--	--
358	NML 3	Predicted	17	20.9	25.8	29.6	30.2	30	29.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
359	NML 3	Predicted	15.8	19.8	24.6	28.4	29	28.8	28.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
36	NML 5	Predicted	26.2	29.8	34.6	38.4	39	38.9	38.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
360	NML 3	Predicted	15.8	19.8	24.7	28.4	29	28.9	28.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
361	NML 3	Predicted	16.1	20	24.9	28.7	29.3	29.1	28.4
		Daytime Criterion	40	40	40	40	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
362	NML 3	Predicted	16.3	20.2	25.1	28.9	29.5	29.3	28.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
364	NML 2	Predicted	19.1	23	27.9	31.6	32.2	32.1	31.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
365	NML 2	Predicted	19	22.8	27.7	31.5	32.1	32	31.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
366	NML 1	Predicted	27.1	30.6	35.4	39.2	39.8	39.7	39.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
367	NML 7	Predicted	25.1	28.6	33.5	37.2	37.9	37.8	37.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
369	NML 4	Predicted	18.5	22.4	27.2	31	31.6	31.5	30.8
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
37	NML 5	Predicted	24.3	28	32.9	36.6	37.2	37.1	36.6
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
370	NML 3	Predicted	26.8	30.3	35.2	38.9	39.6	39.5	39
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
371	NML 3	Predicted	26.8	30.3	35.2	38.9	39.6	39.5	39
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
372	NML 3	Predicted	26.6	30	34.9	38.6	39.3	39.2	38.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
373	NML 2	Predicted	23.8	27.5	32.4	36.1	36.7	36.6	36.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
374	NML 2	Predicted	16.9	20.9	25.8	29.5	30.1	30	29.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
375	NML 2	Predicted	16.3	20.3	25.2	28.9	29.5	29.4	28.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
376	NML 4	Predicted	26.9	30.4	35.3	39.1	39.7	39.6	39.1
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
377	Landowner	Predicted	30.5	33.8	38.7	42.4	43.1	43	42.6

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
378	NML 2	Predicted	19	22.9	27.8	31.5	32.2	32	31.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
379	NML 2	Predicted	22	25.7	30.6	34.3	34.9	34.8	34.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
38	NML 5	Predicted	25.7	29.3	34.2	37.9	38.5	38.4	37.9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
380	NML 2	Predicted	17	20.9	25.8	29.6	30.2	30	29.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
381	NML 3	Predicted	28.9	32.3	37.2	40.9	41.5	41.5	41
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	0.9	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
382	NML 3	Predicted	26.6	30	34.9	38.7	39.3	39.2	38.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
383	NML 3	Predicted	16.8	20.8	25.6	29.4	30	29.9	29.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
384	NML 2	Predicted	17.6	21.5	26.4	30.2	30.8	30.6	29.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
385	NML 3	Predicted	16.9	20.9	25.7	29.5	30.1	30	29.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
386	NML 4	Predicted	16.8	20.8	25.7	29.4	30	29.9	29.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
387	NML 3	Predicted	17.1	21	25.9	29.6	30.2	30.1	29.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
388	NML 3	Predicted	17.1	21.1	25.9	29.7	30.3	30.2	29.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
389	NML 2	Predicted	17.2	21.1	26	29.8	30.4	30.2	29.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
39	NML 4	Predicted	25.4	29	33.9	37.6	38.3	38.2	37.6
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
390	NML 1	Predicted	17.3	21.2	26.1	29.9	30.5	30.3	29.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
391	NML 1	Predicted	17.8	21.7	26.6	30.4	31	30.8	30.1
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
392	NML 1	Predicted	17.6	21.6	26.4	30.2	30.8	30.7	30
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
393	NML 1	Predicted	17.5	21.5	26.3	30.1	30.7	30.6	29.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
394	NML 1	Predicted	17.4	21.4	26.2	30	30.6	30.5	29.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
395	NML 1	Predicted	18.1	22	26.9	30.7	31.3	31.1	30.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
396	NML 6	Predicted	15.1	19.2	24	27.8	28.4	28.2	27.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
397	NML 6	Predicted	15.2	19.3	24.1	27.9	28.5	28.4	27.6
		Daytime Criterion	40	40	40	45	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
398	NML 6	Predicted	15.5	19.5	24.3	28.1	28.7	28.6	27.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
399	NML 6	Predicted	15.5	19.5	24.4	28.2	28.8	28.6	27.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
4	NML 5	Predicted	25.9	29.4	34.3	38	38.7	38.6	38.1
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
40	NML 5	Predicted	26	29.6	34.4	38.2	38.8	38.7	38.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
400	NML 6	Predicted	15.4	19.5	24.3	28.1	28.7	28.6	27.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
401	NML 6	Predicted	15.6	19.6	24.4	28.2	28.8	28.7	27.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
402	NML 6	Predicted	15.6	19.6	24.5	28.3	28.9	28.7	28
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
403	NML 6	Predicted	15.9	19.9	24.8	28.5	29.1	29	28.2
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
404	NML 6	Predicted	16.2	20.2	25.1	28.8	29.4	29.3	28.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
405	NML 6	Predicted	16	20	24.8	28.6	29.2	29.1	28.3
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
406	NML 6	Predicted	15.7	19.7	24.5	28.3	28.9	28.8	28
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
407	NML 6	Predicted	15.3	19.3	24.2	28	28.5	28.4	27.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
408	NML 6	Predicted	15	19	23.9	27.7	28.2	28.1	27.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
409	NML 6	Predicted	15.2	19.3	24.1	27.9	28.5	28.4	27.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
41	Landowner	Predicted	24.3	28	32.9	36.6	37.2	37.1	36.6

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
410	NML 6	Predicted	15.5	19.5	24.4	28.2	28.8	28.6	27.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
411	NML 6	Predicted	15.4	19.4	24.3	28.1	28.7	28.5	27.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
412	NML 6	Predicted	15.6	19.6	24.4	28.2	28.8	28.6	27.9
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
413	NML 6	Predicted	15.5	19.5	24.4	28.1	28.7	28.6	27.8
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
414	NML 7	Predicted	15.6	19.6	24.4	28.2	28.8	28.7	27.9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
415	NML 7	Predicted	15.6	19.6	24.5	28.3	28.9	28.7	28
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
416	NML 7	Predicted	15.6	19.6	24.5	28.3	28.9	28.7	28
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
417	NML 7	Predicted	15.7	19.7	24.5	28.3	28.9	28.8	28
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
418	NML 7	Predicted	15.3	19.3	24.1	27.9	28.5	28.4	27.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
419	NML 7	Predicted	15.7	19.7	24.5	28.3	28.9	28.8	28
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
42	NML 4	Predicted	24.8	28.4	33.3	37	37.7	37.6	37
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
420	NML 7	Predicted	15	19	23.8	27.6	28.2	28.1	27.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
421	NML 7	Predicted	14.7	18.8	23.6	27.4	28	27.8	27.1
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
422	NML 7	Predicted	16.1	20.1	24.9	28.7	29.3	29.2	28.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
423	NML 1	Predicted	16.4	20.4	25.3	29	29.6	29.5	28.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
424	NML 1	Predicted	16.3	20.3	25.2	29	29.6	29.4	28.7
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
425	NML 1	Predicted	16.3	20.3	25.1	28.9	29.5	29.4	28.6
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
426	NML 1	Predicted	16.2	20.2	25	28.8	29.4	29.3	28.5
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
427	NML 1	Predicted	16.1	20.1	25	28.8	29.3	29.2	28.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
428	NML 1	Predicted	16	20.1	24.9	28.7	29.3	29.2	28.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
429	NML 1	Predicted	16	20	24.9	28.6	29.2	29.1	28.3
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
43	NML 4	Predicted	24.7	28.4	33.2	37	37.6	37.5	37
		Daytime Criterion	45	45	45	45	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
430	NML 1	Predicted	16	20	24.9	28.7	29.3	29.1	28.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
431	NML 1	Predicted	17	21	25.9	29.7	30.3	30.1	29.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
432	NML 1	Predicted	17	21	25.8	29.6	30.2	30.1	29.4
		Daytime Criterion	40	40	40	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
433	NML 3	Predicted	16.2	20.1	25	28.8	29.4	29.2	28.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
44	NML 4	Predicted	24.3	28	32.8	36.6	37.2	37.1	36.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
45	NML 4	Predicted	25	28.6	33.5	37.3	37.9	37.8	37.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
46	NML 4	Predicted	24.7	28.3	33.2	37	37.6	37.5	36.9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
47	NML 4	Predicted	24.3	28	32.8	36.6	37.2	37.1	36.6
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
48	NML 4	Predicted	25.2	28.8	33.7	37.5	38.1	38	37.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
49	NML 4	Predicted	24.8	28.4	33.3	37	37.7	37.6	37
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
5	NML 5	Predicted	25.5	29	33.9	37.6	38.3	38.2	37.7
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
50	Landowner	Predicted	29.7	33.1	38	41.8	42.4	42.3	41.9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
51	NML 4	Predicted	29.4	32.8	37.7	41.4	42	42	41.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
52	NML 4	Predicted	28.8	32.2	37.1	40.9	41.5	41.4	41
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
53	NML 4	Predicted	28.7	32.2	37	40.8	41.4	41.3	40.9

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
54	NML 4	Predicted	28.5	32	36.8	40.6	41.2	41.2	40.7
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
55	NML 4	Predicted	28.4	31.9	36.8	40.5	41.1	41.1	40.6
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
56	NML 4	Predicted	28.2	31.7	36.6	40.3	40.9	40.9	40.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
57	NML 4	Predicted	28	31.5	36.4	40.1	40.7	40.6	40.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
58	NML 4	Predicted	27.6	31.1	36	39.7	40.4	40.3	39.8
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
59	NML 4	Predicted	29.6	33	37.8	41.6	42.2	42.2	41.7
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
6	NML 5	Predicted	24.2	27.8	32.7	36.4	37	36.9	36.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
60	NML 4	Predicted	23.6	27.3	32.2	35.9	36.5	36.4	35.9
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
61	NML 4	Predicted	24.2	27.9	32.7	36.5	37.1	37	36.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
62	NML 4	Predicted	24.3	28	32.8	36.6	37.2	37.1	36.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
63	NML 4	Predicted	24.3	27.9	32.8	36.5	37.2	37.1	36.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
64	NML 4	Predicted	24.1	27.8	32.7	36.4	37	37	36.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
65	NML 4	Predicted	23.7	27.4	32.3	36	36.6	36.5	36
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
66	NML 4	Predicted	24.6	28.3	33.1	36.9	37.5	37.4	36.8
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
67	NML 4	Predicted	24.9	28.5	33.4	37.1	37.8	37.7	37.1
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
68	NML 4	Predicted	24.5	28.1	33	36.8	37.4	37.3	36.7
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
69	NML 4	Predicted	26.4	30	34.8	38.6	39.2	39.1	38.6
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
7	NML 5	Predicted	25.4	28.9	33.8	37.6	38.2	38.1	37.6
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
70	Ignore	Predicted	26.7	30.2	35.1	38.8	39.5	39.4	38.9
		Daytime Criterion	55	55	55	55	55	55	55
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	55	55	55	55	55	55	55
		Night-time Excess	--	--	--	--	--	--	--
71	Landowner	Predicted	26.6	30.1	35	38.7	39.4	39.3	38.8
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	45	45	45	45	45	45	45
		Night-time Excess	--	--	--	--	--	--	--
72	Ignore	Predicted	27.2	30.7	35.6	39.3	39.9	39.8	39.3
		Daytime Criterion	55	55	55	55	55	55	55
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	55	55	55	55	55	55	55
		Night-time Excess	--	--	--	--	--	--	--
73	NML 4	Predicted	25.9	29.5	34.4	38.1	38.7	38.6	38.1
		Daytime Criterion	45	45	45	45	45	45	45

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
74	NML 4	Predicted	25.5	29.1	33.9	37.7	38.3	38.2	37.7
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
75	NML 4	Predicted	25.6	29.2	34	37.8	38.4	38.3	37.8
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
76	NML 4	Predicted	27.1	30.6	35.5	39.2	39.9	39.8	39.3
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
77	NML 4	Predicted	25.3	28.9	33.8	37.6	38.2	38.1	37.5
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
78	NML 4	Predicted	25.1	28.8	33.6	37.4	38	37.9	37.4
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
79	NML 3	Predicted	18.9	22.8	27.6	31.4	32	31.9	31.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
8	NML 5	Predicted	24.8	28.4	33.3	37	37.6	37.6	37
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Excess	--	--	--	--	--	--	--
80	Ignore	Predicted	18.4	22.3	27.2	31	31.6	31.4	30.8
		Daytime Criterion	55	55	55	55	55	55	55
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	55	55	55	55	55	55	55
		Night-time Excess	--	--	--	--	--	--	--
81	NML 3	Predicted	18.2	22.1	27	30.8	31.4	31.2	30.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
82	NML 3	Predicted	18	21.9	26.8	30.5	31.1	31	30.3
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
83	NML 3	Predicted	18.1	22	26.8	30.6	31.2	31.1	30.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
84	NML 3	Predicted	17.9	21.8	26.6	30.4	31	30.9	30.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
85	NML 3	Predicted	20.1	23.9	28.8	32.5	33.1	33	32.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
86	NML 3	Predicted	19.2	23	27.9	31.6	32.2	32.1	31.5
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
87	NML 3	Predicted	19.4	23.2	28.1	31.8	32.4	32.3	31.7

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
88	NML 3	Predicted	20	23.8	28.6	32.4	33	32.9	32.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
89	NML 3	Predicted	20.4	24.2	29	32.8	33.4	33.3	32.7
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
9	NML 5	Predicted	24	27.7	32.5	36.3	36.9	36.8	36.2
		Daytime Criterion	45	45	45	45	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
90	NML 3	Predicted	17.5	21.4	26.3	30	30.6	30.5	29.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
91	NML 3	Predicted	17.7	21.6	26.5	30.3	30.9	30.8	30
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
92	NML 3	Predicted	19.5	23.3	28.2	31.9	32.5	32.4	31.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
93	NML 3	Predicted	19.9	23.7	28.6	32.3	33	32.8	32.2
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--

NSL	Survey Location	Parameter	Noise Level, dB L_{A90} at Standardised Wind Speed, m/s						
			3	4	5	6	7	8	9
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
94	NML 3	Predicted	19.7	23.5	28.4	32.2	32.8	32.7	32
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
95	NML 3	Predicted	19.5	23.4	28.2	32	32.6	32.5	31.8
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
96	NML 3	Predicted	20.1	23.9	28.8	32.5	33.1	33	32.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
97	NML 3	Predicted	20.1	23.9	28.8	32.5	33.1	33	32.4
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
98	NML 3	Predicted	19.3	23.2	28	31.8	32.4	32.3	31.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--
99	NML 3	Predicted	20.3	24.1	28.9	32.7	33.3	33.2	32.6
		Daytime Criterion	40	40	40	40	45	45	45
		Daytime Excess	--	--	--	--	--	--	--
		Night-time Criterion	43	43	43	43	43	43	43
		Night-time Excess	--	--	--	--	--	--	--