



Double Bus Bay Shelter & Possible Bus Shelter

Assestion Sheds

ISSUED FOR PLANNING

DRAWING NO. J18-001 016

NOTES:

- LAYOUT IS ONLY INDICATIVE. FINAL POSITION OF SERVICES TO BE CONFIRMED ON SITE
- ALL WORKS TO BE IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE
- ALL WORKS TO BE IN ACCORDANCE WITH IRISH WATER STANDARD DETAILS
- ALL WATERMAIN PIPES TO BE HDPE PE 100 SDR17
- VALVE & FIRE HYDRANT COVERS SHALL BE SURROUNDED BY A CONCRETE PLINTH 200mm WIDE & 100mm DEEP
- WATER SERVICE CONNECTIONS/BOUNDARY BOXES FOR EACH DWELLING TO BE AS PER IRISH WATER STANDARD DRAWING STD-W-02
- COMMERCIAL METERS TO BE INSTALLED AS PER IRISH WATER STANDARD DRAWING STD-W-26
- BULK METERS FOR APARTMENT BLOCKS TO BE INSTALLED AS PER IRISH WATER STANDARD DRAWING STD-W-26

LEGEND:	
	Existing 200mm Watermain
	Existing 100mm Watermain
	Phase 1c Proposed 200mm Watermain
	Phase 1c Proposed 100mm Watermain
	Existing Bulk Flow Meter
	Proposed Scour Valve connection to storm manhole
	Proposed 200mm HDPE Watermain
	Proposed 150mm HDPE Watermain
	Proposed 110mm HDPE Watermain
	Proposed Hydrant
	Proposed Sluice Valve
	Proposed Scour Valve
	Proposed Air Valve
	Proposed Water Meter

REV	DATE	DETAILS
1	19/10/18	ISSUE FOR PLANNING
2	06/11/18	REVISED AS PER IRISH WATER COMMENTS
A	07-12-18	ISSUED FOR PLANNING

JOR
Joseph O'Reilly
Consulting Civil & Structural Engineers

Tel: 046 9077092 Fax: 046 9077932
Email: mail@jor.ie Web: www.jor.ie

Unit 1, St. Theresa's Place, Flowerhill, Navan, Co. Meath

CLIENT	Rockture 1 Limited
PROJECT	Dunshaughlin East SHD Dublin Road, Dunshaughlin, Co. Meath
TITLE	Site Services: Master Watermain Layout
SCALE	1:1250 @ A1
DATE	OCTOBER 2018
DRAWN BY:	LS
CHECKED BY:	MS
JOB No.	J18-001
DRAWING No.	016
REV	A