



- NOTES:**
1. ALL DIMENSIONS NOTED ARE IN MM
 2. POSITION OF LIGHTNING MASTS & LAMP POSTS ARE INDICATIVE AND SUBJECT TO CHANGE DURING DETAILED DESIGN PHASE
 3. POSITION OF BORED WELL AND FOUL HOLDING TANK INDICATIVE ONLY
 4. RURAL SUPPLY POSITION INDICATIVE AND SUBJECT TO CHANGE

LEGEND:

ID	DESCRIPTION
BBPI	BUSBAR POST INSULATOR
BW	BORED WELL
CB	CIRCUIT BREAKER
CC	CABLE CHAIR
CCTV	CLOSED CIRCUIT TELEVISION
CT	CURRENT TRANSFORMER
CTVT	COMBINED CURRENT & VOLTAGE TRANSFORMER
DA	BUSBAR DISCONNECTOR
DB	BUSBAR DISCONNECTOR
DE	EARTH SWITCH
DEM	TRANSFORMER EARTH SWITCH
DG	DIESEL GENERATOR
DL	LINE DISCONNECTOR
DT	TRANSFORMER DISCONNECTOR
FHT	FOUL HOLDING TANK
HDT	HOUSE TRANSFORMER
IFK	INTERFACE KIOSK
LM	LIGHTNING MAST
LP	LAMP POST
LT	LAMP TRAP
NER	NETURAL EARTHING RESISTOR
NER CSE	NER CABLE SEALING END
OLG	OVERHEAD LINE GANTRY
PI	POST INSULATOR
RS	RURAL SUPPLY
SA	SURGE ARRESTER
TP	TELECOMMUNICATIONS POLE
VT	VOLTAGE TRANSFORMER



NORTHERN SITE LEVELS:
 EGL: 41.00mOD
 FGL: 44.00mOD

SOUTHERN SITE LEVELS:
 EGL: 44.00mOD
 FGL: 45.00mOD

- NOTES:**
1. DRAWINGS FOR PLANNING PURPOSES ONLY.
 2. FIGURED DIMENSIONS ONLY TO BE TAKEN FROM THIS DRAWING.
 3. GRID REFERENCES TO IRISH NATIONAL GRID.
 4. ALL LEVELS SHOWN RELATE TO ORDNANCE SURVEY DATUM AT MALIN HEAD

Rev	Date	Description	By	Chkd.
A	Jan. '19	PLANNING ISSUE		ST

Client: **BORD NA MÓNA**
 Naturally Driven

Project: **DERRYADD WIND FARM**

Title: **PROPOSED SUBSTATION PLAN Overhead Line Option A / B**

Scale @ A1: **1:250**

Prepared by: **M. Nolan** Checked: **S. Tinnelly** Date: **January 2019**

Project Director: **D. Grehan**

Drawing Status: **Planning**

TOBIN
 Patrick J. Tobin & Co. Ltd.
 TOBIN Consulting Engineers,
 Block 10-4, Blanchardstown Corporate Park,
 Dublin 15, Ireland.
 tel: +353-(0)1-8030406
 fax: +353-(0)1-8030409
 e-mail: dublin@tobin.ie
 www.tobin.ie

Drawing No.: **10325-2013** Revision: **A**