



**LEGEND**

	PROPOSED SITE BOUNDARY
	PROPOSED 150mm ID MDPE WATER MAIN PIPE
	PROPOSED 100mm ID MDPE WATER MAIN PIPE
	PROPOSED WATER SERVICE PIPE & BOUNDARY BOX
	PROPOSED SCOUR VALVE
	PROPOSED HYDRANT
	PROPOSED SLUICE VALVE
	PROPOSED AIR VALVE
	PROPOSED THRUST BLOCK
	PROPOSED BULK WATER METER
	PROPOSED STORMWATER
	PROPOSED FOUL
	EXISTING WATER MAIN

- NOTES**
- ALL DRAINAGE WORKS SHALL BE CONSTRUCTED IN ACCORDANCE WITH:
    - CIVIL ENGINEERING SPECIFICATION FOR THE WATER INDUSTRY 7TH EDITION,
    - IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE, DECEMBER 2017
  - ALL CONNECTIONS AND FITTINGS TO BE IN ACCORDANCE WITH IRISH WATER STANDARD DETAILS. REFER TO IRISH WATER DOCUMENT WATER INFRASTRUCTURE STANDARD DETAILS, CONNECTIONS AND DEVELOPER SERVICES, DECEMBER 2017.
  - THRUST BLOCKS TO BE PROVIDED AT JUNCTIONS, HYDRANTS AND BENDS (>11.25°).
  - PE-80 SDR17 BLUE PIPES TO BE USED FOR WATER MAINS.
  - PIPES TO SCOUR CHAMBER SHALL BE PROVIDED WITH A NON-RETURN VALVE TO PREVENT BACKFLOW AND AGREED WITH THE LOCAL AUTHORITY.
  - WHERE A MANIFOLD CHAMBER IS USED TO PROVIDE A COMMUNAL BOX, EACH DWELLING UNIT SHALL HAVE ITS OWN SUPPLY PIPE, METER AND STOP VALVE. ALL METERS IN THE MANIFOLD SHALL BE TAGGED TO INDICATE INDIVIDUAL PROPERTIES. UNUSED OUTLETS SHALL BE BLANKED OFF. REFER TO SECTION 3.15.3 OF THE IRISH WATER CODE OF PRACTICE FOR DETAILS.
  - WATER MAIN 'T' JUNCTIONS TO BE CONSTRUCTED AT 90° ANGLES AS PER IRISH WATER STD-W-07.

E	11.01.19	PLANNING	NOM	PMS
rev.	date	amendment	drn	ckd

PROPOSED HOUSING DEVELOPMENT  
CREAGH, GOREY, CO. WEXFORD

PROPOSED WATER MAINS

LAYOUT PLAN  
SHEET 1

**IE CONSULTING**  
WATER-ENVIRONMENTAL-CIVIL

INNOVATION CENTRE TELEPHONE: 059 91 33084  
GREEN ROAD FAX: 059 91 40499  
CARLOW EMAIL: info@iece.ie

file location:	N:\IE1505\DRAWINGS	scale:	1:500	A1
drawing status:	PLANNING	datum:	MALIN	
drawing no.	IE1505-007	drawn:	NOM	
		checked:	PMS	
		approved:	PMS	
		date:	11.01.2019	

© IE Consulting. This drawing or its contents must not be reproduced for any purpose without written permission. It is to be used only for the purpose for which it is supplied.