

THE INFORMATION ON THIS DRAWING IS TO THE ORDINANCE SURVEY IRELAND ITM COORDINATE SYSTEM

- NOTES:
1. Pump Station to be in accordance with STD-VW-28.
 2. Valves to have mass concrete thrust block as per standard detail STD-VW-28.
 3. The design takes account of the following from the Hydro Environmental Flood Risk Assessment
 - 200 year flood level = 4.47m OD Main
 - 1000 year flood level = 4.47m OD Main
 - Freeboard of 0.33m = 5.07m OD Main
 The levels of the slab are at 5.10m is above the levels as outlined.

- NOTES:
1. FIGURED DIMENSIONS ONLY TO BE TAKEN FROM THIS DRAWING.
 2. ALL DRAWINGS TO BE CHECKED BY THE CONTRACTOR ON SITE
 3. ENGINEER/EMPLOYERS REPRESENTATIVE, AS APPROPRIATE, TO BE INFORMED BY THE CONTRACTOR OF ANY DISCREPANCIES BEFORE ANY WORK COMMENCES
 4. THE CONTRACTOR SHALL UNDERTAKE A THOROUGH CHECK FOR THE ACTUAL LOCATION OF ALL SERVICES/UTILITIES ABOVE AND BELOW GROUND, BEFORE ANY ALL LEVELS'S SHOWN RELATE TO ORDNANCE SURVEY DATUM AT MAIN HEAD
 5. ALL LEVELS'S SHOWN RELATE TO ORDNANCE SURVEY DATUM AT MAIN HEAD
 6. FINISHED LEVELS SUBJECT TO ARCHITECTS APPROVAL

Rev	Date	Description	By	Chkd
B	21/02/19	Wall Removed	FG	BR
A	20/08/2018	Issue for Planning	JK	BR

Client: **ARLUM LTD.**

Project: **Residential Development
Moneyduff, Oranmore
Co. Galway**

Title: **Typical Pumping Station Details**

Scale @ A1: **1:50 @A3: 1:100**

Prepared by: **JK** Date: **March 2018**
 Checked: **BR**
 Project Director: **Michael McDonnell**
 Drawing Status: **Planning**

TOBIN
 Patrick J. Tobin & Co. Ltd.
 TOBIN Consulting Engineers,
 Falgoutree House, Falgoutree Road,
 Galway, Ireland.
 Tel: +353-(0)9-4565211
 Fax: +353-(0)9-4565288
 e-mail: info@tobin.ie
 www.tobin.ie

Drawing No.: **10402-2013** Revision: **B**

