



INSTALL KINGSPAN - KLARGESTER CLASS 1 BYPASS SEPARATOR REFERENCE NSBE015 ON SURFACE WATER LINE PRIOR TO DISCHARGE TO ATTENUATION BASIN/POND.

SILT TRAP TO BE INSTALLED PRIOR TO PETROL INTERCEPTOR. WHERE TRAP SHALL HAVE A MINIMUM VOLUME OF 2.50M3.

PERMEABLE DRAINAGE SYSTEM UNDER ALL CAR PARKS CONNECTED TO SWALE AS SHOWN



CULVERT OUTLET @ DISCHARGE POINT

450MMØ PIPELINE FROM FROM INFILTRATION BASIN/POND TO DISCHARGE INTO 1000MM WIDE X 750MM HIGH BOX CULVERT WHERE CULVERT SHALL EXTEND TO END OF EXISTING OPEN CHANNEL. BOX CULVERT SHALL BE LAID AT MINIMUM GRADIENT WHERE THERE SHALL BE 150MM LEVEL DEPTH OF WATER IN BOTTOM OF CULVERT AT ALL TIMES. VELOCITY OF WATER EXITING 450MM DIA PIPELINE = 1.86LS/S VELOCITY OF WATER EXITING CULVERT = .465LS/S

NEW HEAD WALL TO BE CONSTRUCTED AT OUTLET FROM BOX CULVERT AS SHOWN. FORM RIPRAP APRON AT OUTLET FROM CULVERT BY LAYING 100MM BROKEN STONE. WHERE APRON SHALL BE 2.00M LONG AND 250MM DEEP

MH No.	MANHOLE DIAMETER	MANHOLE TYPE	COVER LEVEL	INVERT LEVEL	DEPTH TO SOFFIT	EASTING	NORTHING
SMH1	1200	Type E	23.025	21.845	1.180	709666.070	804500.880
SMH2	1200	Type E	23.224	20.255	2.969	709618.981	80418.875
SMH3	1200	Type E	20.591	19.915	0.676	709632.781	80423.054
SMH4	1200	Type E	21.272	19.915	1.357	709698.842	80452.854
SMH5	1200	Type E	21.015	19.276	1.739	709662.249	80446.200
SMH6	1200	Type E	20.591	19.096	1.495	709670.872	80410.431
SMH7	1200	Type E	20.327	18.983	1.344	709679.910	80416.413
SMH8	1200	Type E	19.925	18.273	1.652	709745.791	80471.407
SMH9	1200	Type E	21.630	20.227	1.403	709736.743	80463.269
SMH10	1200	Type E	21.441	19.728	1.713	709720.059	80419.610
SMH11	1200	Type E	20.993	19.200	1.793	709723.218	80413.770
SMH12	1200	Type E	19.814	17.113	2.701	709779.890	80439.881
SMH13	1200	Type E	19.902	14.761	5.141	709628.343	80492.985
SMH14	1200	Type E	19.500	13.696	5.804	709687.571	80481.411
SMH15	1200	Type E	19.089	12.708	6.381	709622.369	80436.889
SMH16	1200	Type E	17.862	16.226	1.636	709691.841	80426.680
SMH17	1200	Type E	18.351	15.976	2.375	709612.214	80483.087
SMH18	1200	Type E	20.162	15.736	4.426	709655.011	80422.987
SMH19	1200	Type A	19.641	15.467	4.174	709634.905	80427.949
SMH20	1200	Type E	18.291	16.819	1.472	709550.894	80421.079
SMH21	1200	Type E	19.637	16.216	3.421	709614.157	80401.987
SMH22	1200	Type A	19.580	15.277	4.303	709634.905	80426.769
SMH23	1200	Type E	18.804	17.268	1.536	709742.977	80482.247
SMH24	1200	Type B	17.422	14.677	2.745	709748.762	80424.200
SMH25	1200	Type E	15.529	13.461	2.068	709681.879	80421.268
SMH26	1200	Type E	14.986	13.964	1.022	709694.687	80416.704
SMH27	1200	Type D	13.812	12.889	0.923	709687.422	80425.814
SMH28	1200	Type E	14.378	11.897	2.481	709622.332	80426.797
SMH29	1200	Type A	13.922	12.244	1.678	709624.117	80401.987
SMH30	1200	Type E	14.017	11.736	2.281	709642.618	80487.215
SMH31	1200	Type E	15.211	14.074	1.137	709696.002	80494.418
SMH32	1200	Type E	14.764	13.039	1.725	709700.096	80426.895
SMH33	1200	Type E	14.978	13.311	1.667	709653.339	80429.791
SMH34	1200	Type E	15.133	11.616	3.517	709619.532	80407.593
SMH35	1200	Type B	14.269	12.26	2.009	709722.858	80426.192
SMH36	1200	Type E	13.220	10.897	2.323	709712.218	80426.262
SMH37	1200	Type D	11.971	9.71	2.260	709702.706	80479.600
SMH38	1200	Type E	10.266	8.13	2.133	709684.880	80434.343
SMH39	1200	Type D	10.45	6.30	4.150	709712.142	80433.488
SMH40	1200	Type D	9.229	8.10	1.129	709701.157	80436.414
SMH41	1200	Type D	8.915	7.87	1.044	709691.889	80436.871
SMH42	1200	Type C	8.255	7.25	1.000	709683.558	80435.024
SMH43	1200	Type D	8.240	7.416	0.824	709655.888	80475.889
SMH44	1200	Type E	15.647	14.241	1.406	709555.314	80401.078
SMH45	1200	Type E	16.625	14.133	2.492	709514.445	80487.425
SMH46	1200	Type E	13.701	12.291	1.410	709535.121	80417.444
SMH47	1200	Type A	15.613	12.991	2.622	709525.210	80438.175
SMH48	1200	Type E	16.185	14.817	1.368	709532.831	80439.074
SMH49	1200	Type E	17.278	16.901	0.377	709525.297	80433.965
SMH50	1200	Type E	18.318	13.875	4.443	709550.932	80490.404
SMH51	1200	Type A	17.397	13.52	3.877	709608.121	80414.037
SMH52	1200	Type A	16.597	11.865	4.732	709628.008	80438.983
SMH53	1200	Type A	15.460	11.355	4.105	709610.837	80435.776
SMH54	1200	Type E	12.819	11.428	1.391	709675.289	80428.858
SMH55	1200	Type B	13.906	11.035	2.871	709668.498	80430.534
SMH56	1200	Type A	14.415	10.801	3.614	709670.309	80430.479
SMH57	1200	Type B	13.802	10.954	2.848	70972.908	80430.863
SMH58	1200	Type C	10.871	9.45	1.421	70974.584	80433.289
SMH59	1200	Type B	11.484	9.16	2.324	70979.981	80417.792
SMH60	1200	Type A	12.299	8.90	3.399	70978.651	80438.973
SMH61	1200	Type B	11.273	8.50	2.773	709688.827	80438.791
SMH62	1200	Type E	9.948	8.603	1.345	70968.948	80448.989
SMH63	1200	Type B	10.252	8.902	1.350	70961.659	80447.881
SMH64	1200	Type B	10.161	8.25	1.916	70969.890	80447.474
SMH65	1200	Type B	10.108	8.14	1.964	70981.273	80442.709
SMH66	1200	Type E	9.905	8.484	1.421	70981.273	80442.709
SMH67	1200	Type B	10.414	7.85	2.569	70983.665	80441.989
SMH68	1200	Type D	8.336	7.50	0.836	70984.412	80431.186
SMH69	1200	Type C	8.910	7.437	1.473	70985.353	80438.792
SMH70	1200	HEADWALL	8.672	7.297	1.375	70984.823	80439.245
SMH71	1200	Type B	8.782	6.80	1.982	70990.680	80438.790
SMH72	1200	Type B	8.990	6.48	2.512	70992.497	80445.500
SMH73	1200	Type A	9.996	6.37	3.629	70991.723	80491.388
SMH74	1200	Type D	8.40	6.225	2.175	70994.294	80448.451
SMH75	1200	Type E	8.50	5.771	2.729	70995.964	80450.819
SMH76	1200	Type E	8.35	6.907	1.443	70990.992	80451.501
SMH77	1200	Type D	7.80	6.60	1.200	70991.542	80455.385
SMH78	1200	Type B	8.307	6.06	2.241	70995.621	80454.868
SMH79	1200	Type C	4.680	3.07	1.603	70988.872	80457.721
SMH80	1200	Type E	4.195	2.790	1.405	70993.229	80450.547
SMH81	1200	Type D	3.952	2.914	1.038	70997.087	80462.300
SMH82	1200	Type D	3.999	2.202	1.797	70998.940	80467.814
SMH83	1200	Type D	3.565	1.728	1.837	70998.940	80463.812
SMH84	1200	HEADWALL	3.42	1.516	1.904	70998.940	80463.812
SMH85	1200	Type D	11.428	10.434	0.994	70998.938	80424.950
SMH86	1200	Type D	8.267	7.15	1.117	70998.938	80428.771
SMH87	1200	Type D	5.408	4.185	1.223	70998.938	80430.560
SMH88	1200	Type D	4.015	2.44	1.575	70998.938	80428.967
SMH89	1200	Type D	3.772	2.15	1.622	70998.938	80428.967
SMH90	1200	HEADWALL	2.95	2.022	0.928	70998.938	80428.967

Key Plan

B	Issued for Planning	May 2019	T.Finn
A	Box Culvert added as discharge of attenuated storm flows	Sept 2108	T.Finn
REV. NO.	DESCRIPTION	DATE	INITIALS

STAINLESS STEEL HYDROBRAKE FLOW CONTROL DEVICE TO BE FITTED WITHIN MANHOLE SMH71 ON INLET PIPE FROM ATTENUATION BASIN/POND TO CONTROL FLOWS TO 80.6 litres/sec.

IN ADDITION A SECONDARY PNEUMATICALLY CONTROLLED SLAM-SHUT/PENSTOCK VALVE SHALL BE FITTED INSIDE THE MANHOLE THAT CAN BE CLOSED WHERE THE SURFACE WATER RUNOFF FROM THE SITE BECOMES CONTAMINATED AND WHERE THE RUNOFF NEEDS TO BE RETAINED ON SITE TO ALLOW SUFFICIENT TIME FOR TESTING AND IMPLEMENTATION OF PLAN TO REMOVE RUNOFF FROM SITE, IF REQUIRED.

INSTALL KINGSPAN KLARGESTER CLASS 1 BYPASS SEPARATOR REFERENCE NSBE030 ON SURFACE WATER LINE PRIOR TO DISCHARGE TO ATTENUATION BASIN/POND.

SILT TRAP TO BE INSTALLED PRIOR TO PETROL INTERCEPTOR. WHERE TRAP SHALL HAVE A MINIMUM VOLUME OF 4.50M3.

LEGEND:

	ROAD EDGE (IN-SITU KERB)		ROAD GRADIENT
	FOOTPATH EDGE		ROAD DIMENSION
	ROAD CENTRELINE		PERMEABLE PAVING TO CAR PARKS 1-8
	ROAD CHANNEL LINE		ROAD SURFACE
	ROAD RAMP		FOOTPATH SURFACE
	DROPPED KERB WITH TACTILE PAVING		RAISED TABLE
	CORDUROY PAVING		SHARED SURFACE - VEHICULAR (HOMEZONE)
	CAR DRIVEWAYS		PARKING
	GROUND FLOOR LEVEL		GRASS/PLANTING
			TACTILE PAVING

NOTES:

THE GREENFIELD RUNOFF RATE OF (GBAR) 105.90 L/TS/SEC IS CALCULATED ON A SITE AREA OF 175000M2 OR 17.5HA. THE GRAB RATE USED FOR THE CALCULATION OF THE REQUIRED ON SITE STORAGE IS REDUCED TO 80.6 L/TS/SEC TO COMPENSATE FOR THE 25.3 L/TS/SEC OF RUNOFF THAT IS NOT ATTENUATED AND WHICH IS DERIVED FROM THE NORTHEAST CORNER OF THE DEVELOPMENT. THE ATTENUATION SYSTEM CONSISTS OF A SILT TRAP, CLASS 1 BYPASS PETROL INTERCEPTOR ON ALL NEW PIPEWORK AND AN ATTENUATION BASIN/POND HAVING A STORAGE VOLUME OF 3000M3. THE CRITICAL STORM DURATION FOR A 1 IN 30 YR STORM EVENT IS 30MIN (WINTER) WHERE THE REQUIRED STORAGE VOLUME IS 2978.7M3. THE CRITICAL STORM DURATION FOR A 1 IN 100 YR STORM EVENT IS ALSO 30MIN (WINTER) WHERE THE REQUIRED STORAGE VOLUME IS 2975.70M3 RESULTING IN AN OVERFLOW OF 13.30M3.

ALL STORM DRAINAGE PIPE LINES HAVE BEEN DESIGNED FOR 1 IN 2 YR RETURN PERIOD WITH A MAXIMUM RAINFALL OF 50MM/HR. MINIMUM SELF CLEANSING VELOCITY OF 0.8L/SEC & MINIMUM TIME OF ENTRY 4 MINS. 10% ALLOWANCE HAS BEEN INCLUDED FOR GLOBAL CLIMATE CHANGE.

ALL COVER LEVELS ARE INDICATIVE AND THE FINAL COVER LEVELS TO MATCH FINISHED PATHWAY LEVELS.

ALL LEVELS FOR PIPES TO BE CHECKED AND VERIFIED PRIOR TO WORK COMMENCING ON SITE.

THE LAYOUT OF THE BRANCH DRAINS FROM THE INDIVIDUAL SITES ARE AS SHOWN ON THE DWELLINGS LAYOUT PLAN. ANY CHANGES ARE TO BE AGREED PRIOR TO CONSTRUCTION. THE DISTANCE FROM THE FINAL ACCESS JUNCTION ON EACH INDIVIDUAL SITE TO THE CONNECTION TO THE MAIN DRAIN TO BE A MAXIMUM OF 12m.

THE CONNECTION OF THE BRANCH DRAINS TO MAIN DRAINS SHOULD BE MADE AT A MANHOLE WHERE POSSIBLE OR BY USING AN ORBICULAR TYPE SADDLE. SADDLES SHOULD NOT BE USED ON PIPES OF 100mm DIAMETER. NOR TO CONNECT PIPES OF THE SAME DIAMETER.

ALL PIPES SHOULD HAVE FLEXIBLE JOINTS FORMED BY A METHOD RECOMMENDED BY THE PIPE MANUFACTURER. ELASTOMERIC SEALING RINGS, COMPLYING WITH THE REQUIREMENTS OF BS 2494, TYPE D, SHOULD BE USED.

MANHOLE COVERS AND FRAMES (TO COMPLY WITH THE REQUIREMENTS OF IS EN 124):
 CLASS D 400
 B 125
 FOOTWAYS: GRASS VERGES
 AREAS INACCESSIBLE TO MOTOR VEHICLES

ALL BRANCH CONNECTIONS FROM ACCESS JUNCTIONS (AJS) TO BE 100mmØ uPVC PIPES AT A GRADIENT OF 1 IN 60.

GULLIES SHALL BE PRECAST CONCRETE COMPLYING WITH THE REQUIREMENTS OF BS 5911: PART 230, OR MAY CONSIST OF A CHAMBER CONSTRUCTED OF 100mm Ø SCLD BLOCKWORK AND HAVING A 100mm IN SITU CONCRETE FLOOR. WITH INTERNAL DIMENSIONS OF 400mm x 300mm x 100mm. THE OUTLET FROM THE GULLY SHOULD BE 150mm DIAMETER. SET A MINIMUM OF 375mm ABOVE THE FLOOR OF THE CHAMBER.

GULLY GRATINGS IN ROADS SHOULD BE SET WITH THE DIRECTION OF THE OPENINGS AT RIGHT ANGLES TO THE DIRECTION OF TRAFFIC.

LOCATION AND INVERT LEVELS OF EXISTING (OR PROPOSED) MANHOLES OR OUTLET POINTS TO BE VERIFIED PRIOR TO COMMENCEMENT OF CONSTRUCTION OF PROPOSED DRAINAGE NETWORK.

THE TYPE OF PIPE AND FITTINGS TO BE USED TO BE uPVC FOR PIPES UP TO 300mm IN DIAMETER (IN ACCORDANCE WITH THE REQUIREMENTS OF IS 424).

TRENCH WIDTH AT THE LEVEL OF THE TOP OF THE PIPE SHOULD GENERALLY BE AS NARROW AS SAFE WORKING CONDITIONS WOULD ALLOW, WITH A MINIMUM WIDTH OF 300mm PLUS THE EXTERNAL DIAMETER OF THE PIPE BARREL.

DRAINS SHALL BE ACCESSIBLE FOR MAINTENANCE AND REPAIR AND SHALL BE CONSTRUCTED ON PUBLIC PROPERTY. ACCESS SHALL GENERALLY BE PROVIDED BY MEANS OF A MANHOLE BUT, SUBJECT TO APPROVAL, A PROPRIETARY ACCESS JUNCTION MAY BE USED IN LIEU OF A MANHOLE. ON A DRAIN WHERE THE DEPTH TO INVERT IS LESS THAN 600mm.

DRAINAGE PIPES SHOULD BE LAID WITH A MINIMUM COVER OF 1.2m IN ROADS AND DRIVEWAYS, 0.9m IN OPEN SPACES AND FOOTPATHS NOT ADJACENT TO ROADWAYS AND 0.6m IN GARDENS. WHERE IT IS NOT POSSIBLE TO ACHIEVE THESE MINIMUM COVERS, ADDITIONAL MEASURES SHOULD BE TAKEN TO PROTECT PIPEWORK. DETAILS SHOULD BE AGREED WITH THE ENGINEER PRIOR TO CONSTRUCTING THE PIPELINE.

finn DESIGN PARTNERSHIP
 Creative • Innovative

Blakestown, Ardee, Co. Louth, Ireland
 t 041 6857200 e info@finn.ie www.finn.ie

DRAWING NO: **114B** REV. NO:

Storm Drainage Layout Zone 4

PROJECT: Haggardstown, Blackrock, Dundalk Residential Development @

CLIENT: Kingsbridge Consultancy Ltd
 1st Floor Quayside Business Park
 Mill Street, Dundalk, Co Louth.

SCALE: 1:500 @ A1 DRAWN: P.Coyle

DATE: November 2018 CHECKED:

STATUS: **Planning Permission**

JOB NO: **1703**

NOTES:
 1. Copyright Reserved 2008 ©
 2. Work to agreed dimensions only. Do not scale drawing.
 3. All dimensions are to be taken from the finished ground level unless otherwise specified.
 4. Where appropriate, for details of structure, or mechanical and electrical details, see Engineers drawings.
 5. Proprietary items shall be fixed to site accordance with manufacturers instructions.
 6. The contractor shall be responsible for the construction of structure, finishes and services.

© CIVIL - STRUCTURAL ENGINEERING PROJECT MANAGEMENT