


NOTES:

- 1. EACH UNIT TO BE PROVIDED WITH A WATER SERVICE CONTROL UNIT (WSCU). EACH WSCU TO HAVE AN ACCESS LID AND STOPOCK. TYPE OF WSCU TO BE APPROVED BY LOUTH COUNTY COUNCIL.
- 2. ALL WSCUS TO BE LOCATED IN PUBLIC FOOTPATHS (OUTSIDE OF INDIVIDUAL SITES).
- 3. ALL WATERMANS FOR THE DEVELOPMENT TO BE 100mm CLASS C uPVC PIPES EXCEPT WHERE UNDER ROADWAYS WHERE EQUIVALENT DUCTILE IRON PIPES TO BE USED.
- 4. WATER SERVICE CONNECTION TO UNITS TO BE 12mm POLYETHYLENE TYPE 32HEAVY GAUGE TO ISO 154.
- 5. WATERMAIN PIPES TO HAVE MINIMUM COVER OF 900mm. SERVICE PIPES SHOULD HAVE A MINIMUM COVER OF 600mm.
- 6. SERVICE PIPES TO HAVE 100mm SURROUND CONSISTING OF 10mm PEA GRAVEL.
- 7. AIR VALVES TO BE LOCATED AT HIGH POINTS AND SCOUR VALVES TO BE LOCATED AT LOW POINTS ON THE PIPE NETWORK. LOCATION OF ALL VALVES TO BE AGREED WITH LOUTH COUNTY COUNCIL.
- 8. WATERMANS SHOULD BE LOOPED AS SHOWN ON THIS DRAWING. WHERE DEAD ENDS ARE USED, A DUCK FOOT HYDRANT SHOULD BE PROVIDED AT THE DEAD END.
- 9. MARKER POSTS TO BE INSTALLED AT ALL SLUICE VALVES, FIRE HYDRANTS, AIR VALVES & SCOUR VALVES. ALL TEES SPECIAL BENDS TO BE FLANGED ONLY.
- 10. JOINTS SHALL BE FORMED BY AN APPROVED METHOD, RECOMMENDED BY THE MANUFACTURER. ELASTOMERIC SEALING RINGS, WHERE USED, SHOULD COMPLY WITH THE REQUIREMENTS OF BS 2494.
- 11. CONCRETE ANCHOR BLOCKS SHOULD BE PROVIDED ON WATERMANS AT DEAD ENDS. TEES, BENDS OF CURVATURE GREATER THAN 22.5° AND AT BOTH SIDES OF A SLUICE VALVE CHAMBER. ANCHOR BLOCKS SHOULD ENCASE THE PIPE IN CONCRETE (CLASS C, CLASS E, CLASS E2 SPECIFICATION FOR ROADWORKS), TO A MINIMUM THICKNESS OF 150mm ALL ROUND AND SHOULD BE A MINIMUM LENGTH OF 750mm.
- 12. DUCTILE IRON PIPES TO BE USED UNDER ROADWAYS AND PARKING BAYS.
- 13. ALL WATERMANS TO BE OVERLAID WITH MARKER TAPE COMPLETE WITH 2 STRANDS OF CONTINUOUS TRACER WIRE. TRACER WIRE TO BE CONNECTED TO FITTINGS. CONTINUITY OF TRACER WIRE TO BE ENSURED AT ENDS OF ROLLS, FITTINGS AND CHANGES IN DIRECTION.
- 14. HYDRANT, SLUICE VALVE, AIR VALVE AND STOPOCK CHAMBERS SHOULD BE PROVIDED WITH CAST IRON SURFACE BOXES IN COMPLIANCE WITH THE REQUIREMENTS OF IS 201. SURFACE BOXES FOR ROADWAYS AND AREAS ACCESSIBLE TO WHEELER TRAFFIC SHOULD BE SUBJECT TO APPROVAL.
- 15. THE LOCATION OF HYDRANTS, AIR VALVES AND SLUICE VALVES SHOULD BE SHOWN BY INDICATOR PLATES POSITIONED TO THE APPROVAL OF LOUTH COUNTY COUNCIL.
- 16. ALL WATERMANS SHOULD BE HYDRAULICALLY TESTED AFTER LAYING. TO BE TESTED IN SECTIONS AT 1.5 TIMES ITS OPERATING PRESSURE AND BE WITNESSED AND CERTIFIED BY A REPRESENTATIVE OF DBOLCC. METHOD OF TESTING AS APPROVED BY LOUTH COUNTY COUNCIL. THE PIPELINE SHOULD BE ADEQUATELY ANCHORED OR RESTRAINED, DURING TESTING.
- 17. ALL WATERMANS TO BE FULLY CLEANED AND STERILISED BEFORE THE COMPLETION AND HANDOVER OF THE DEVELOPMENT OR PARTS THEREOF.
- 18. CONNECTIONS TO PUBLIC MAINS AND THE INDIVIDUAL RESIDENTIAL CONNECTIONS TO THE NEW SITE MAIN HAVE TO BE CARRIED OUT BY A LOUTH COUNTY COUNCIL APPROVED PLUMBER AND CERTIFIED ACCORDINGLY.
- 19. ALL WORKS WILL BE CARRIED OUT IN CONJUNCTION WITH IRISH WATER CODE OF PRACTICE FOR POTABLE WATER INFRASTRUCTURE AND IRISH WATER STANDARD DETAILS FOR POTABLE WATER.
- 20. ALL DETAILS FOR POTABLE WATER MUST COMPLY WITH IRISH WATER STANDARD DETAILS: IW-CDS-5020-01



REV. NO.	DESCRIPTION	DATE	INITIALS
B	Issued for Planning	May 2019	T. Finn
A	Issued to Irish Water for Statement of Acceptance	28th April 2019	T. Finn

finn
DESIGN PARTNERSHIP
CREATIVE • INNOVATIVE

Blakestown, Ardee, Co. Louth, Ireland
t 041 6857200 f 041 6857201 e info@finn.ie w www.finn.ie

DRAWING NO: **134 B** REV. NO:

TITLE: **Watermain Layout Zone 4**

PROJECT: **Residential Development @ Haggardstown, Blackrock, Co Louth**

CLIENT: **Kingsbridge Consultancy Ltd
1st Floor, Block 1, Quayside Business Park,
Mill Street, Dundalk, Co. Louth;**

SCALE: **1:500 @ A1** DRAWN: **PC**

DATE: **November 2018** CHECKED:

STATUS: **Planning Permission**

JOB NO: **1703**

NOTES:
1. Copyright Reserved 2003 ©
2. Work to figure dimensions only. Do not scale drawing.
3. The contractor is responsible for checking all levels and dimensions on site and shall refer all discrepancies to the Architect.
4. Where appropriate, for cables, conduits, or mechanical and electrical applications, see Engineers drawings.
5. Proprietary items shall be fixed in strict accordance with manufacturers instructions.
6. Where appropriate, items shall be checked with manufacturer.
7. The contractor shall be responsible for the coordination of structure, fixtures and services.

● CIVIL - STRUCTURAL ENGINEERING ● PROJECT MANAGEMENT